



Listing and Technical Evaluation Report™

A Duly Authenticated Report from an Approved Agency

Report No: 1504-05



Issue Date: August 24, 2016

Revision Date: September 30, 2025

Subject to Renewal: October 1, 2026

Rmax® ThermaBase-CI™

Trade Secret Report Holder:

Rmax® a Business Unit of Sika Corporation

Phone: 972-850-3652

Website: www.rmax.com

Email: technical@rmax.com

CSI Designations:

DIVISION: 06 00 00 - WOOD, PLASTICS AND COMPOSITES

Section: 06 16 00 - Sheathing

Section: 06 16 13 - Insulated Sheathing

DIVISION: 07 00 00 - THERMAL AND MOISTURE PROTECTION

Section: 07 20 00 - Thermal Protection

Section: 07 21 00 - Thermal Insulation

Section: 07 27 00 - Air Barriers

1 Innovative Product Evaluated¹

1.1 Rmax ThermaBase-CI

2 Product Description and Materials

2.1 The innovative product evaluated in this report is shown in **Figure 1**.



Figure 1. ThermaBase-CI



- 2.2 ThermaBase-CI is a composite product that consists of an Rmax rigid, closed-cell polyisocyanurate (polyiso) Foamed Plastic Insulating Sheathing (FPIS) board bonded to either Oriented Strand Board (OSB), or CDX plywood with a proprietary adhesive.
- 2.2.1 ThermaBase-CI conforms to ASTM C1289 Type V and is available in up to 4.5" in foam thickness, plus the thickness of the OSB portion of the product.
- 2.2.2 The Rmax polyiso FPIS component conforms to ASTM C1289.
- 2.2.2.1 Rmax Thermasheath® conforms to ASTM C1289 Type I, Class 1 and Class 2. Additional information regarding Rmax Thermasheath can be found in Report Number [1309-03](#).
- 2.2.2.2 Rmax Durasheath® conforms to ASTM C1289 Type II, Class 2. Additional information regarding Rmax Durasheath can be found in Report Number [2202-02](#).
- 2.2.2.3 The rigid insulation portion is available in the following nominal thicknesses: 1/2" (12.7 mm) through 4 1/2" (114 mm).
- 2.2.3 The OSB component conforms to DOC PS 2 as specified in [IBC Section 2303.1.5](#) and [IRC Section R604.1](#).
- 2.2.3.1 The standard nailing surface for ThermaBase-CI is 7/16" (11 mm) OSB.
- 2.2.4 The CDX plywood component conforms to DOC PS 1 as specified in [IBC Section 2303.1.5](#) and [IRC Section R604.1](#).
- 2.2.4.1 Plywood is available as an alternate nailing surface.
- 2.2.5 Other OSB or CDX plywood thicknesses may be available upon request.
- 2.3 *Material Availability*
- 2.3.1 *Standard Product Width:*
- 2.3.1.1 48" (1,219 mm)
- 2.3.2 *Standard Product Length:*
- 2.3.2.1 96" (2,438 mm)
- 2.4 As needed, review material properties for design in **Section 6** and the regulatory evaluation in **Section 8**.

3 Definitions²

- 3.1 New Materials³ are defined as building materials, equipment, appliances, systems, or methods of construction, not provided for by prescriptive and/or legislatively adopted regulations, known as alternative materials.⁴ The design strength and permissible stresses shall be established by tests⁵ and/or engineering analysis.⁶
- 3.2 Duly authenticated reports⁷ and research reports⁸ are test reports and related engineering evaluations that are written by an approved agency⁹ and/or an approved source.¹⁰
- 3.2.1 These reports utilize intellectual property and/or trade secrets to create public domain material properties for commercial end-use.
- 3.2.1.1 This report protects confidential Intellectual Property and trade secrets under the regulation, [18.U.S.Code.90](#), also known as [Defend Trade Secrets Act of 2016](#) (DTSA).¹¹
- 3.3 An approved agency is "approved" when it is [ANAB ISO/IEC 17065 accredited](#). DrJ Engineering, LLC (DrJ) is accredited and listed in the [ANAB directory](#).
- 3.4 An approved source is "approved" when a professional engineer (i.e., Registered Design Professional, hereinafter RDP) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.¹²



- 3.5 Testing and/or inspections conducted for this duly authenticated report were performed by an ISO/IEC 17025 accredited testing laboratory, an ISO/IEC 17020 accredited inspection body, and/or a licensed RDP.
- 3.5.1 The Center for Building Innovation (CBI) is ANAB¹³ ISO/IEC 17025 and ISO/IEC 17020 accredited.
- 3.6 The regulatory authority shall enforce¹⁴ the specific provisions of each legislatively adopted regulation. If there is a non-conformance, the specific regulatory section and language of the non-conformance shall be provided in writing¹⁵ stating the nonconformance and the path to its cure.
- 3.7 The regulatory authority shall accept duly authenticated reports from an approved agency and/or an approved source with respect to the quality and manner of use of new materials or assemblies as provided for in regulations regarding the use of alternative materials, designs, or methods of construction.¹⁶
- 3.8 ANAB is an International Accreditation Forum (IAF) Multilateral Recognition Arrangement (MLA) signatory. Therefore, recognition of certificates and validation statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA with the appropriate scope shall be approved.¹⁷ Thus, all ANAB ISO/IEC 17065 duly authenticated reports are approval equivalent,¹⁸ and can be used in any country that is an MLA signatory found at this link: <https://iaf.nu/en/recognised-abs/>
- 3.9 Approval equity is a fundamental commercial and legal principle.¹⁹

4 Applicable Local, State, and Federal Approvals; Standards; Regulations²⁰

4.1 Local, State, and Federal

- 4.1.1 Approved in all local jurisdictions pursuant to ISO/IEC 17065 duly authenticated report use, which includes, but is not limited to, the following featured local jurisdictions: Austin, Baltimore, Broward County, Chicago, Clark County, Dade County, Dallas, Detroit, Denver, DuPage County, Fort Worth, Houston, Kansas City, King County, Knoxville, Las Vegas, Los Angeles City, Los Angeles County, Miami, Nashville, New York City, Omaha, Philadelphia, Phoenix, Portland, San Antonio, San Diego, San Jose, San Francisco, Seattle, Sioux Falls, South Holland, Texas Department of Insurance, and Wichita.²¹
- 4.1.2 Approved in all state jurisdictions pursuant to ISO/IEC 17065 duly authenticated report use, which includes, but is not limited to, the following featured states: California, Florida, New Jersey, Oregon, New York, Texas, Washington, and Wisconsin.²²
- 4.1.3 Approved by the Code of Federal Regulations Manufactured Home Construction: Pursuant to Title 24, Subtitle B, Chapter XX, Part 3282.14²³ and Part 3280²⁴ pursuant to the use of ISO/IEC 17065 duly authenticated reports.
- 4.1.4 Approved means complying with the requirements of local, state, or federal legislation.

4.2 Standards

- 4.2.1 *AISI S100: North American Specification for the Design of Cold-formed Steel Structural Members*
- 4.2.2 *ANSI/AWC NDS: National Design Specification (NDS) for Wood Construction*
- 4.2.3 *ANSI/AWC SDPWS: Special Design Provisions for Wind and Seismic*
- 4.2.4 *ASTM C90: Standard Specification for Loadbearing Concrete Masonry Units*
- 4.2.5 *ASTM C1019: Standard Test Method for Sampling and Testing Grout for Masonry*
- 4.2.6 *ASTM C1289: Standard Specification for Faced Rigid Cellular Polyisocyanurate Thermal Insulation Board*
- 4.2.7 *ASTM E84: Standard Test Method for Surface Burning Characteristics of Building Materials*
- 4.2.8 *ASTM E330: Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference*
- 4.2.9 *ASTM E564: Standard Practice for Static Load Test for Shear Resistance of Framed Walls for Buildings*
- 4.2.10 *ASTM E2178: Standard Test Method for Air Permeance of Building Materials*



4.2.11 *DOC PS 2: Performance Standard for Wood-based Structural-use Panels*

4.2.12 *UL 263: Standard for Fire Test of Building Construction and Materials*

4.3 Structural performance for shear wall assemblies used as lateral force resisting systems in Seismic Design Categories A through F have been tested and evaluated in accordance with the following standards:

4.3.1 *ASCE/SEI 7: Minimum Design Loads and Associated Criteria for Buildings and Other Structures*

4.3.2 *ASTM D7989: Standard Practice for Demonstrating Equivalent In-Plane Lateral Seismic Performance to Wood-Frame Shear Walls Sheathed with Wood Structural Panels*

4.3.2.1 ASTM D7989 is accepted engineering practice used to establish Seismic Design Coefficients (SDC).

4.3.2.2 Tested data generated by ISO/IEC 17025 approved agencies and/or professional engineers, which use ASTM D7989 as their basis, are defined as intellectual property and/or trade secrets.

4.3.2.3 All professional engineering evaluations are defined as an independent design review (i.e., listings, certified reports, duly authenticated reports from approved agencies, and/or research reports, are prepared independently by approved agencies and/or approved sources, when signed and sealed by licensed professional engineer pursuant to registration law.

4.3.3 *ASTM E564: Standard Practice for Static Load Test for Shear Resistance of Framed Walls for Buildings*

4.3.4 *ASTM E2126: Standard Test Methods for Cyclic (Reversed) Load Test for Shear Resistance of Vertical Elements of the Lateral Force Resisting Systems for Buildings*

4.4 *Regulations*

4.4.1 *IBC – 18, 21, 24: International Building Code®*

4.4.2 *IRC – 18, 21, 24: International Residential Code®*

4.4.3 *IECC – 18, 21, 24: International Energy Conservation Code®*

5 Listed²⁵

5.1 Equipment, materials, products, or services included in a List published by a nationally recognized testing laboratory (i.e., CBI), an approved agency (i.e., CBI and DrJ), and/or an approved source (i.e., DrJ), or other organization(s) concerned with product evaluation (i.e., DrJ), that maintains periodic inspection (i.e., CBI) of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner.

6 Tabulated Properties Generated from Nationally Recognized Standards

6.1 *General*

6.1.1 ThermaBase-CI is a composite insulation panel for use in the following applications:

6.1.1.1 Continuous insulation on buildings constructed in accordance with the IBC and IRC for light-frame wood construction.

6.1.1.2 Continuous insulation providing a nail base for cladding materials used in light-frame wood construction.

6.1.1.3 Continuous insulation on buildings constructed in accordance with the IBC for light-frame, cold-formed steel construction or metal buildings.

6.1.1.4 Continuous insulation providing a nail base for cladding materials used in light-frame, cold-formed steel construction or metal buildings.



- 6.1.1.5 Continuous insulation on buildings constructed in accordance with the IBC for concrete masonry buildings or concrete buildings.
- 6.1.1.6 Continuous insulation providing a nail base for cladding materials used in concrete masonry buildings or concrete buildings.

6.1.2 Environmental Product Declarations (EPD) for ThermaBase-CI are available at www.polyiso.org/page/EPDs.

6.2 Thermal Insulation

6.2.1 ThermaBase-CI is intended to be used as exterior continuous insulation under any type of permitted cladding.

6.3 Air Barrier

6.3.1 ThermaBase-CI meets the requirements of [IRC Section N1102.4](#), [IECC Section C402.5](#), and [IECC Section R402.4](#) for use as a component of the air barrier, when installed in accordance with the manufacturer installation instructions and this report, with all seams including the top and bottom edges, sealed.

6.3.2 Air barrier properties for ThermaBase-CI are shown in **Table 1**.

Table 1. ThermaBase-CI Air Barrier Properties

Test Method	Property
ASTM E2178	$< 0.02 \text{ L/(s}\cdot\text{m}^2)^1$
1. Liter per second per square meter	

6.3.3 The air permeance of an air barrier material is defined in [IRC Section N1101.10.5](#), [IECC Section C402.6.2.3.1](#),²⁶ and [IECC Section R303.1.5](#) as being no greater than 0.02 liter per second per square meter [$\text{L/(s}\cdot\text{m}^2)$] at 75 Pa (0.004 cfm/ft² at 1.57 psf) pressure difference when tested in accordance with ASTM E2178.

6.4 Fire Safety

6.4.1 Surface Burning Characteristics:

6.4.1.1 Flame spread and smoke developed indexes for ThermaBase-CI were evaluated in accordance with ASTM E84, and are shown in **Table 2**.

6.4.1.2 The surface burning characteristics of the foam component of ThermaBase-CI complies with [IBC Section 2603.3](#) and [IBC Section 2603.5.4](#) where applicable, and [IRC Section R303.3](#).²⁷

Table 2. Surface Burn Characteristics

Product	Thickness (in)	Flame Spread	Smoke Developed	Classification
ThermaBase-CI Core ¹	< 1	< 40	< 250	Class B
	≥ 1	< 25	< 160	Class A
SI: 1 in = 25.4 mm				
1. Foam plastic portion of ThermaBase-CI tested in accordance with ASTM E84. Flame spread and smoke developed numbers are shown for comparison purposes only and are not intended to represent the performance of ThermaBase-CI and related components under actual fire conditions.				



6.4.2 Thermal Barrier:

- 6.4.2.1 Except as noted in **Section 6.4.2.2**, ThermaBase-CI panels, with the rigid insulation layer at a maximum thickness of up to 4¹/₂" (114 mm), may be installed within the building envelope (including, but not limited to, attics, crawlspaces, and wall assemblies) of all building types when separated from the interior with a thermal barrier. The thermal barrier shall consist of a minimum 1/2" Gypsum Wallboard (GWB), or an approved equivalent in accordance with IBC Section 2603.4 and IRC Section R303.4.²⁸
- 6.4.2.2 The thermal barrier required by **Section 6.4.2.1** is not required in the following applications:
 - 6.4.2.2.1 ThermaBase-CI is covered by a minimum 1" thickness of concrete or masonry separating the interior of the building from the sheathing in accordance with IBC Section 2603.4.1 or IRC Section R303.5.1.²⁹
 - 6.4.2.2.2 Walk-in coolers in accordance with IBC Section 2603.4.1.3.
- 6.4.2.3 Where an ignition barrier is permitted in lieu of a thermal barrier such as attic, crawlspace, or other uninhabitable space applications, ThermaBase-CI panels, with the rigid insulation layer at a maximum thickness of up to 2", may be installed on walls only, without a thermal barrier or ignition barrier, in accordance with IBC Section 2603.4.1.6, IRC Section R303.5.3,³⁰ and IRC Section R303.5.4.³¹
- 6.4.2.3.1 For panels with the rigid insulation layer at a thickness greater than 2", an ignition barrier is required.

6.4.3 Fire Resistance Ratings:

- 6.4.3.1 ThermaBase-CI has been tested and meets the requirements of UL 263 in accordance with IBC Section 2603.5.1, for use in the following assembly designs when installed in accordance with the manufacturer installation instructions and this report:
 - 6.4.3.1.1 45 minutes: U424, U425, V321, V499, W456
 - 6.4.3.1.2 1 hour: U026, U326, U330, U354, U355, U364, U424, U425, U460, V302, V303, V454, V499, W307, W417, W456
 - 6.4.3.1.3 1.5 hours: U424, U425, V499, W456
 - 6.4.3.1.4 2 hours: U349, U424, U425, U905, U906, V332, V499, W456
 - 6.4.3.1.5 3 hours: U904, U907
 - 6.4.3.1.6 4 hours: U902, U907



6.5 Wind Pressure Resistance

6.5.1 ThermaBase-CI is permitted to be used where the maximum nominal design wind speed is as shown in **Table 3**.

Table 3. Transverse Load Performance of ThermaBase-CI Structural Sheathing – Maximum Wind Speed¹

Minimum Nail		Maximum Wall Stud Spacing (in)	Maximum Panel Nail Spacing		Maximum Nominal Design Wind Speed, V _{ult} /V _{asd} (mph)		
Size	Penetration (in)		Edge (in. o.c.)	Field (in. o.c.)	Wind Exposure Category		
					B	C	D
8d common (0.131 diameter)	1 1/4"	24	4	12	220/170	220/170	220/170
			6	12	220/170	200/155	190/147
			8	12	200/155	180/139	170/132
			12	12	180/139	150/116	140/108
			16	16	160/124	130/101	120/93
			24	24	120/93	-	-
12d common (0.148 diameter)	1 1/4"	24	4	12	220/170	220/170	220/170
			6	12	220/170	200/155	200/155
			8	12	220/170	190/147	170/132
			12	12	190/147	160/124	150/116
			16	16	160/124	140/108	130/101
			24	24	130/101	110/85	-
Rmax® Nail Board Fastener: SIPTP, FastenMaster® HeadLOK®, TRUFAST® SIPTP	1 1/4"	24	24	24	220/170	220/170	220/170
Simpson Strong-Drive® SDWS™ 22	1 1/4"	24	16	16	220/170	220/170	220/170
			24	24	220/170	220/170	200/155

SI: 1 in = 25.4 mm, 1 mph = 1.61 km/h

1. Wind speeds are based on an enclosed building with a mean roof height of 30', Zone 4 and a 10 ft area.



6.6 Resistance to Lateral Loads

6.6.1 ThermaBase-CI has been tested in accordance with ASTM E564 for lateral resistance and has the shear capacity as shown in **Table 4** and **Table 5**.

Table 4. Allowable Stress Design (ASD) Capacity – Wind^{1,4} (Foam Against Studs)

Product	Fastener Type and Size ^{5,6} (Spaced 4":12")	Maximum Stud Spacing (in)	Maximum Distance from Face of Framing to Underside of Fastener Head (in)	Allowable Unit Shear Capacity (plf) ²
ThermaBase-CI 1/2" Polyiso + 7/16" OSB	8d (0.131" x 2 1/2")	24 o.c.	0.938	470
		16 o.c.		495
ThermaBase-CI 1" Polyiso + 7/16" OSB	8d (0.131" x 3 1/4")	24 o.c.	1.438	385
		16 o.c.		425
ThermaBase-CI 1 1/2" Polyiso + 7/16" OSB	0.131" x 3 1/4" Smooth Shank Nail	24 o.c.	1.938	330
		16 o.c.		375
ThermaBase-CI 2" Polyiso + 7/16" OSB	0.131" x 3 1/4" Smooth Shank Nail ³	24 o.c.	2.438	310
		16 o.c.		360
ThermaBase-CI 2" Polyiso + 7/16" OSB	Rmax Nail Board Fastener: SIPTP, FastenMaster HeadLOK, TRUFAST SIPTP, Simpson Strong-Drive SDWS22	24 o.c.	2.438	310
		16 o.c.		360

SI: 1 in = 25.4 mm, 1 lb/ft = 0.0146 kN/m

1. ThermaBase-CI attached with a minimum 0.131" diameter smooth shank nail, lengths as listed above. Fasteners are to be spaced a maximum of 4" o.c. at the edges and 12" o.c. in the field with a minimum edge distance of 3/8". Minimum fastener penetration of 1 1/4" required, excepted as noted below.
2. No additional capacity may be added for GWB installed on the interior side of the wall.
3. Fastener penetration of only 13/16" (0.813").
4. For thicker continuous insulation applications, design is required in accordance with accepted engineering practice.
5. Fasteners of equal or greater diameter, length, and head size, in addition to material properties, may be substituted for the fasteners above including all fasteners shown in **Table 6** and **Table 7**.
6. Fastener head shall be flush with the OSB. The total distance from the face of the stud to the underside of the fastener head shall not be more than that listed above.

**Table 5.** Allowable Stress Design (ASD) Capacity – Wind^{1,3,4}

Product	Fastener Type and Size (Spaced 4":12")	Maximum Stud Spacing (in)	Maximum Distance from Face of Framing to Underside of Fastener Head (in)	Allowable Unit Shear Capacity (plf) ^{2,6}
ThermaBase-CI 1 ³ / ₁₆ " Polyiso + 7 ⁷ / ₁₆ " OSB (OSB installed against the studs) ⁵	0.113" x 2 ³ / ₈ " Smooth Shank Nail	24 o.c.	0.438	490
		16 o.c.		535

SI: 1 in = 25.4 mm, 1 lb/ft = 0.0146 kN/m

- ThermaBase-CI attached with a minimum 0.131" diameter smooth shank nail, lengths as listed above. Fasteners are to be spaced a maximum of 4" o.c. at the edges and 12" o.c. in the field with a minimum edge distance of 3³/₈". Minimum fastener penetration of 1¹/₄" required, excepted as noted below.
- Where GWB is installed on the interior side of the wall, capacity of the gypsum may be added to the allowable unit shear capacity in accordance with SDPWS, Table 4.3C.
- For thicker continuous insulation applications, design is required in accordance with accepted engineering practice.
- Fastener head shall be flush with the OSB. The total distance from the face of the stud to the underside of the fastener head shall not be more than that listed above.
- Requires installation using Senco® SCN63LDXP structural foam insulation nailer. 1³/₁₆" is maximum ThermaBase-CI foam thickness.
- For framing species other than Douglas-Fir-Larch or Southern Pine, reduced capacities shall be determined by multiplying the unit shear capacity by a framing lumber specific gravity adjustment factor = [1-(0.5-G)] where G = the specific gravity of the framing lumber per NDS Table 11.3.2A. The adjustment factor shall not be greater than 1.

6.7 Fastener Attachments to Wood and Steel Framing for ThermaBase-CI to Support Cladding Weight

- 6.7.1 To develop the loads listed in **Table 4** and **Table 5**, the fasteners attaching the ThermaBase-CI sheathing to the wall framing shall have a minimum size and maximum spacing as shown in **Table 4** and **Table 5**, and all panel edges shall be supported by framing or blocking.
- 6.7.2 Fasteners are required to attach the ThermaBase-CI sheathing to the wall framing to carry the cladding weight.
- 6.7.2.1 See **Table 6** through **Table 11** for allowable cladding loads for various fastener types and sheathing thicknesses for wood stud framing.
- 6.7.2.2 See **Table 12** through **Table 17** for allowable cladding loads for various fastener types and sheathing thicknesses for light-frame cold-formed steel construction.
- 6.7.3 Minimum penetration into wood wall framing is 1¹/₄" unless specifically noted in this report.
- 6.7.4 Minimum allowable penetration into steel wall framing is the steel thickness plus three threads plus the tip.
- 6.7.5 For attaching to wood studs, fasteners with equal or greater design properties shall be permitted:
- 6.7.5.1 Rmax Nail Board Fastener SIPTP: 0.189" shank diameter, 0.635" head diameter
- 6.7.5.2 8d nail (0.131" x 2¹/₂") : 0.281" head diameter
- 6.7.5.3 12d nail (0.148" x 3¹/₄") : 0.312" head diameter
- 6.7.5.4 Simpson Strong-Drive SDWS22: 0.22" shank diameter, 0.435" head diameter
- 6.7.5.5 FastenMaster HeadLOK: 0.191" shank diameter, 0.625" head diameter
- 6.7.5.6 TRUFAST SIPTP: 0.189" shank diameter, 0.635" head diameter
- 6.7.6 For attaching to cold-form steel studs, fasteners with equal or greater design properties shall be permitted:
- 6.7.6.1 Rmax Nail Board Fastener: SIPLD: 0.189" shank diameter, 0.635" head diameter
- 6.7.6.2 Rmax Nail Board Fastener: SIPHD: 0.189" shank diameter, 0.635" head diameter
- 6.7.6.3 #8 screw: 0.164" shank diameter, 0.313" head diameter
- 6.7.6.4 #10 screw: 0.190" shank diameter, 0.340" head diameter



- 6.7.6.5 #12 screw: 0.216" shank diameter, 0.340" head diameter
- 6.7.6.6 TRUFAST SIPLD: 0.189" shank diameter, 0.635" head diameter
- 6.7.6.7 TRUFAST SIPHD: 0.189" shank diameter, 0.635" head diameter
- 6.7.6.8 FastenMaster HeadLOK: 0.191" shank diameter, 0.625" head diameter
- 6.7.6.9 SFS intec Dekfast™: 0.191" shank diameter, 0.625" head diameter

Table 6. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" and 1/2" OSB
With Vertical Wood Studs Spaced 16" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
Rmax Nail Board Fastener: SIPTP	1/2	24	24	24	24	16	16
	3/4	24	24	24	16	12	12
	1	24	24	20	12	12	8
	1 1/2	24	16	12	8	8	8
	2	20	12	8	8	6	6
	2 1/2	16	8	8	6	4	4
	3	12	8	6	4	4	4
	3 1/2	8	6	4	4	4	-
	4	8	6	4	4	-	-
	4 1/2	6	4	4	-	-	-
8d (0.131" x 2 1/2")	1/2	24	16	12	8	8	6
	3/4	24	12	8	8	6	4
12d (0.148" x 3 1/4")	1/2	24	20	16	12	8	8
	3/4	24	16	12	8	8	6
	1	20	12	8	8	6	4
	1 1/2	12	8	6	4	4	4
TRUFAST SIPTP	1/2	24	24	24	24	16	16
	3/4	24	24	24	16	12	12
	1	24	24	20	12	12	8
	1 1/2	24	16	12	8	8	8



Table 6. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" and 1/2" OSB
With Vertical Wood Studs Spaced 16" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
TRUFAST SIPTP Continued	2	20	12	8	8	6	6
	2 1/2	16	8	8	6	4	4
	3	12	8	6	4	4	4
	3 1/2	8	6	4	4	4	-
	4	8	6	4	4	-	-
	4 1/2	6	4	4	-	-	-
FastenMaster HeadLOK	1/2	24	24	24	24	20	16
	3/4	24	24	24	20	16	12
	1	24	24	20	16	12	12
	1 1/2	24	20	16	12	8	8
	2	24	16	12	8	8	6
	2 1/2	20	12	8	8	6	4
	3	12	8	8	6	4	4
	3 1/2	12	8	6	4	4	4
	4	8	6	6	4	4	-
	4 1/2	8	6	4	4	-	-
Simpson Strong-Drive SDWS22	1/2	24	24	24	24	24	20
	3/4	24	24	24	24	20	16
	1	24	24	24	20	16	16
	1 1/2	24	24	20	16	12	8
	2	24	20	16	12	8	8
	2 1/2	24	16	12	8	8	6
	3	20	12	8	8	6	6
	3 1/2	16	12	8	6	6	4
	4	12	8	8	6	4	4
	4 1/2	12	8	6	4	4	4



Table 6. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{7}{16}$ " and $\frac{1}{2}$ " OSB
With Vertical Wood Studs Spaced 16" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m ²							
1. Minimum fastener penetration into stud is 1¼".							
2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing.							
3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure.							
4. Wood studs shall be a minimum of 2 x 4 and have a minimum specific gravity of 0.42.							
5. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap.							
6. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.							

Table 7. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{7}{16}$ " and $\frac{1}{2}$ " OSB
With Vertical Wood Studs Spaced 24" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
Rmax Nail Board Fastener: SIPTP	$\frac{1}{2}$	24	24	20	16	12	8
	$\frac{3}{4}$	24	20	16	12	8	8
	1	24	16	12	8	8	6
	$1\frac{1}{2}$	20	12	8	6	6	4
	2	12	8	6	4	4	4
	$2\frac{1}{2}$	8	6	4	4	-	-
	3	8	6	4	-	-	-
	$3\frac{1}{2}$	6	4	-	-	-	-
	4	6	4	-	-	-	-
	$4\frac{1}{2}$	4	-	-	-	-	-
8d (0.131" x 2.5")	$\frac{1}{2}$	20	12	8	6	4	4
	$\frac{3}{4}$	16	8	6	4	4	-
12d (0.148" x 3.25")	$\frac{1}{2}$	24	12	8	8	6	4
	$\frac{3}{4}$	20	12	8	6	4	4
	1	12	8	6	4	4	-
	$1\frac{1}{2}$	8	6	4	-	-	-



Table 7. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" and 1/2" OSB
With Vertical Wood Studs Spaced 24" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
TRUFAST SIPTP	1/2	24	24	20	16	12	8
	3/4	24	20	16	12	8	8
	1	24	16	12	8	8	6
	1 1/2	20	12	8	6	6	4
	2	12	8	6	4	4	4
	2 1/2	8	6	4	4	-	-
	3	8	6	4	-	-	-
	3 1/2	6	4	-	-	-	-
	4	6	4	-	-	-	-
	4 1/2	4	-	-	-	-	-
FastenMaster HeadLOK	1/2	24	24	20	16	12	12
	3/4	24	24	16	12	12	8
	1	24	20	12	12	8	8
	1 1/2	24	12	8	8	6	6
	2	16	8	8	6	4	4
	2 1/2	12	8	6	4	4	-
	3	8	6	4	4	-	-
	3 1/2	8	6	4	-	-	-
	4	6	4	4	-	-	-
	4 1/2	4	4	-	-	-	-
Simpson Strong-Drive SDWS22	1/2	24	24	24	20	16	12
	3/4	24	24	24	16	12	12
	1	24	24	16	12	12	8
	1 1/2	24	16	12	8	8	6
	2	20	12	8	8	6	6
	2 1/2	16	8	8	6	4	4
	3	12	8	6	4	4	4
	3 1/2	8	8	6	4	4	-
	4	8	6	4	4	-	-
	4 1/2	8	6	4	-	-	-



Table 7. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{7}{16}$ " and $\frac{1}{2}$ " OSB
With Vertical Wood Studs Spaced 24" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m ² 1. Minimum fastener penetration into stud is 1¼". 2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing. 3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure. 4. Wood studs shall be a minimum of 2 x 4 and have a minimum specific gravity of 0.42. 5. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap. 6. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.							

Table 8. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{1}{2}$ " or $\frac{5}{8}$ " Plywood
With Vertical Wood Studs Spaced 16" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Max. Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
Rmax Nail Board Fastener: SIPTP	$\frac{1}{2}$	24	24	24	20	16	12
	$\frac{3}{4}$	24	24	20	16	12	12
	1	24	24	16	12	12	8
	$1\frac{1}{2}$	24	16	12	8	8	6
	2	20	12	8	8	6	4
	$2\frac{1}{2}$	12	8	8	6	4	4
	3	12	8	6	4	4	-
	$3\frac{1}{2}$	8	6	4	4	-	-
	4	8	6	4	-	-	-
	$4\frac{1}{2}$	6	4	4	-	-	-
8d (0.131" x 2.5")	$\frac{1}{2}$	24	16	12	8	6	6
	$\frac{3}{4}$	20	12	8	6	6	4
12d (0.148" x 3.25")	$\frac{1}{2}$	24	20	12	8	8	8
	$\frac{3}{4}$	24	16	8	8	6	6
	1	20	12	8	6	6	4
	$1\frac{1}{2}$	12	8	6	4	4	-



Table 8. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Wood Studs Spaced 16" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Max. Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
TRUFAST SIPTP	1/2	24	24	24	20	16	12
	3/4	24	24	20	16	12	12
	1	24	24	16	12	12	8
	1 1/2	24	16	12	8	8	6
	2	20	12	8	8	6	4
	2 1/2	12	8	8	6	4	4
	3	12	8	6	4	4	-
	3 1/2	8	6	4	4	-	-
	4	8	6	4	-	-	-
	4 1/2	6	4	4	-	-	-
FastenMaster HeadLOK	1/2	24	24	24	24	20	16
	3/4	24	24	24	20	16	12
	1	24	24	20	16	12	12
	1 1/2	24	20	16	12	8	8
	2	24	16	12	8	8	6
	2 1/2	16	12	8	6	6	4
	3	12	8	6	6	4	4
	3 1/2	12	8	6	4	4	4
	4	8	6	4	4	4	-
	4 1/2	8	6	4	4	-	-
Simpson Strong-Drive SDWS22	1/2	24	24	24	24	24	20
	3/4	24	24	24	24	20	16
	1	24	24	24	20	16	12
	1 1/2	24	24	20	16	12	8
	2	24	20	12	12	8	8
	2 1/2	20	16	12	8	8	6
	3	16	12	8	8	6	6
	3 1/2	16	8	8	6	6	4
	4	12	8	6	6	4	4
	4 1/2	8	8	6	4	4	4



Table 8. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Wood Studs Spaced 16" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Max. Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
<p>SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m²</p> <p>1. Minimum fastener penetration into stud is 1 1/4".</p> <p>2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing.</p> <p>3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure.</p> <p>4. Wood studs shall be a minimum of 2 x 4 and have a minimum specific gravity of 0.42.</p> <p>5. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap.</p> <p>6. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.</p>							

Table 9. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Wood Studs Spaced 24" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
Rmax Nail Board Fastener: SIPTP	1/2	24	24	16	12	12	8
	3/4	24	20	12	8	8	8
	1	24	16	12	8	8	6
	1 1/2	16	12	8	6	4	4
	2	12	8	6	4	4	-
	2 1/2	8	6	4	4	-	-
	3	8	4	4	-	-	-
	3 1/2	6	4	-	-	-	-
	4	4	4	-	-	-	-
	4 1/2	4	-	-	-	-	-
8d (0.131" x 2.5")	1/2	16	8	8	6	4	4
	3/4	12	8	6	4	4	-
12d (0.148" x 3.25")	1/2	20	12	8	6	6	4
	3/4	16	8	6	6	4	4
	1	12	8	6	4	4	-
	1 1/2	8	4	4	-	-	-



Table 9. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Wood Studs Spaced 24" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
TRUFAST SIPTP	1/2	24	24	16	12	12	8
	3/4	24	20	12	8	8	8
	1	24	16	12	8	8	6
	1 1/2	16	12	8	6	4	4
	2	12	8	6	4	4	-
	2 1/2	8	6	4	4	-	-
	3	8	4	4	-	-	-
	3 1/2	6	4	-	-	-	-
	4	4	4	-	-	-	-
	4 1/2	4	-	-	-	-	-
FastenMaster HeadLOK	1/2	24	24	20	16	12	8
	3/4	24	24	16	12	8	8
	1	24	20	12	8	8	8
	1 1/2	20	12	8	8	6	4
	2	16	8	8	6	4	4
	2 1/2	12	8	6	4	4	-
	3	8	6	4	4	-	-
	3 1/2	8	4	4	-	-	-
	4	6	4	-	-	-	-
	4 1/2	4	4	-	-	-	-
Simpson Strong-Drive SDWS22	1/2	24	24	24	20	16	12
	3/4	24	24	20	16	12	12
	1	24	24	16	12	12	8
	1 1/2	24	16	12	8	8	6
	2	20	12	8	8	6	4
	2 1/2	12	8	8	6	4	4
	3	12	8	6	4	4	4
	3 1/2	8	6	6	4	4	-
	4	8	6	4	4	-	-
	4 1/2	6	4	4	-	-	-



Table 9. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood With Vertical Wood Studs Spaced 24" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m ² 1. Minimum fastener penetration into stud is 1¼". 2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing. 3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure. 4. Wood studs shall be a minimum of 2 x 4 and have a minimum specific gravity of 0.42. 5. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap. 6. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.							

Table 10. Maximum Fastener Spacing for ThermaBase-CI Utilizing 5/8" OSB, 3/4" OSB, or 3/4" Plywood With Vertical Wood Studs Spaced 16" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
Rmax Nail Board Fastener: SIPTP	1/2	24	24	24	20	16	16
	3/4	24	24	24	16	12	12
	1	24	24	20	16	12	8
	1 1/2	24	20	12	12	8	8
	2	20	12	8	8	6	6
	2 1/2	16	12	8	6	6	4
	3	12	8	6	6	4	4
	3 1/2	8	8	6	4	4	-
	4	8	6	4	4	-	-
	4 1/2	8	6	4	4	-	-
8d (0.131" x 2.5")	1/2	24	20	12	8	8	8
	3/4	24	16	12	8	6	6
12d (0.148" x 3.25")	1/2	24	24	16	12	8	8
	3/4	24	16	12	8	8	8
	1	24	16	12	8	6	6
	1 1/2	16	8	8	6	4	4



Table 10. Maximum Fastener Spacing for ThermaBase-CI Utilizing 5/8" OSB, 3/4" OSB, or 3/4" Plywood With Vertical Wood Studs Spaced 16" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
TRUFAST SIPTP	1/2	24	24	24	20	16	16
	3/4	24	24	24	16	12	12
	1	24	24	20	16	12	8
	1 1/2	24	20	12	12	8	8
	2	20	12	8	8	6	6
	2 1/2	16	12	8	6	6	4
	3	12	8	6	6	4	4
	3 1/2	8	8	6	4	4	-
	4	8	6	4	4	-	-
	4 1/2	8	6	4	4	-	-
FastenMaster HeadLOK	1/2	24	24	24	24	20	16
	3/4	24	24	24	20	16	12
	1	24	24	20	16	12	12
	1 1/2	24	20	16	12	8	8
	2	24	16	12	8	8	6
	2 1/2	20	12	8	8	6	6
	3	16	8	8	6	6	4
	3 1/2	12	8	6	6	4	4
	4	8	8	6	4	4	-
	4 1/2	8	6	4	4	4	-
Simpson Strong-Drive SDWS22	1/2	24	24	24	24	24	20
	3/4	24	24	24	24	20	16
	1	24	24	24	20	16	16
	1 1/2	24	24	20	16	12	12
	2	24	20	16	12	8	8
	2 1/2	24	16	12	8	8	8
	3	20	12	8	8	6	6
	3 1/2	16	12	8	8	6	6
	4	12	8	8	6	6	4
	4 1/2	12	8	6	6	4	4



Table 10. Maximum Fastener Spacing for ThermaBase-CI Utilizing 5/8" OSB, 3/4" OSB, or 3/4" Plywood With Vertical Wood Studs Spaced 16" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m ² 1. Minimum fastener penetration into stud is 1¼". 2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing. 3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure. 4. Wood studs shall be a minimum of 2 x 4 and have a minimum specific gravity of 0.42. 5. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap. 6. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.							

Table 11. Maximum Fastener Spacing for ThermaBase-CI Utilizing 5/8" OSB, 3/4" OSB, or 3/4" Plywood With Vertical Wood Studs Spaced 24" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Max. Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
Rmax Nail Board Fastener: SIPTP	1/2	24	24	16	12	12	8
	3/4	24	20	16	12	8	8
	1	24	16	12	8	8	6
	1 1/2	20	12	8	8	6	4
	2	12	8	6	6	4	4
	2 1/2	8	8	6	4	4	-
	3	8	6	4	4	-	-
	3 1/2	6	4	4	-	-	-
	4	6	4	-	-	-	-
	4 1/2	4	4	-	-	-	-
8d (0.131" x 2.5")	1/2	20	12	8	6	6	4
	3/4	16	8	8	6	4	4
12d (0.148" x 3.25")	1/2	24	16	12	8	6	6
	3/4	20	12	8	6	6	4
	1	16	8	8	6	4	4
	1 1/2	8	6	4	4	-	-



Table 11. Maximum Fastener Spacing for ThermaBase-CI Utilizing 5/8" OSB, 3/4" OSB, or 3/4" Plywood With Vertical Wood Studs Spaced 24" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Max. Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
TRUFAST SIPTP	1/2	24	24	16	12	12	8
	3/4	24	20	16	12	8	8
	1	24	16	12	8	8	6
	1 1/2	20	12	8	8	6	4
	2	12	8	6	6	4	4
	2 1/2	8	8	6	4	4	-
	3	8	6	4	4	-	-
	3 1/2	6	4	4	-	-	-
	4	6	4	-	-	-	-
	4 1/2	4	4	-	-	-	-
FastenMaster HeadLOK	1/2	24	24	20	16	12	12
	3/4	24	24	16	12	12	8
	1	24	20	12	12	8	8
	1 1/2	20	12	8	8	6	6
	2	16	8	8	6	6	4
	2 1/2	12	8	6	4	4	4
	3	8	6	6	4	4	-
	3 1/2	8	6	4	4	-	-
	4	6	4	4	-	-	-
	4 1/2	6	4	-	-	-	-
Simpson Strong-Drive SDWS22	1/2	24	24	24	20	16	12
	3/4	24	24	20	16	12	12
	1	24	24	16	12	12	8
	1 1/2	24	16	12	8	8	8
	2	20	12	8	8	6	6
	2 1/2	16	8	8	6	6	4
	3	12	8	6	6	4	4
	3 1/2	8	8	6	4	4	4
	4	8	6	4	4	4	-
	4 1/2	8	6	4	4	-	-



Table 11. Maximum Fastener Spacing for ThermaBase-CI Utilizing 5/8" OSB, 3/4" OSB, or 3/4" Plywood With Vertical Wood Studs Spaced 24" o.c.^{1,3,4,5,6}

Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Max. Fastener Spacing (in)					
		Specified Cladding Weight ² (psf)					
		5	10	15	20	25	30
SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m ² 1. Minimum fastener penetration into stud is 1¼". 2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing. 3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure. 4. Wood studs shall be a minimum of 2 x 4 and have a minimum specific gravity of 0.42. 5. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap. 6. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.							

Table 12. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil)	Rmax Nailboard Fastener: SIPLD	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	#8 Screw	1/2	8	4	4	-	-	-
		3/4	8	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	4	-	-	-	-	-
		2	4	-	-	-	-	-
	#10 Screw	1/2	8	6	4	-	-	-
		3/4	8	4	4	-	-	-
		1	8	4	-	-	-	-
		1 1/2	6	4	-	-	-	-
		2	4	-	-	-	-	-



Table 12. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil) Continued	TRUFast SIPLD	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	FastenMaster HeadLOK	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	SFS intec Dekfast	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
18-gauge Structural (43 mil)	Rmax Nailboard Fastener: SIPLD	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-



Table 12. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge Structural (43 mil) Continued	#8 Screw	1/2	8	4	4	-	-	-
		3/4	8	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	4	-	-	-	-	-
		2	4	-	-	-	-	-
	#10 Screw	1/2	8	6	4	-	-	-
		3/4	8	4	4	-	-	-
		1	8	4	-	-	-	-
		1 1/2	6	4	-	-	-	-
		2	4	-	-	-	-	-
	#12 Screw	1/2	8	6	4	-	-	-
		3/4	8	4	4	-	-	-
		1	8	4	-	-	-	-
		1 1/2	6	4	-	-	-	-
		2	4	-	-	-	-	-
		2 1/2	4	-	-	-	-	-
	TRUFAST SIPLD	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	FastenMaster HeadLOK	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-



Table 12. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge Structural (43 mil) Continued	SFS indec Dekfast	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
16-gauge Structural (53 mil)	Rmax Nailboard Fastener: SIPHD	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	#8 Screw	1/2	8	4	4	-	-	-
		3/4	8	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	4	-	-	-	-	-
		2	4	-	-	-	-	-
	#10 Screw	1/2	8	6	4	-	-	-
		3/4	8	4	4	-	-	-
		1	8	4	-	-	-	-
		1 1/2	6	4	-	-	-	-
		2	4	-	-	-	-	-
	#12 Screw	1/2	8	6	4	-	-	-
		3/4	8	4	4	-	-	-
		1	8	4	-	-	-	-
		1 1/2	6	4	-	-	-	-
		2	4	-	-	-	-	-
		2 1/2	4	-	-	-	-	-



Table 12. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (53 mil) Continued	TRUFast SIPHD	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	FastenMaster HeadLOK	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	SFS intec Dekfast	1/2	16	8	8	6	4	4
		3/4	16	8	6	4	4	4
		1	12	8	6	4	4	-
		1 1/2	12	6	4	4	-	-
		2	8	6	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-

SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m²

1. Minimum fastener penetration into stud is the steel thickness plus three threads and the tip of the fastener.
2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing.
3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure.
4. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap.
5. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing



Table 13. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge structural (33 mil)	Rmax Nailboard Fastener: SIPLD	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
	#8 Screw	1/2	6	-	-	-	-	-
		3/4	4	-	-	-	-	-
		1	4	-	-	-	-	-
	#10 Screw	1/2	6	4	-	-	-	-
		3/4	6	-	-	-	-	-
		1	4	-	-	-	-	-
		1 1/2	4	-	-	-	-	-
	#12 Screw	1/2	6	4	-	-	-	-
		3/4	6	-	-	-	-	-
		1	4	-	-	-	-	-
		1 1/2	4	-	-	-	-	-
	TRUFast SIPLD	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
	FastenMaster HeadLOK	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-



Table 13. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil) (Continued)	SFS intec Dekfast	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
18-gauge Structural (43 mil)	Rmax Nailboard Fastener: SIPLD	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
	#8 Screw	1/2	6	-	-	-	-	-
		3/4	4	-	-	-	-	-
		1	4	-	-	-	-	-
	#10 Screw	1/2	6	4	-	-	-	-
		3/4	6	-	-	-	-	-
		1	4	-	-	-	-	-
		1 1/2	4	-	-	-	-	-
	#12 Screw	1/2	6	4	-	-	-	-
		3/4	6	-	-	-	-	-
		1	4	-	-	-	-	-
		1 1/2	4	-	-	-	-	-
	TRUFAST SIPLD	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-



Table 13. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge Structural (43 mil) (Continued)	FastenMaster HeadLOK	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
	SFS intec Dekfast	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
16-gauge Structural (53 mil)	Rmax Nailboard Fastener: SIPHD	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
	#8 Screw	1/2	6	-	-	-	-	-
		3/4	4	-	-	-	-	-
		1	4	-	-	-	-	-
	#10 Screw	1/2	6	4	-	-	-	-
		3/4	6	-	-	-	-	-
		1	4	-	-	-	-	-
		1 1/2	4	-	-	-	-	-
	#12 Screw	1/2	6	4	-	-	-	-
		3/4	6	-	-	-	-	-
		1	4	-	-	-	-	-
		1 1/2	4	-	-	-	-	-



Table 13. Maximum Fastener Spacing for ThermaBase-CI Utilizing 1/2" or 5/8" Plywood
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (53 mil) (Continued)	TRUFAST SIPHD	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
	FastenMaster HeadLOK	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
	SFS intec Dekfast	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	8	4	-	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-

SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m²

1. Minimum fastener penetration into stud is the steel thickness plus three threads and the tip of the fastener.
2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing.
3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure.
4. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap.
5. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.



Table 14. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{7}{16}$ " OSB, $\frac{1}{2}$ " OSB, or $\frac{3}{4}$ " Plywood With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge structural (33 mil)	Rmax Nailboard Fastener: SIPLD	$\frac{1}{2}$	24	12	8	8	6	4
		$\frac{3}{4}$	20	12	8	8	6	4
		1	20	12	8	6	6	4
		$1\frac{1}{2}$	16	8	6	6	4	4
		2	12	8	6	4	4	-
		$2\frac{1}{2}$	8	6	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
	#8 Screw	$\frac{1}{2}$	12	6	4	4	-	-
		$\frac{3}{4}$	8	6	4	-	-	-
		1	8	6	4	-	-	-
		$1\frac{1}{2}$	6	4	-	-	-	-
		2	4	-	-	-	-	-
	#10 Screw	$\frac{1}{2}$	12	8	6	4	-	-
		$\frac{3}{4}$	12	6	4	4	-	-
		1	8	6	4	4	-	-
		$1\frac{1}{2}$	8	4	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
	#12 Screw	$\frac{1}{2}$	12	8	6	4	-	-
		$\frac{3}{4}$	12	8	4	4	-	-
		1	8	6	4	4	-	-
		$1\frac{1}{2}$	8	6	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	6	4	-	-	-	-
		3	4	-	-	-	-	-



Table 14. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" OSB, 1/2" OSB, or 3/4" Plywood With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil) (Continued)	TRUFAST SIPLD	1/2	24	12	8	8	6	4
		3/4	20	12	8	8	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	-	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-
	FastenMaster HeadLOK	1/2	24	12	8	8	6	4
		3/4	20	12	8	8	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	4	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-
	SFS intec Dekfast	1/2	24	12	8	8	6	4
		3/4	20	12	8	6	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	-	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-



Table 14. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" OSB, 1/2" OSB, or 3/4" Plywood With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge structural (43 mil)	Rmax Nailboard Fastener: SIPLD	1/2	24	12	8	8	6	4
		3/4	20	12	8	8	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	-	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-
	#8 Screw	1/2	12	6	4	4	-	-
		3/4	8	6	4	-	-	-
		1	8	6	4	-	-	-
		1 1/2	6	4	-	-	-	-
		2	4	-	-	-	-	-
	#10 Screw	1/2	12	8	6	4	-	-
		3/4	12	6	4	4	-	-
		1	8	6	4	4	-	-
		1 1/2	8	4	4	-	-	-
		2	6	4	-	-	-	-
		2 1/2	4	-	-	-	-	-
	#12 Screw	1/2	12	8	6	4	-	-
		3/4	12	8	4	4	-	-
		1	8	6	4	4	-	-
		1 1/2	8	6	4	-	-	-
		2	6	4	-	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-



Table 14. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" OSB, 1/2" OSB, or 3/4" Plywood With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge Structural (43 mil) (Continued)	TRUFAST SIPLD	1/2	24	12	8	8	6	4
		3/4	20	12	8	8	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	-	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-
	FastenMaster HeadLOK	1/2	24	12	8	8	6	4
		3/4	20	12	8	8	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	4	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-
	SFS intec Dekfast	1/2	24	12	8	8	6	4
		3/4	20	12	8	6	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	-	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-



Table 14. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{7}{16}$ " OSB, $\frac{1}{2}$ " OSB, or $\frac{3}{4}$ " Plywood With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (43 mil)	Rmax Nailboard Fastener: SIPHD	$\frac{1}{2}$	24	12	8	8	6	4
		$\frac{3}{4}$	20	12	8	8	6	4
		1	20	12	8	6	6	4
		$1\frac{1}{2}$	16	8	6	6	4	4
		2	12	8	6	4	4	-
		$2\frac{1}{2}$	8	6	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
	#8 Screw	$\frac{1}{2}$	12	6	4	4	-	-
		$\frac{3}{4}$	8	6	4	-	-	-
		1	8	6	4	-	-	-
		$1\frac{1}{2}$	6	4	-	-	-	-
		2	4	-	-	-	-	-
	#10 Screw	$\frac{1}{2}$	12	8	6	4	-	-
		$\frac{3}{4}$	12	6	4	4	-	-
		1	8	6	4	4	-	-
		$1\frac{1}{2}$	8	4	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
	#12 Screw	$\frac{1}{2}$	12	8	6	4	-	-
		$\frac{3}{4}$	12	8	4	4	-	-
		1	8	6	4	4	-	-
		$1\frac{1}{2}$	8	6	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	6	4	-	-	-	-
		3	4	-	-	-	-	-



Table 14. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" OSB, 1/2" OSB, or 3/4" Plywood With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (43 mil) (Continued)	TRUFAST SIPHD	1/2	24	12	8	8	6	4
		3/4	20	12	8	8	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	-	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-
	FastenMaster HeadLOK	1/2	24	12	8	8	6	4
		3/4	20	12	8	8	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	4	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-
	SFS intec Dekfast	1/2	24	12	8	8	6	4
		3/4	20	12	8	6	6	4
		1	20	12	8	6	6	4
		1 1/2	16	8	6	6	4	4
		2	12	8	6	4	4	-
		2 1/2	8	6	4	-	-	-
		3	6	4	-	-	-	-
		3 1/2	4	-	-	-	-	-

SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m²

1. Minimum fastener penetration into stud is the steel thickness plus three threads and the tip of the fastener.
2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing.
3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure.
4. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap.
5. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.



Table 15. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" OSB, 1/2" OSB, or 3/4" Plywood With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastner Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil)	Rmax Nailboard Fastener: SIPLD	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	#8 Screw	1/2	8	4	-	-	-	-
		3/4	6	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	4	-	-	-	-	-
	#10 Screw	1/2	8	4	4	-	-	-
		3/4	8	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	6	-	-	-	-	-
		2	4	-	-	-	-	-
	#12 Screw	1/2	8	4	4	-	-	-
		3/4	8	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	6	4	-	-	-	-
		2	4	-	-	-	-	-
		2 1/2	4	-	-	-	-	-
	TRUFast SIPLD	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-



Table 15. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" OSB, 1/2" OSB, or 3/4" Plywood With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastner Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil) Continued	FastenMaster HeadLOK	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	SFS intec Dekfast	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
18-gauge Structural (43 mil)	Rmax Nailboard Fastener: SIPLD	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	#8 Screw	1/2	8	4	-	-	-	-
		3/4	6	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	4	-	-	-	-	-
	#10 Screw	1/2	8	4	4	-	-	-
		3/4	8	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	6	-	-	-	-	-
		2	4	-	-	-	-	-



Table 15. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" OSB, 1/2" OSB, or 3/4" Plywood With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastner Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge Structural (43 mil) Continued	#12 Screw	1/2	8	4	4	-	-	-
		3/4	8	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	6	4	-	-	-	-
		2	4	-	-	-	-	-
		2 1/2	4	-	-	-	-	-
	TRUFast SIPLD	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	FastenMaster HeadLOK	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	SFS intec Dekfast	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-



Table 15. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" OSB, 1/2" OSB, or 3/4" Plywood With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastner Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (53 Mil)	Rmax Nailboard Fastener: SIPHD	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	#8 Screw	1/2	8	4	-	-	-	-
		3/4	6	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	4	-	-	-	-	-
	#10 Screw	1/2	8	4	4	-	-	-
		3/4	8	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	6	-	-	-	-	-
		2	4	-	-	-	-	-
	#12 Screw	1/2	8	4	4	-	-	-
		3/4	8	4	-	-	-	-
		1	6	4	-	-	-	-
		1 1/2	6	4	-	-	-	-
		2	4	-	-	-	-	-
		2 1/2	4	-	-	-	-	-
	TRUFast SIPHD	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-



Table 15. Maximum Fastener Spacing for ThermaBase-CI Utilizing 7/16" OSB, 1/2" OSB, or 3/4" Plywood With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastner Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (53 Mil) Continued	FastenMaster HeadLOK	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-
	SFS intec Dekfast	1/2	16	8	6	4	4	-
		3/4	12	8	6	4	4	-
		1	12	8	6	4	4	-
		1 1/2	8	6	4	4	-	-
		2	8	4	4	-	-	-
		2 1/2	6	4	-	-	-	-
		3	4	-	-	-	-	-

SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m²

1. Minimum fastener penetration into stud is the steel thickness plus three threads and the tip of the fastener.
2. The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing.
3. ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure.
4. Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap.
5. Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.



Table 16. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil)	Rmax Nailboard Fastener: SIPLD	$\frac{1}{2}$	24	16	12	8	8	6
		$\frac{3}{4}$	24	12	8	8	6	6
		1	20	12	8	8	6	4
		$1\frac{1}{2}$	16	8	8	6	4	4
		2	12	8	6	4	4	4
		$2\frac{1}{2}$	8	6	4	4	-	-
		3	6	4	4	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
	#8 Screw	$\frac{1}{2}$	16	8	6	4	4	4
		$\frac{3}{4}$	12	8	6	4	4	-
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	8	6	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
	#10 Screw	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	12	6	4	4	-	-
		2	8	6	4	-	-	-
		$2\frac{1}{2}$	6	4	-	-	-	-
	#12 Screw	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	4
		$1\frac{1}{2}$	12	8	6	4	4	-
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	4	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-



Table 16. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil) Continued	TRUFAST SIPLD	$\frac{1}{2}$	24	16	12	8	8	6
		$\frac{3}{4}$	24	12	8	8	6	6
		1	20	12	8	8	6	4
		$1\frac{1}{2}$	16	8	8	6	4	4
		2	12	8	6	4	4	4
		$2\frac{1}{2}$	8	6	4	4	-	-
		3	6	4	4	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
	FastenMaster HeadLOK	$\frac{1}{2}$	24	16	12	8	8	6
		$\frac{3}{4}$	24	12	8	8	6	6
		1	20	12	8	8	6	4
		$1\frac{1}{2}$	16	8	8	6	4	4
		2	12	8	6	4	4	4
		$2\frac{1}{2}$	8	6	4	4	-	-
		3	6	4	4	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
	SFS intec Dekfast	$\frac{1}{2}$	24	16	12	8	8	6
		$\frac{3}{4}$	24	12	8	8	6	6
		1	20	12	8	8	6	4
		$1\frac{1}{2}$	16	8	8	6	4	4
		2	12	8	6	4	4	4
		$2\frac{1}{2}$	8	6	4	4	-	-
		3	6	4	4	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-



Table 16. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge Structural (43 mil)	Rmax Nailboard Fastener: SIPLD	$\frac{1}{2}$	24	20	12	12	8	8
		$\frac{3}{4}$	24	16	12	8	8	6
		1	24	16	12	8	8	6
		$1\frac{1}{2}$	20	12	8	8	6	6
		2	16	8	8	6	4	4
		$2\frac{1}{2}$	12	8	6	4	4	-
		3	8	6	4	4	-	-
		$3\frac{1}{2}$	6	4	-	-	-	-
	#8 Screw	$\frac{1}{2}$	16	8	6	4	4	4
		$\frac{3}{4}$	12	8	6	4	4	-
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	8	6	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
	#10 Screw	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	12	6	4	4	-	-
		2	8	6	4	-	-	-
		$2\frac{1}{2}$	6	4	-	-	-	-
	#12 Screw	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	4
		$1\frac{1}{2}$	12	8	6	4	4	-
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	4	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-



Table 16. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge Structural (43 mil) Continued	TRUFAST SIPLD	$\frac{1}{2}$	24	20	12	12	8	8
		$\frac{3}{4}$	24	16	12	8	8	6
		1	24	16	12	8	8	6
		$1\frac{1}{2}$	20	12	8	8	6	6
		2	16	8	8	6	4	4
		$2\frac{1}{2}$	12	8	6	4	4	-
		3	8	6	4	4	-	-
		$3\frac{1}{2}$	6	4	-	-	-	-
	FastenMaster HeadLOK	$\frac{1}{2}$	24	20	12	12	8	8
		$\frac{3}{4}$	24	16	12	8	8	6
		1	24	16	12	8	8	6
		$1\frac{1}{2}$	20	12	8	8	6	6
		2	16	8	8	6	4	4
		$2\frac{1}{2}$	12	8	6	4	4	4
		3	8	6	4	4	-	-
		$3\frac{1}{2}$	6	4	-	-	-	-
	SFS intec Dekfast	$\frac{1}{2}$	24	20	12	8	8	8
		$\frac{3}{4}$	24	16	12	8	8	6
		1	24	16	12	8	8	6
		$1\frac{1}{2}$	20	12	8	8	6	6
		2	16	8	8	6	4	4
		$2\frac{1}{2}$	12	8	6	4	4	-
		3	8	6	4	4	-	-
		$3\frac{1}{2}$	6	4	-	-	-	-



Table 16. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (53 mil)	Rmax Nailboard Fastener: SIPHD	$\frac{1}{2}$	24	20	12	12	8	8
		$\frac{3}{4}$	24	16	12	8	8	6
		1	24	16	12	8	8	6
		$1\frac{1}{2}$	20	12	8	8	6	6
		2	16	8	8	6	4	4
		$2\frac{1}{2}$	12	8	6	4	4	-
		3	8	6	4	4	-	-
		$3\frac{1}{2}$	6	4	-	-	-	-
	#8 Screw	$\frac{1}{2}$	16	8	6	4	4	4
		$\frac{3}{4}$	12	8	6	4	4	-
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	8	6	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
	#10 Screw	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	12	6	4	4	-	-
		2	8	6	4	-	-	-
		$2\frac{1}{2}$	6	4	-	-	-	-
	#12 Screw	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	4
		$1\frac{1}{2}$	12	8	6	4	4	-
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	4	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-

Table 16. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 16" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (53 mil) Continued	TRUFAST SIPHD	$\frac{1}{2}$	24	20	12	12	8	8
		$\frac{3}{4}$	24	16	12	8	8	6
		1	24	16	12	8	8	6
		$1\frac{1}{2}$	20	12	8	8	6	6
		2	16	8	8	6	4	4
		$2\frac{1}{2}$	12	8	6	4	4	-
		3	8	6	4	4	-	-
		$3\frac{1}{2}$	6	4	-	-	-	-
	FastenMaster HeadLOK	$\frac{1}{2}$	24	20	12	12	8	8
		$\frac{3}{4}$	24	16	12	8	8	6
		1	24	16	12	8	8	6
		$1\frac{1}{2}$	20	12	8	8	6	6
		2	16	8	8	6	4	4
		$2\frac{1}{2}$	12	8	6	4	4	4
		3	8	6	4	4	-	-
		$3\frac{1}{2}$	6	4	-	-	-	-
	SFS intec Dekfast	$\frac{1}{2}$	24	20	12	8	8	8
		$\frac{3}{4}$	24	16	12	8	8	6
		1	24	16	12	8	8	6
		$1\frac{1}{2}$	20	12	8	8	6	6
		2	16	8	8	6	4	4
		$2\frac{1}{2}$	12	8	6	4	4	-
		3	8	6	4	4	-	-
		$3\frac{1}{2}$	6	4	-	-	-	-

SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m²

- Minimum fastener penetration into stud is the steel thickness plus three threads and the tip of the fastener.
- The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing.
- ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure.
- Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap.
- Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.



Table 17. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil)	Rmax Nailboard Fastener: SIPLD	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	8	6	4	4	-	-
		2	8	6	4	-	-	-
		$2\frac{1}{2}$	6	4	-	-	-	-
		3	4	-	-	-	-	-
	#8 Screw	$\frac{1}{2}$	8	6	4	-	-	-
		$\frac{3}{4}$	8	6	4	-	-	-
		1	8	4	4	-	-	-
		$1\frac{1}{2}$	6	4	-	-	-	-
		2	4	-	-	-	-	-
	#10 Screw	$\frac{1}{2}$	12	6	4	4	-	-
		$\frac{3}{4}$	8	6	4	4	-	-
		1	8	6	4	-	-	-
		$1\frac{1}{2}$	8	4	-	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
	#12 Screw	$\frac{1}{2}$	12	6	4	4	-	-
		$\frac{3}{4}$	8	6	4	4	-	-
		1	8	6	4	-	-	-
		$1\frac{1}{2}$	8	4	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
		3	4	-	-	-	-	-



Table 17. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
20-gauge Structural (33 mil) (Continued)	TRUFAST SIPLD	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	8	6	4	4	-	-
		2	8	6	4	-	-	-
		$2\frac{1}{2}$	6	4	-	-	-	-
		3	4	-	-	-	-	-
	FastenMaster HeadLOK	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	8	6	4	4	-	-
		2	8	6	4	-	-	-
		$2\frac{1}{2}$	6	4	-	-	-	-
		3	4	-	-	-	-	-
	SFS intec Dekfast	$\frac{1}{2}$	16	8	8	6	4	4
		$\frac{3}{4}$	16	8	6	6	4	4
		1	12	8	6	4	4	-
		$1\frac{1}{2}$	8	6	4	4	-	-
		2	8	6	4	-	-	-
		$2\frac{1}{2}$	6	4	-	-	-	-
		3	4	-	-	-	-	-
18-gauge Structural (43 mil)	Rmax Nailboard Fastener: SIPLD	$\frac{1}{2}$	20	12	8	8	6	4
		$\frac{3}{4}$	20	12	8	6	6	4
		1	16	8	8	6	4	4
		$1\frac{1}{2}$	12	8	6	4	4	4
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	4	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-



Table 17. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge Structural (43 mil) Continued	#8 Screw	$\frac{1}{2}$	8	6	4	-	-	-
		$\frac{3}{4}$	8	6	4	-	-	-
		1	8	4	4	-	-	-
		$1\frac{1}{2}$	6	4	-	-	-	-
		2	4	-	-	-	-	-
	#10 Screw	$\frac{1}{2}$	12	6	4	4	-	-
		$\frac{3}{4}$	8	6	4	4	-	-
		1	8	6	4	-	-	-
		$1\frac{1}{2}$	8	4	-	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
	#12 Screw	$\frac{1}{2}$	12	6	4	4	-	-
		$\frac{3}{4}$	8	6	4	4	-	-
		1	8	6	4	-	-	-
		$1\frac{1}{2}$	8	4	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
		3	4	-	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
	TRUFAST SIPLD	$\frac{1}{2}$	20	12	8	8	6	4
		$\frac{3}{4}$	20	12	8	6	6	4
		1	16	8	8	6	4	4
		$1\frac{1}{2}$	12	8	6	4	4	4
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	4	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-



Table 17. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
18-gauge Structural (43 mil) Continued	FastenMaster HeadLOK	$\frac{1}{2}$	20	12	8	8	6	4
		$\frac{3}{4}$	20	12	8	6	6	4
		1	16	8	8	6	4	4
		$1\frac{1}{2}$	12	8	6	4	4	4
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	6	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
	SFS intec Dekfast	$\frac{1}{2}$	20	12	8	6	6	4
		$\frac{3}{4}$	20	12	8	6	6	4
		1	16	8	8	6	4	4
		$1\frac{1}{2}$	12	8	6	4	4	4
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	4	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
16-gauge Structural (53 mil)	Rmax Nailboard Fastener: SIPHD	$\frac{1}{2}$	20	12	8	8	6	4
		$\frac{3}{4}$	20	12	8	6	6	4
		1	16	8	8	6	4	4
		$1\frac{1}{2}$	12	8	6	4	4	4
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	4	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
	#8 Screw	$\frac{1}{2}$	8	6	4	-	-	-
		$\frac{3}{4}$	8	6	4	-	-	-
		1	8	4	4	-	-	-
		$1\frac{1}{2}$	6	4	-	-	-	-
		2	4	-	-	-	-	-



Table 17. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (53 mil) Continued	#10 Screw	$\frac{1}{2}$	12	6	4	4	-	-
		$\frac{3}{4}$	8	6	4	4	-	-
		1	8	6	4	-	-	-
		$1\frac{1}{2}$	8	4	-	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
	#12 Screw	$\frac{1}{2}$	12	6	4	4	-	-
		$\frac{3}{4}$	8	6	4	4	-	-
		1	8	6	4	-	-	-
		$1\frac{1}{2}$	8	4	4	-	-	-
		2	6	4	-	-	-	-
		$2\frac{1}{2}$	4	-	-	-	-	-
		3	4	-	-	-	-	-
	TRUFAST SIPHD	$\frac{1}{2}$	20	12	8	8	6	4
		$\frac{3}{4}$	20	12	8	6	6	4
		1	16	8	8	6	4	4
		$1\frac{1}{2}$	12	8	6	4	4	4
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	4	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-
	FastenMaster HeadLOK	$\frac{1}{2}$	20	12	8	8	6	4
		$\frac{3}{4}$	20	12	8	6	6	4
		1	16	8	8	6	4	4
		$1\frac{1}{2}$	12	8	6	4	4	4
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	6	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-



Table 17. Maximum Fastener Spacing for ThermaBase-CI Utilizing $\frac{5}{8}$ " or $\frac{3}{4}$ " OSB
With Vertical Cold-Form Steel Studs Spaced 24" o.c.^{1,3,4,5}

Framing Member	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Fastener Spacing (in)					
			Specified Cladding Weight ² (psf)					
			5	10	15	20	25	30
16-gauge Structural (53 mil) (Continued)	SFS intec Dekfast	$\frac{1}{2}$	20	12	8	6	6	4
		$\frac{3}{4}$	20	12	8	6	6	4
		1	16	8	8	6	4	4
		$1\frac{1}{2}$	12	8	6	4	4	4
		2	8	6	4	4	-	-
		$2\frac{1}{2}$	8	4	4	-	-	-
		3	6	4	-	-	-	-
		$3\frac{1}{2}$	4	-	-	-	-	-

SI: 1 in = 25.4 mm, 1 psf = 0.0479 kN/m²

- Minimum fastener penetration into stud is the steel thickness plus three threads and the tip of the fastener.
- The weight of ThermaBase-CI and sheathing is included in the fastener spacing calculations. The specified cladding weight shall include all other supported materials besides the ThermaBase-CI and sheathing.
- ThermaBase-CI is installed directly to the studs with the OSB or plywood to the exterior of the structure.
- Nail and screw values determined using NDS Yield Limit Equations and TR-12 for evaluating the foam as a gap.
- Nail fasteners shall comply with ASTM F1667, except nail length shall be permitted to exceed ASTM F1667 standard lengths. Minimum bending yield strength for nails with a diameter up to 0.148", 0.162", and 0.225" shall be 90,000 psi, 90,000 psi, and 80,000 psi, respectively. Proprietary fastener properties are per published data or testing.

6.8 Fastener Attachments to Concrete and Masonry Substrates for ThermaBase-CI to Support Cladding Weight

6.8.1 Fasteners are required to attach the ThermaBase-CI sheathing to the substrate to carry the cladding weight listed in the tables below. The cladding weight shall include the weight of the ThermaBase-CI sheathing as well as any additional cladding attached to the sheathing. The tables below only consider the gravity (dead) loads corresponding to the tabulated cladding weights.

6.8.1.1 See **Table 18**, **Table 19**, and **Table 20** for allowable cladding loads for various fastener types and sheathing thicknesses for connection to minimum 2,500 psi concrete (at 28 days).

6.8.1.2 See **Table 21**, **Table 22**, and **Table 23** for allowable cladding loads for various fastener types and sheathing thicknesses for connection to concrete masonry unit (CMU) block.

6.8.2 All fasteners shall be installed into the face of CMU block.

6.8.3 For attaching to concrete substrate, fasteners with equal or greater design properties shall be permitted:

6.8.3.1 ITW Buildex Tapcon® Hex: $\frac{3}{16}$ " nominal diameter

6.8.3.2 Hilti KH-EZ C: $\frac{1}{4}$ " nominal diameter

6.8.3.3 Simpson Strong-Tie® Titen HD®: $\frac{1}{4}$ " nominal diameter



6.8.4 For attaching to CMU block, fasteners with equal or greater design properties shall be permitted:

- 6.8.4.1 ITW Buildex Tapcon Hex: $\frac{3}{16}$ " nominal diameter
- 6.8.4.2 Hilti KH-EZ C: $\frac{1}{4}$ " nominal diameter
- 6.8.4.3 Simpson Strong-Tie Titen HD: $\frac{1}{4}$ " nominal diameter
- 6.8.4.4 TRUFAST SIPLD: 0.189" shank diameter

Table 18. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to Concrete
(Horizontally Spaced at 16" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁴ (psf)					
			5	10	15	20	25	30
Concrete ($f'_c = 2,500$ psi)	$\frac{3}{16}$ " ITW Buildex Tapcon Hex ¹	$\frac{1}{2}$	24	24	24	16	12	12
		$\frac{3}{4}$	24	24	24	16	12	12
		1	24	24	20	16	12	8
		$1\frac{1}{2}$	24	24	20	12	12	8
		2	24	24	16	12	8	8
		$2\frac{1}{2}$	24	20	12	8	8	6
		3	24	16	8	8	6	4
		$3\frac{1}{2}$	24	12	8	6	4	4
		4	16	8	4	4	-	-
		$4\frac{1}{2}$	8	4	-	-	-	-
	$\frac{1}{4}$ " Hilti KH-EZ C ²	$\frac{1}{2}$	24	24	24	20	16	12
		$\frac{3}{4}$	24	24	24	20	16	12
		1	24	24	24	16	12	12
		$1\frac{1}{2}$	24	24	20	16	12	8
		2	24	24	20	12	12	8
		$2\frac{1}{2}$	24	24	16	12	8	8
		3	24	20	12	8	8	6
		$3\frac{1}{2}$	24	20	12	8	8	6
		4	24	16	8	8	6	4
		$4\frac{1}{2}$	24	12	8	6	4	4

Table 18. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to Concrete
(Horizontally Spaced at 16" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁴ (psf)					
			5	10	15	20	25	30
Concrete ($f'_c = 2,500$ psi) Continued	$\frac{1}{4}$ " Simpson Strong-Tie Titen HD ³	$\frac{1}{2}$	24	24	16	12	8	8
		$\frac{3}{4}$	24	24	16	12	8	8
		1	24	24	16	12	8	8
		$1\frac{1}{2}$	24	20	12	8	8	6
		2	24	20	12	8	8	6
		$2\frac{1}{2}$	24	16	12	8	6	6
		3	24	16	8	8	6	4
		$3\frac{1}{2}$	24	12	8	6	4	4
		4	20	8	6	4	4	-
		$4\frac{1}{2}$	16	8	4	4	-	-

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 psf = 47.88 N/m²

1. Minimum nominal embedment depth of 2" and minimum edge distance of 2".
2. Minimum nominal embedment depth of $1\frac{5}{8}$ " and minimum edge distance of 1.5".
3. Minimum nominal embedment depth of $1\frac{1}{8}$ " and minimum edge distance of 1.5".
4. The cladding weight shall include the weight of the ThermaBase-CI sheathing as well as any additional cladding attached to the sheathing.

Table 19. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to Concrete
(Horizontally Spaced at 24" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁴ (psf)					
			5	10	15	20	25	30
Concrete ($f'_c = 2,500$ psi)	$\frac{3}{16}$ " ITW Buildex Tapcon Hex ¹	$\frac{1}{2}$	24	24	16	12	8	8
		$\frac{3}{4}$	24	24	16	12	8	8
		1	24	20	12	8	8	6
		$1\frac{1}{2}$	24	20	12	8	8	6
		2	24	16	8	8	6	4
		$2\frac{1}{2}$	24	12	8	6	4	4
		3	20	8	6	4	4	-
		$3\frac{1}{2}$	16	8	4	4	-	-
		4	8	4	-	-	-	-
		$4\frac{1}{2}$	4	-	-	-	-	-



Table 19. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to Concrete
(Horizontally Spaced at 24" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁴ (psf)					
			5	10	15	20	25	30
Concrete (f _c ' = 2,500 psi) Continued	1/4" Hilti KH-EZ C ²	1/2	24	24	16	12	8	8
		3/4	24	24	16	12	8	8
		1	24	24	16	12	8	8
		1 1/2	24	20	12	8	8	6
		2	24	20	12	8	8	6
		2 1/2	24	16	12	8	6	6
		3	24	12	8	6	6	4
		3 1/2	24	12	8	6	4	4
		4	20	8	6	4	4	-
		4 1/2	16	8	4	4	-	-
	1/4" Simpson Strong-Tie Titen HD ³	1/2	24	16	12	8	6	6
		3/4	24	16	12	8	6	6
		1	24	16	8	8	6	4
		1 1/2	24	12	8	6	6	4
		2	24	12	8	6	4	4
		2 1/2	24	12	8	6	4	4
		3	20	8	6	4	4	-
		3 1/2	16	8	6	4	-	-
		4	12	6	4	-	-	-
		4 1/2	8	4	-	-	-	-

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 psf = 47.88 N/m²

- Minimum nominal embedment depth of 2" and minimum edge distance of 2".
- Minimum nominal embedment depth of 1 5/8" and minimum edge distance of 1.5".
- Minimum nominal embedment depth of 1 5/8" and minimum edge distance of 1.5".
- The cladding weight shall include the weight of the ThermaBase-CI sheathing as well as any additional cladding attached to the sheathing.



Table 20. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to Concrete
(Horizontally Spaced at 48" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁴ (psf)					
			5	10	15	20	25	30
Concrete ($f'_c = 2,500$ psi)	$\frac{3}{16}$ " ITW Buildex Tapcon Hex ¹	$\frac{1}{2}$	24	12	8	6	4	4
		$\frac{3}{4}$	24	12	8	6	4	4
		1	20	8	6	4	4	-
		$1\frac{1}{2}$	20	8	6	4	4	-
		2	16	8	4	4	-	-
		$2\frac{1}{2}$	12	6	4	-	-	-
		3	8	4	-	-	-	-
		$3\frac{1}{2}$	8	4	-	-	-	-
		4	4	-	-	-	-	-
	$\frac{1}{4}$ " Hilti KH-EZ C ²	$\frac{1}{2}$	24	12	8	6	4	4
		$\frac{3}{4}$	24	12	8	6	4	4
		1	24	12	8	6	4	4
		$1\frac{1}{2}$	20	8	6	4	4	-
		2	20	8	6	4	4	-
		$2\frac{1}{2}$	16	8	6	4	-	-
		3	12	6	4	-	-	-
		$3\frac{1}{2}$	12	6	4	-	-	-
		4	8	4	-	-	-	-
		$4\frac{1}{2}$	8	4	-	-	-	-
	$\frac{1}{4}$ " Simpson Strong-Tie Titen HD ³	$\frac{1}{2}$	16	8	6	4	-	-
		$\frac{3}{4}$	16	8	6	4	-	-
		1	16	8	4	4	-	-
		$1\frac{1}{2}$	12	6	4	-	-	-
		2	12	6	4	-	-	-
		$2\frac{1}{2}$	12	6	4	-	-	-
		3	8	4	-	-	-	-
		$3\frac{1}{2}$	8	4	-	-	-	-
		4	6	-	-	-	-	-
		$4\frac{1}{2}$	4	-	-	-	-	-



Table 20. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to Concrete
(Horizontally Spaced at 48" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁴ (psf)					
			5	10	15	20	25	30
SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 psf = 47.88 N/m ² 1. Minimum nominal embedment depth of 2" and minimum edge distance of 2". 2. Minimum nominal embedment depth of 1⅝" and minimum edge distance of 1.5". 3. Minimum nominal embedment depth of 1⅝" and minimum edge distance of 1.5". 4. The cladding weight shall include the weight of the ThermaBase-CI sheathing as well as any additional cladding attached to the sheathing.								

Table 21. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to CMU Block
(Horizontally Spaced at 16" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁵ (psf)					
			5	10	15	20	25	30
CMU Block	3/16" ITW Buildex Tapcon Hex ¹	1/2	24	16	8	8	6	4
		3/4	24	12	8	6	6	4
		1	24	12	8	6	4	4
		1 1/2	24	12	8	6	4	4
		2	20	8	6	4	4	-
		2 1/2	16	8	4	4	-	-
		3	12	6	4	-	-	-
		3 1/2	8	4	-	-	-	-
		4	4	-	-	-	-	-
	1/4" Hilti KH-EZ C ²	1/2	24	24	24	24	24	20
		3/4	24	24	24	24	24	20
		1	24	24	24	24	24	20
		1 1/2	24	24	24	24	20	16
		2	24	24	24	24	16	16
		2 1/2	24	24	24	20	16	12
		3	24	24	20	16	12	8
		3 1/2	24	24	16	12	8	8
		4	24	20	12	8	8	6
		4 1/2	24	12	8	6	4	4



Table 21. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to CMU Block
(Horizontally Spaced at 16" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁵ (psf)					
			5	10	15	20	25	30
CMU Block Continued	1/4" Simpson Strong-Tie Titen HD ³	1/2	24	24	24	24	24	20
		3/4	24	24	24	24	24	20
		1	24	24	24	24	24	20
		1 1/2	24	24	24	24	20	16
		2	24	24	24	24	16	16
		2 1/2	24	24	24	20	16	12
		3	24	24	24	16	12	12
		3 1/2	24	24	20	12	12	8
		4	24	24	16	12	8	8
		4 1/2	24	20	12	8	8	6
	TRUFAST SIPLD ⁴	1/2	24	24	24	20	16	12
		3/4	24	24	24	20	16	12
		1	24	24	24	20	16	12
		1 1/2	24	24	20	16	12	8
		2	24	24	16	12	8	8
		2 1/2	24	20	12	8	8	6
		3	24	16	12	8	6	6
		3 1/2	24	16	8	8	6	4
		4	24	12	8	6	4	4
		4 1/2	24	12	8	6	4	4

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 psf = 47.88 N/m²

- Allowable connection design strength is based on attachment to minimum Grade N, Type II, medium-weight or normal-weight CMU (conforming to ASTM C90) filled with 2,000 psi grout (conforming to ASTM C1019) and a minimum embedment of 1", edge distance of 4", and spacing of 3".
- Allowable connection design strength is based on attachment to minimum Grade N, Type II, lightweight CMU (conforming to ASTM C90) filled with 2,000 psi grout (conforming to ASTM C1019) and a minimum embedment of 1 5/8" edge distance of 4", and spacing of 4". At 28 days, the compressive strength of masonry, f_m , shall be a minimum of 1,500 psi.
- Allowable connection design strength is based on attachment to minimum Grade N, Type II, lightweight CMU (conforming to ASTM C90) filled with 2,000 psi grout (conforming to ASTM C1019) and a minimum embedment of 2 1/2", edge distance of 4", and spacing of 4". At 28 days, the compressive strength of masonry, f_m , shall be a minimum of 1,500 psi.
- Tabulated values do not consider the masonry strength in holding the fastener as a post-installed embedment. Minimum nominal embedment depth shall be determined in accordance with accepted practice.
- The cladding weight shall include the weight of the ThermaBase-CI sheathing as well as any additional cladding attached to the sheathing.



Table 22. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to CMU Block
(Horizontally Spaced at 24" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁵ (psf)					
			5	10	15	20	25	30
CMU Block	3/16" ITW Buildex Tapcon Hex ¹	1/2	20	8	6	4	4	-
		3/4	20	8	6	4	4	-
		1	16	8	6	4	-	-
		1 1/2	16	8	4	4	-	-
		2	12	6	4	-	-	-
		2 1/2	8	4	-	-	-	-
		3	8	4	-	-	-	-
		3 1/2	6	-	-	-	-	-
	1/4" Hilti KH-EZ C ²	1/2	24	24	24	20	16	12
		3/4	24	24	24	20	16	12
		1	24	24	24	20	16	12
		1 1/2	24	24	24	16	12	12
		2	24	24	20	16	12	8
		2 1/2	24	24	16	12	8	8
		3	24	20	12	8	8	6
		3 1/2	24	16	12	8	6	6
		4	24	12	8	6	4	4
		4 1/2	16	8	4	4	-	-
	1/4" Simpson Strong-Tie Titen HD ³	1/2	24	24	24	20	16	12
		3/4	24	24	24	20	16	12
		1	24	24	24	20	16	12
		1 1/2	24	24	24	16	12	12
		2	24	24	20	16	12	8
		2 1/2	24	24	16	12	8	8
		3	24	24	16	12	8	8
		3 1/2	24	20	12	8	8	6
		4	24	16	8	8	6	4
		4 1/2	24	12	8	6	4	4



Table 22. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to CMU Block
(Horizontally Spaced at 24" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁵ (psf)					
			5	10	15	20	25	30
CMU Block Continued	TRUFAST SIPLD ⁴	1/2	24	24	20	12	12	8
		3/4	24	24	20	12	12	8
		1	24	24	20	12	12	8
		1 1/2	24	20	12	8	8	6
		2	24	16	12	8	6	6
		2 1/2	24	12	8	6	6	4
		3	24	12	8	6	4	4
		3 1/2	20	8	6	4	4	-
		4	16	8	6	4	-	-
		4 1/2	16	8	4	4	-	-

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 psf = 47.88 N/m²

- Allowable connection design strength is based on attachment to minimum Grade N, Type II, medium-weight or normal-weight CMU (conforming to ASTM C90) filled with 2,000 psi grout (conforming to ASTM C1019) and a minimum embedment of 1", edge distance of 4", and spacing of 3".
- Allowable connection design strength is based on attachment to minimum Grade N, Type II, lightweight CMU (conforming to ASTM C90) filled with 2,000 psi grout (conforming to ASTM C1019) and a minimum embedment of 1 5/8" edge distance of 4", and spacing of 4". At 28 days, the compressive strength of masonry, f_m , shall be a minimum of 1,500 psi.
- Allowable connection design strength is based on attachment to minimum Grade N, Type II, lightweight CMU (conforming to ASTM C90) filled with 2,000 psi grout (conforming to ASTM C1019) and a minimum embedment of 2 1/2", edge distance of 4", and spacing of 4". At 28 days, the compressive strength of masonry, f_m , shall be a minimum of 1,500 psi.
- Tabulated values do not consider the masonry strength in holding the fastener as a post-installed embedment. Minimum nominal embedment depth shall be determined in accordance with accepted practice.
- The cladding weight shall include the weight of the ThermaBase-CI sheathing as well as any additional cladding attached to the sheathing.



Table 23. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to CMU Block
(Horizontally Spaced at 48" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁵ (psf)					
			5	10	15	20	25	30
CMU Block	³ / ₁₆ " ITW Buildex Tapcon Hex ¹	¹ / ₂	8	4	-	-	-	-
		³ / ₄	8	4	-	-	-	-
		1	8	4	-	-	-	-
		1 ¹ / ₂	8	4	-	-	-	-
		2	6	-	-	-	-	-
		2 ¹ / ₂	4	-	-	-	-	-
		3	4	-	-	-	-	-
	¹ / ₄ " Hilti KH-EZ C ²	¹ / ₂	24	20	12	8	8	6
		³ / ₄	24	20	12	8	8	6
		1	24	20	12	8	8	6
		1 ¹ / ₂	24	16	12	8	6	6
		2	24	16	8	8	6	4
		2 ¹ / ₂	24	12	8	6	4	4
		3	20	8	6	4	4	-
		3 ¹ / ₂	16	8	6	4	-	-
		4	12	6	4	-	-	-
		4 ¹ / ₂	8	4	-	-	-	-
	¹ / ₄ " Simpson Strong-Tie Titen HD ³	¹ / ₂	24	20	12	8	8	6
		³ / ₄	24	20	12	8	8	6
		1	24	20	12	8	8	6
		1 ¹ / ₂	24	16	12	8	6	6
		2	24	16	8	8	6	4
		2 ¹ / ₂	24	12	8	6	4	4
		3	24	12	8	6	4	4
		3 ¹ / ₂	20	8	6	4	4	-
		4	16	8	4	4	-	-
		4 ¹ / ₂	12	6	4	-	-	-



Table 23. Maximum Vertical Fastener Spacing for ThermaBase-CI Attached to CMU Block
(Horizontally Spaced at 48" o.c.)

Substrate Material	Screw Fastener Type and Minimum Size	Maximum Nominal Thickness of the Polyiso Portion of ThermaBase-CI (in)	Maximum Vertical Fastener Spacing (in)					
			Specified Cladding Weight ⁵ (psf)					
			5	10	15	20	25	30
CMU Block (Continued)	TRUFAST SIPLD ⁴	1/2	24	12	8	6	6	4
		3/4	24	12	8	6	6	4
		1	24	12	8	6	6	4
		1 1/2	20	8	6	4	4	-
		2	16	8	6	4	-	-
		2 1/2	12	6	4	-	-	-
		3	12	6	4	-	-	-
		3 1/2	8	4	-	-	-	-
		4	8	4	-	-	-	-
		4 1/2	8	4	-	-	-	-

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 psf = 47.88 N/m²

- Allowable connection design strength is based on attachment to minimum Grade N, Type II, medium-weight or normal-weight CMU (conforming to ASTM C90) filled with 2,000 psi grout (conforming to ASTM C1019) and a minimum embedment of 1", edge distance of 4", and spacing of 3".
- Allowable connection design strength is based on attachment to minimum Grade N, Type II, lightweight CMU (conforming to ASTM C90) filled with 2,000 psi grout (conforming to ASTM C1019) and a minimum embedment of 1 5/8" edge distance of 4", and spacing of 4". At 28 days, the compressive strength of masonry, f_m , shall be a minimum of 1,500 psi.
- Allowable connection design strength is based on attachment to minimum Grade N, Type II, lightweight CMU (conforming to ASTM C90) filled with 2,000 psi grout (conforming to ASTM C1019) and a minimum embedment of 2 1/2", edge distance of 4", and spacing of 4". At 28 days, the compressive strength of masonry, f_m , shall be a minimum of 1,500 psi.
- Tabulated values do not consider the masonry strength in holding the fastener as a post-installed embedment. Minimum nominal embedment depth shall be determined in accordance with accepted practice.
- The cladding weight shall include the weight of the ThermaBase-CI sheathing as well as any additional cladding attached to the sheathing.

- 6.9 Where the application falls outside of the performance evaluation, conditions of use, and/or installation requirements set forth herein, alternative techniques shall be permitted in accordance with accepted engineering practice and experience. This includes but is not limited to the following areas of engineering: mechanics or materials, structural, building science, and fire science.

7 Certified Performance³²

- 7.1 All construction methods shall conform to accepted engineering practices to ensure durable, livable, and safe construction and shall demonstrate acceptable workmanship reflecting journeyman quality of work of the various trades.³³
- 7.2 The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.³⁴



8 Regulatory Evaluation and Accepted Engineering Practice

- 8.1 ThermaBase-CI complies with the following legislatively adopted regulations and/or accepted engineering practice for the following reasons:
- 8.1.1 ThermaBase-CI was evaluated to determine the following:
- 8.1.1.1 Thermal resistance for use as insulating sheathing in accordance with [IECC Section C402.1](#), [IECC Section R402.1](#), and [IRC Section N1102.1](#).
 - 8.1.1.2 Foam plastic insulation performance in accordance with [IBC Section 2603](#) and [IRC Section R303](#).³⁵
 - 8.1.1.3 Connection to light-frame wood construction framing to support cladding weight in accordance with [IBC Section 1604.2](#) and [IRC Section R301.1.3](#).
 - 8.1.1.4 Connection to light-frame cold-formed steel framing to support cladding weight in accordance with [IBC Section 1604.2](#) and [IRC Section R301.1.3](#).
 - 8.1.1.5 Connection to concrete substrate to support cladding weight in accordance with [IBC Section 1901.3](#) and [IRC Section R301.1.3](#).
 - 8.1.1.6 Performance for use as an air barrier in accordance with [IRC Section N1101.10.5](#), [IECC Section C402.6.2.3.1](#),³⁶ and [IECC Section R303.1.5](#).
 - 8.1.1.7 Structural performance under lateral load conditions for use as an alternative to SDPWS Section 4.3 Wood Frame Shear Walls.
 - 8.1.1.8 Resistance to transverse loads for wall assemblies used in light-frame wood construction in accordance with [IRC Section R301.2.1](#) and [IBC Section 1609.1.1](#).
 - 8.1.1.9 Performance for use in a fire resistance rated assembly in accordance with [IBC Section 2603.5.1](#).
- 8.1.2 Design of cladding fastening to ThermaBase-CI is outside the scope of this report.
- 8.1.3 Seismic design is outside the scope of this report.
- 8.2 Any building code, regulation and/or accepted engineering evaluations (i.e., [research reports](#), [duly authenticated reports](#), etc.) that are conducted for this Listing were performed by DrJ, which is an [ISO/IEC 17065 accredited certification body](#) and a professional engineering company operated by [RDP](#) or [approved sources](#). DrJ is qualified³⁷ to practice product and regulatory compliance services within its [scope of accreditation and engineering expertise](#),³⁸ respectively.
- 8.3 Engineering evaluations are conducted with DrJ's ANAB [accredited ICS code scope](#) of expertise, which is also its areas of professional engineering competence.
- 8.4 Any regulation specific issues not addressed in this section are outside the scope of this report.

9 Installation

- 9.1 Installation shall comply with the approved construction documents, the manufacturer installation instructions, this report, and the applicable building code.
- 9.2 In the event of a conflict between the manufacturer installation instructions and this report, contact the manufacturer for counsel on the proper installation method.
- 9.3 *Installation Procedure*
- 9.3.1 *Orientation:*
- 9.3.1.1 ThermaBase-CI shall be installed vertically with framing that has a nominal thickness of not less than 2" (1.5" actual, 38.1 mm), and spaced a maximum of 24" (610 mm) o.c.
 - 9.3.1.2 ThermaBase-CI shall be installed vertically over concrete or CMU block in accordance with **Table 18** through **Table 23**.
 - 9.3.1.3 ThermaBase-CI shear wall aspect ratio must not exceed 3.5:1.



9.3.2 Attachment:

- 9.3.2.1 Fasteners shall be installed with a minimum edge distance of $\frac{3}{8}$ " (9.5 mm) unless otherwise noted.
- 9.3.2.2 Bending yield strength of commodity fasteners shall be as shown in [NDS Table 12N, footnote 2](#). Bending yield of proprietary fasteners are as published by the fastener manufacturer.
- 9.3.2.3 Fasteners shall be installed with the maximum on-center spacing as indicated in **Table 4** through **Table 23**.
- 9.3.2.4 See footnotes of **Table 18** through **Table 23** for more information about installation into concrete and masonry substrates.
 - 9.3.2.4.1 All fasteners installed in masonry shall be in the face of CMU block.

10 Substantiating Data

- 10.1 Testing has been performed under the supervision of a professional engineer and/or under the requirements of ISO/IEC 17025 as follows:
 - 10.1.1 Shear wall performance testing in accordance with ASTM E564
 - 10.1.2 Flame spread and smoke developed ratings testing in accordance with ASTM E84
 - 10.1.3 Air permeance testing in accordance with ASTM E2178
 - 10.1.4 Wind speed calculations in accordance with ASCE 7 and accepted engineering practices performed by DrJ Engineering, LLC
 - 10.1.5 Fastener spacing calculations in accordance with accepted engineering practices performed by DrJ Engineering, LLC
- 10.2 Information contained herein may include the result of testing and/or data analysis by sources that are [approved agencies](#), [approved sources](#), and/or an [RDP](#). Accuracy of external test data and resulting analysis is relied upon.
- 10.3 Where applicable, testing and/or engineering analysis are based upon provisions that have been codified into law through state or local adoption of regulations and standards. The developers of these regulations and standards are responsible for the reliability of published content. DrJ's engineering practice may use a regulation-adopted provision as the control. A regulation-endorsed control versus a simulation of the conditions of application to occur establishes a new material as [being equivalent](#) to the regulatory provision in terms of quality, [strength](#), effectiveness, [fire resistance](#), durability, and safety.
- 10.4 The accuracy of the provisions provided herein may be reliant upon the published properties of raw materials, which are defined by the grade mark, grade stamp, mill certificate, or [duly authenticated reports](#) from [approved agencies](#) and/or [approved sources](#) provided by the supplier. These are presumed to be minimum properties and relied upon to be accurate. The reliability of DrJ's engineering practice, as contained in this [duly authenticated report](#), may be dependent upon published design properties by others.
- 10.5 *Testing and Engineering Analysis*
 - 10.5.1 The strength, rigidity, and/or general performance of component parts and/or the integrated structure are determined by suitable tests that simulate the actual conditions of application that occur and/or by accepted engineering practice and experience.³⁹
- 10.6 Where additional condition of use and/or regulatory compliance information is required, please search for ThermaBase-CI on the [DrJ Certification website](#).



11 Findings

- 11.1 As outlined in **Section 6**, ThermaBase-CI has performance characteristics that were tested and/or meet applicable regulations. In addition, they are suitable for use pursuant to its specified purpose.
- 11.2 When used and installed in accordance with this duly authenticated report and the manufacturer installation instructions, ThermaBase-CI shall be approved for the following applications:
- 11.2.1 Use as a nail base for support of cladding materials when installed in accordance with the manufacturer installation instructions and this report
 - 11.2.2 Thermal resistance for use as insulating sheathing in accordance with IECC Section C402.1, IECC Section R402.1, and IRC Section N1102.1.
 - 11.2.3 Foam plastic insulation performance in accordance with IBC Section 2603 and IRC Section R303.⁴⁰
 - 11.2.4 Performance for use as an air barrier in accordance with IRC Section N1101.10.5, IECC Section C402.6.2.3.1,⁴¹ and IECC Section R303.1.5.
 - 11.2.5 Wind pressure resistance in accordance with IBC Section 1609.1.1 and IRC Section R301.2.1.
 - 11.2.6 Performance for use in a fire resistance rated assembly in accordance with IBC Section 2603.5.1.
- 11.3 Unless exempt by state statute, when ThermaBase-CI is to be used as a structural and/or building envelope component in the design of a specific building, the design shall be performed by an RDP.
- 11.4 Any application specific issues not addressed herein can be engineered by an RDP. Assistance with engineering is available from Rmax or Sika Corporation.
- 11.5 IBC Section 104.2.3⁴² (IRC Section R104.2.2⁴³ and IFC Section 104.2.3⁴⁴ are similar) in pertinent part state:
- 104.2.3 Alternative Materials, Design and Methods of Construction and Equipment.** The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code, provided that any such alternative is not specifically prohibited by this code and has been approved.
- 11.6 **Approved:**⁴⁵ Building regulations require that the building official shall accept duly authenticated reports.⁴⁶
- 11.6.1 An approved agency is “*approved*” when it is ANAB ISO/IEC 17065 accredited.
 - 11.6.2 An approved source is “*approved*” when an RDP is properly licensed to transact engineering commerce.
 - 11.6.3 Federal law, Title 18 US Code Section 242, requires that, where the alternative product, material, service, design, assembly, and/or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved. Denial without written reason deprives a protected right to free and fair competition in the marketplace.
- 11.7 DrJ is a licensed engineering company, employs licensed RDPs and is an ANAB Accredited Product Certification Body – Accreditation #1131.
- 11.8 Through the IAF Multilateral Arrangement (MLA), this duly authenticated report can be used to obtain product approval in any jurisdiction or country because all ANAB ISO/IEC 17065 duly authenticated reports are equivalent.⁴⁷

12 Conditions of Use

- 12.1 Material properties shall not fall outside the boundaries defined in **Section 6**.
- 12.2 As defined in **Section 6**, where material and/or engineering mechanics properties are created for load resisting design purposes, the resistance to the applied load shall not exceed the ability of the defined properties to resist those loads using the principles of accepted engineering practice.



12.3 As listed herein, ThermaBase-CI shall not be used:

12.3.1 To resist horizontal loads from concrete and masonry walls.

12.4 ThermaBase-CI may be used as a nail base for cladding. Fastener size and spacing for the attachment of ThermaBase-CI to the wall framing shall be in accordance with **Table 4** through **Table 17**.

12.5 Cladding attachments shall be in accordance with the cladding manufacturer installation instructions or an approved engineered design.

12.6 Design properties shall not exceed those described in **Section 6**.

12.7 When required by adopted legislation and enforced by the building official, also known as the Authority Having Jurisdiction (AHJ) in which the project is to be constructed:

12.7.1 Any calculations incorporated into the construction documents shall conform to accepted engineering practice and, when prepared by an approved source, shall be approved when signed and sealed.

12.7.2 This report and the installation instructions shall be submitted at the time of permit application.

12.7.3 This innovative product has an internal quality control program and a third-party quality assurance program.

12.7.4 At a minimum, this innovative product shall be installed per **Section 9**.

12.7.5 The review of this report by the AHJ shall comply with IBC Section 104.2.3.2 and IBC Section 105.3.1.

12.7.6 This innovative product has an internal quality control program and a third party quality assurance program in accordance with IBC Section 104.7.2, IBC Section 110.4, IBC Section 1703, IRC Section R104.7.2, and IRC Section R109.2.

12.7.7 The application of this innovative product in the context of this report is dependent upon the accuracy of the construction documents, implementation of installation instructions, inspection as required by IBC Section 110.3, IRC Section R109.2, and any other regulatory requirements that may apply.

12.8 The approval of this report by the AHJ shall comply with IBC Section 1707.1, where legislation states in part, *"the building official shall make, or cause to be made, the necessary tests and investigations; or the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in Section 104.2.3", all of IBC Section 104, and IBC Section 105.3.*

12.9 Design loads shall be determined in accordance with the regulations adopted by the jurisdiction in which the project is to be constructed and/or by the building designer (i.e., owner or RDP).

12.10 The actual design, suitability, and use of this report for any particular building, is the responsibility of the owner or the authorized agent of the owner.

13 Identification

13.1 Rmax ThermaBase-CI as listed in **Section 1.1**, is identified by a label on the board or packaging material bearing the manufacturer name, product name, this report number, and other information to confirm code compliance.

13.2 Additional technical information can be found at www.rmax.com.

14 Review Schedule

14.1 This report is subject to periodic review and revision. For the latest version, visit www.drjcertification.org.

14.2 For information on the status of this report, please contact DrJ Certification.



For more information, visit [dricertification.org](#) or call us at 608-310-6748.

Capitalized terms and responsibilities are defined pursuant to the applicable building code, applicable reference standards, the latest edition of TPI 1, the NDS, AISI S202, US professional engineering law, Canadian building code, Canada professional engineering law, Qualtim External Appendix A: Definitions/Commentary, Qualtim External Appendix B: Project/Deliverables, Qualtim External Appendix C: Intellectual Property and Trade Secrets, definitions created within Design Drawings and/or definitions within Reference Sheets. Beyond this, terms not defined shall have ordinarily accepted meanings as the context implies. Words used in the present tense include the future; words stated in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural, the singular.

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1702>

Alternative Materials, Design and Methods of Construction and Equipment: The provisions of any regulation code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by a regulation. Please review <https://www.justice.gov/atr/mission> and <https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#104.2.3>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1706.2.1~:text=the%20design%20strengths%20and%20permissible%20stresses%20shall%20be%20established%20by%20tests>

The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design of accepted engineering practice. <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1706.1.1~:text=Conformance%20to%20Standards-The%20design%20strengths%20and%20permissible%20stresses-of%20any%20structural>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1.1~:text=the%20building%20official%20shall%20make%2C%20or%20cause%20to%20be%20made%2C%20the%20necessary%20tests%20and%20investigations%3B%20or%20the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies%20in%20respect%20to%20the%20quality%20and%20manner%20of%20use%20of%20new%20materials%20or%20assemblies%20as%20provided%20for%20in%20Section%20104.2.3>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1703.4.2>

https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#approved_agency

https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#approved_source

<https://www.law.cornell.edu/uscode/text/18/1832> (b) Any organization that commits any offense described in subsection (a) shall be fined not more than the greater of \$5,000,000 or 3 times the value of the stolen trade secret to the organization, including expenses for research and design and other costs of reproducing the trade secret that the organization has thereby avoided. The federal government and each state have a public records act. To follow DTSA and comply state public records and trade secret legislation requires approval through ANAB ISO/IEC 17065 accredited certification bodies or approved sources. For more information, please review this website: [Intellectual Property and Trade Secrets](#).

<https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>

<https://www.cbiteest.com/accreditation/>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#104.1.1~:text=directed%20to%20enforce%20the%20provisions%20of%20this%20code>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#104.2.3> AND <https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#105.3.1>

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1>

<https://iaf.nu/en/about-iaf-mla/#~:text=Once%20an%20accreditation%20body%20is%20a%20signatory%20of%20the%20IAF%20MLA%2C%20it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope>

True for all ANAB accredited product evaluation agencies and all International Trade Agreements.

<https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>

Unless otherwise noted, the links referenced herein use un-amended versions of the [2024 International Code Council \(ICC\)](#) 2024 International Code Council (ICC) model codes as foundation references. Mississippi versions of the [IBC 2024](#) and the [IRC 2024](#) are un-amended. This material, product, design, service and/or method of construction also complies with the 2000-2012 versions of the referenced codes and the standards referenced therein. As pertinent to this technical and code compliance evaluation, CBI and/or DrJ staff have reviewed any state or local regulatory amendments to assure this report is in compliance.

See [Adoptions by Publisher](#) for the latest adoption of a non-amended or amended model code by the local jurisdiction. <https://up.codes/codes/general>

See [Adoptions by Publisher](#) for the latest adoption of a non-amended or amended model code by state. <https://up.codes/codes/general>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3282/subpart-A/section-3282.14>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2> (Listed%20or%20certified): <https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#listed> AND <https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#labeled>

[2021 IECC Section C402.5.1.3](#) and [2018 IECC Section C402.5.1.2.1](#)

[2021 IRC Section R316.3](#)

[2021 IRC Section R316.4](#)

[2021 IRC Section R316.5.1](#)

[2021 IRC Section R316.5.3](#)

[2021 IRC Section R316.5.4](#)

<https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1703.4>



- 33 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#:~:text=All%20construction%20methods%20shall%20be%20in%20conformance%20with%20accepted%20engineering%20practices%20to%20insure%20durable%2C%20livable%2C%20and%20safe%20housing%20and%20shall%20demonstrate%20acceptable%20workmanship%20reflecting%20journeyman%20quality%20of%20work%20of%20the%20various%20trades>
- 34 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#:~:text=The%20strength%20and%20rigidity%20of%20the%20component%20parts%20and/or%20the%20integrated%20structure%20shall%20be%20determined%20by%20engineering%20analysis%20or%20by%20suitable%20load%20tests%20to%20simulate%20the%20actual%20loads%20and%20conditions%20of%20application%20that%20occur>
- 35 [2021 IRC Section R316](#)
- 36 [2021 IECC Section C402.5.1.3 and 2018 IECC Section C402.5.1.2.1](#)
- 37 Qualification is performed by a legislatively defined Accreditation Body. ANSI National Accreditation Board (ANAB) is the largest independent accreditation body in North America and provides services in more than 75 countries. DrJ is an ANAB accredited product certification body.
- 38 <https://anabpd.ansi.org/Accreditation/product-certification/AllDirectoryDetails?prgID=1&orgID=2125&statusID=4#:~:text=Bill%20Payment%20Date-,Accredited%20Scopes-,13%20ENVIRONMENT.%20HEALTH>
- 39 See Code of Federal Regulations (CFR) Title 24 Subtitle B Chapter XX Part 3280 for definition: <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>
- 40 [2021 IRC Section R316](#)
- 41 [2021 IECC Section C402.5.1.3 and 2018 IECC Section C402.5.1.2.1](#)
- 42 [2021 IBC Section 104.11](#)
- 43 [2021 IRC Section R104.11](#)
- 44 2018: <https://up.codes/viewer/wyoming/ifc-2018/chapter/1/scope-and-administration#104.9> AND 2021: <https://up.codes/viewer/wyoming/ibc-2021/chapter/1/scope-and-administration#104.11>
- 45 Approved is an adjective that modifies the noun after it. For example, Approved Agency means that the Agency is accepted officially as being suitable in a particular situation. This example conforms to IBC/IRC/IFC Section 201.4 (<https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#201.4>) where the building code authorizes sentences to have an ordinarily accepted meaning such as the context implies.
- 46 <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1>
- 47 Multilateral approval is true for all ANAB accredited product evaluation agencies and all International Trade Agreements.