



Listing and Technical Evaluation Report™

Report No: 1910-01



Issue Date: November 7, 2019

Revision Date: August 15, 2024

Subject to Renewal: October 1, 2025

Shear Wall Performance of Carlisle® Coatings and Waterproofing R2+ BASE and R2+ BASE (Class A)

Trade Secret Report Holder:

Carlisle® Coatings and Waterproofing (CCW)

Phone: 1-800-527-7092

Website: www.carlisleccw.com

Email: kristofer.cullison@carlisleccm.com

CSI Designations:

DIVISION: 06 00 00 - WOOD, PLASTICS AND COMPOSITES

Section: 06 12 00 - Structural Panels

Section: 06 12 19 - Shear Wall Panels

Section: 06 16 00 - Sheathing

DIVISION: 07 00 00 - THERMAL AND MOISTURE PROTECTION

Section: 07 27 00 - Air Barriers

1 Innovative Products Evaluated¹

1.1 R2+ BASE and R2+ BASE (Class A)

2 Product Description and Materials

2.1 The innovative products evaluated in this report are shown in **Figure 1**.

SHOWN: R2+ BASE in Steel Stud Wall Assembly
with Metal Composite Cladding



Figure 1. R2+ BASE and R2+ BASE (Class A)



- 2.2 R2+ BASE and R2+ BASE (Class A) are an insulating nail base designed for use in commercial construction above-grade wall applications and are ASTM C1289 Type V compliant.
- 2.2.1 R2+ BASE and R2+ BASE (Class A) consist of a closed cell polyisocyanurate foam core with premium performance coated glass facers on both sides and laminated to a $\frac{5}{8}$ " or $\frac{3}{4}$ " fire treated, APA-TECO rated plywood one side.
- 2.2.2 R2+ BASE and R2+ BASE (Class A) are permitted for use in Types I-IV construction in accordance with IBC to provide continuous insulation within the building envelope.
- 2.3 *Material Availability*
- 2.3.1 R2+ BASE and R2+ BASE (Class A) are available with either a $\frac{5}{8}$ " or $\frac{3}{4}$ " fire treated plywood and 1" through $3\frac{1}{2}$ " coated glass polyiso.
- 2.3.1.1 *Total Thickness with $\frac{5}{8}$ " Substrate:*
- 2.3.1.1.1 $1\frac{5}{8}$ " through $4\frac{5}{8}$ "
- 2.3.1.2 *Total Thickness with $\frac{3}{4}$ " Substrate:*
- 2.3.1.2.1 $1\frac{3}{4}$ " through $4\frac{3}{4}$ "
- 2.3.1.3 *Standard Product Width:*
- 2.3.1.3.1 48" (1,219 mm)
- 2.3.1.4 *Standard Product Length:*
- 2.3.1.4.1 96" (2,438 mm)
- 2.4 As needed, review material properties for design in **Section 6** and to regulatory evaluation in **Section 8**.

3 Definitions

- 3.1 New Materials² are defined as building materials, equipment, appliances, systems or methods of construction not provided for by prescriptive and/or legislatively adopted regulations, known as alternative materials.³ The design strengths and permissible stresses shall be established by tests⁴ and/or engineering analysis.⁵
- 3.2 Duly authenticated reports⁶ and research reports⁷ are test reports and related engineering evaluations, which are written by an approved agency⁸ and/or an approved source.⁹
- 3.2.1 These reports contain intellectual property and/or trade secrets, which are protected by the Defend Trade Secrets Act (DTSA).¹⁰
- 3.3 An approved agency is "approved" when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is listed in the ANAB directory.
- 3.4 An approved source is "approved" when a professional engineer (i.e., Registered Design Professional) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.¹¹
- 3.5 Testing and/or inspections conducted for this duly authenticated report were performed by an ISO/IEC 17025 accredited testing laboratory, an ISO/IEC 17020 accredited inspection body and/or a licensed Registered Design Professional (RDP).
- 3.5.1 The Center for Building Innovation (CBI) is ANAB¹² ISO/IEC 17025 and ISO/IEC 17020 accredited.
- 3.6 The regulatory authority shall enforce¹³ the specific provisions of each legislatively adopted regulation. If there is a non-conformance, the specific regulatory section and language of the non-conformance shall be provided in writing¹⁴ stating the nonconformance and the path to its cure.
- 3.7 The regulatory authority shall accept duly authenticated reports from an approved agency and/or an approved source with respect to the quality and manner of use of new materials or assemblies as provided for in regulations regarding the use of alternative materials, designs, or methods of construction.¹⁵



3.8 ANAB is an International Accreditation Forum (IAF) Multilateral Recognition Arrangement (MLA) signatory where recognition of certificates, validation and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA with the appropriate scope, shall be approved.¹⁶ Therefore, all ANAB ISO/IEC 17065 duly authenticated reports are approval equivalent.¹⁷

3.9 Approval equity is a fundamental commercial and legal principle.¹⁸

4 Applicable Standards for the Listing; Regulations for the Regulatory Evaluation¹⁹

4.1 Standards

- 4.1.1 *ANSI/AWC SDPWS: Special Design Provisions for Wind and Seismic*
- 4.1.2 *ASCE/SEI 7: Minimum Design Loads and Associated Criteria for Buildings and Other Structures*
- 4.1.3 *ASTM E84: Standard Test Method for Surface Burning Characteristics of Building Materials*
- 4.1.4 *ASTM E564: Standard Practice for Static Load Test for Shear Resistance of Framed Walls for Buildings*
- 4.1.5 *ASTM E2126: Standard Test Methods for Cyclic (Reversed) Load Test for Shear Resistance of Vertical Elements of the Lateral Force Resisting Systems for Buildings*
- 4.1.6 *ASTM E2178: Standard Test Method for Air Permeance of Building Materials*

4.2 Regulations

- 4.2.1 *IBC – 15, 18, 21: International Building Code®*
- 4.2.2 *IRC – 15, 18, 21: International Residential Code®*
- 4.2.3 *IECC – 15, 18, 21: International Energy Conservation Code®*

5 Listed²⁰

5.1 Equipment, materials, products or services included in a List published by a nationally recognized testing laboratory (i.e., CBI), approved agency (i.e., CBI and DrJ), and/or approved source (i.e., DrJ) or other organization concerned with product evaluation (i.e., DrJ) that maintains periodic inspection (i.e., CBI) of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner.

6 Tabulated Properties Generated from Nationally Recognized Standards

6.1 R2+ BASE and R2+ BASE (Class A) may be used in the following applications:

- 6.1.1 Wall sheathing in buildings constructed in accordance with IBC and IRC for light-frame wood construction.
- 6.1.2 Structural wall sheathing to provide lateral load resistance (wind and seismic) for braced wall panels used in light-frame wood construction.
- 6.1.3 Structural wall sheathing in buildings constructed in accordance with the IBC requirements for Type V light frame construction.
- 6.1.4 Structural wall sheathing to provide resistance to transverse loads for wall assemblies used in light-frame wood construction.

6.2 Structural Applications

- 6.2.1 Except as otherwise described in this report, R2+ BASE and R2+ BASE (Class A) shall be installed in accordance with the applicable building codes listed in **Section 4** using the provisions set forth herein for the design and installation of Wood Structural Panels (WSP).
 - 6.2.1.1 R2+ BASE and R2+ BASE (Class A) are permitted to be designed in accordance with SDPWS for the design of shear walls using the methods set forth therein, including the perforated shear wall methodology, and subject to SDPWS boundary conditions, except as specifically allowed in this report.



- 6.2.2 Anchorage for in-plane shear shall be provided to transfer the induced shear force into and out of each shear wall. Shear wall anchorage shall be in accordance with the applicable code referenced in **Section 4**.
- 6.2.3 Installation is permitted for single top plate or double top plate applications.
- 6.2.4 *Prescriptive IBC Conventional Light-Frame Wood Construction:*
- 6.2.4.1 R2+ BASE and R2+ BASE (Class A) may be used to brace exterior walls of buildings as an equivalent alternative to Method 3 of the IBC when installed with blocked or unblocked 1/2" gypsum fastened with a minimum 5d cooler nail (0.086" diameter x 1 5/8") or #6 type W or S screw spaced a maximum of 16" o.c. at panel edges and 16" o.c. in the field. Bracing shall be in accordance with the conventional light frame construction method of IBC Section 2308.6 and this report.
- 6.2.5 *Performance-Based Wood-Frame Construction:*
- 6.2.5.1 R2+ BASE and R2+ BASE (Class A) used in wall assemblies designed as shear walls are permitted to be designed in accordance with the methodology used in SDPWS for WSP using the capacities shown in **Table 1** and **Table 2**.
- 6.2.5.2 R2+ BASE and R2+ BASE (Class A) shear walls are permitted to resist horizontal wind load forces using the allowable shear loads (in pounds per linear foot) set forth in **Table 1**.
- 6.2.6 R2+ BASE and R2+ BASE (Class A) shear walls that require seismic design in accordance with IBC Section 1613 shall use the seismic allowable unit shear capacities set forth in **Table 2**.
- 6.2.7 The response modification coefficient, R, system overstrength factor, Ω_0 , and deflection amplification factor, C_d , indicated in **Table 2** shall be used to determine the base shear, element design forces, and design story drift in accordance with ASCE 7 Chapter 12 and Section 14.5.
- 6.2.7.1 For Limit States Seismic Design, see **Table 3** for the specified shear strength, ductility and overstrength factors.

Table 1. R2+ BASE and R2+ BASE (Class A) Allowable Strength Design (ASD) Capacity (Wind)

Product ^{1,4}	Fastener ² (Spaced 3":12")	Maximum Stud Spacing (in)	Gypsum Wallboard ³ (GWB)	Gypsum Wallboard Fastener Spacing (edge:field) (in)	Allowable Unit Shear Capacity (plf)
R2+ BASE and R2+ BASE (Class A)	3 1/4" x 0.131" Smooth Shank Nail	16 o.c.	No GWB	N/A	325
			1/2" GWB	8:8	350
R2+ BASE and R2+ BASE (Class A) 5/8" FRT Plywood + 1" Polyiso	3 1/4" x 0.131" Smooth Shank Nail	16 o.c.	No GWB	N/A	700

SI: 1 in = 25.4 mm, 1 lb/ft = 0.0146 kN/m

- For R2+ BASE and R2+ BASE (Class A) design values shall be reduced in accordance with the fire retardant treatment manufacturer published strength design reduction factors for fasteners.
- R2+ BASE and R2+ BASE (Class A) attached with a minimum 3 1/4" x 0.131" smooth shank nail. Fasteners are to be spaced a maximum of 3" o.c. at the edges and 12" o.c. in the field with a minimum edge distance of 3/8". Minimum fastener penetration of 3/4" required. Maximum product thickness is 2 5/8" (2" foam plus 5/8" wood structural panel).
- Gypsum attached with minimum 5d cooler nail or #6 type W or S screws 1 1/4" long. Fastener spacing shall be as required above.
- R2+ BASE and R2+ BASE (Class A) joints shall be butted at framing members and a single row of fasteners must be applied to each panel edge into the stud below.



**Table 2. R2+ BASE and R2+ BASE (Class A) Allowable Stress Design (ASD)
Capacity and Seismic Design Coefficients^{1,2,3,10}**

Seismic Force-Resisting System	Max. Stud Spacing (in)	Gypsum Wallboard (GWB) ⁹	Seismic Allowable Unit Shear Capacity (plf) ⁴	Apparent Shear Stiffness, G_a (kips/in)	Response Modification Factor, R^5	System Overstrength Factor, Ω_0^6	Deflection Amplification Coefficient C_d^7	Structural System Limitations and Building Height Limit ⁸ (ft)				
								Seismic Design Category				
								B	C	D	E	F
Light-Frame (Wood) Walls Sheathed with R2+ BASE and R2+ BASE (Class A)	16 o.c.	1/2" GWB	280	9.4	6.5	3	4	NL	NL	65	65	65
		No GWB	260	3.7								

SI: 1 in = 25.4 mm, 1 lb/ft = 0.0146 kN/m, 1 kips/in = 175.13 kN/m

- For R2+ BASE and R2+ BASE (Class A) design values shall be reduced in accordance with the fire retardant treatment manufacturer published strength design reduction factors for fasteners.
- R2+ BASE and R2+ BASE (Class A) attached with a minimum 3 1/4" x 0.131" smooth shank nail. Fasteners are to be spaced a maximum of 3" o.c. at the edges and 12" o.c. in the field with a minimum edge distance of 3/8". Minimum fastener penetration of 3/4" required. Maximum product thickness is 2 5/8" (2" foam plus 5/8" wood structural panel).
- All seismic design coefficients follow the equivalency procedures as defined in **Section 8** of this report.
- Allowable unit shear capacity is based on a safety factor of 2.5 in accordance with ASCE 7 Chapter 12.
- Response modification coefficient, R , for use throughout ASCE 7. Note R reduces forces to a strength level, not an allowable stress level.
- The tabulated value of the overstrength factor, Ω_0 , is permitted to be reduced by subtracting one-half (0.5) for structures with flexible diaphragms.
- Deflection amplification factor, C_d , for use with ASCE 7 Sections 12.8.6, 12.8.7, and 12.9.2
- NL = Not Limited. Heights are measured from the base of the structure as defined in ASCE 7 Section 11.2.
- Gypsum attached with minimum #6 type W or S screws 1 1/4" long spaced 8" o.c. at panel edges and in the field. Maximum stud spacing is 16" o.c.
- Drift limits are required to be checked, in accordance with, and shall not exceed those as allowed by ASCE 7 Table 12.12-1.

**Table 3. R2+ BASE and R2+ BASE (Class A) Limit States Design Capacity
and Seismic Design Coefficients (Seismic)^{1,2,3}**

Seismic Force-Resisting System	Maximum Stud Spacing (in)	Gypsum Wallboard (GWB)	Seismic Specified Shear Strength (plf)	Ductility, R_d	Overstrength Factor, R_0
Light-Frame (Wood) Walls Sheathed with R2+ BASE and R2+ BASE (Class A)	16 o.c.	1/2" GWB	370	4.0	1.7
		No GWB	350	3.0	1.7

SI: 1 in = 25.4 mm, 1 lb/ft = 0.0146 kN/m

- For R2+ BASE and R2+ BASE (Class A) design values shall be reduced in accordance with the fire retardant treatment manufacturer published strength design reduction factors for fasteners.
- R2+ BASE and R2+ BASE (Class A) attached with a minimum 3 1/4" x 0.131" smooth shank nail. Fasteners are to be spaced a maximum of 3" o.c. at the edges and 12" o.c. in the field with a minimum edge distance of 3/8". Minimum fastener penetration of 3/4" required. Maximum product thickness is 2 5/8" (2" foam plus 5/8" wood structural panel).
- Gypsum attached with minimum #6 type W or S screws 1 1/4" long spaced 16" o.c. at panel edges and in the field. Maximum stud spacing is 16" o.c.



6.3 Transverse Wind Loading

- 6.3.1 Transverse wind load design shall be in accordance with IBC Section 2304.6.1. Fasteners must be minimum 6d common nail (2" x 0.113") with 1½" penetration or 8d common nail (2½" x 0.131") with 1¾" penetration.

6.4 Perforated Shear Walls

- 6.4.1 R2+ BASE and R2+ BASE (Class A) shear walls are permitted to be designed in accordance with the methodology found in SDPWS Section 4.3.3.5 with the following exceptions:

6.4.1.1 2015 SDPWS:

- 6.4.1.1.1 C_o from Equation 4.3-5 in SDPWS shall be replaced by the equation presented below:

$$C_o = \frac{r}{(0.6 + 0.4 \times r)} \times \frac{L_{tot}}{\sum L_i}$$

$$r = \frac{1}{1 + \frac{A_o}{h \sum L_i}}$$

where,

C_o = shear resistance adjustment factor

r = sheathing area ratio

L_{tot} = total length of the perforated shear wall (including the lengths of perforated shear wall segments, and the lengths of segments containing openings), [ft]


A_o = total area of openings, [ft²]

h = height of wall, [ft]

$\sum L_i$ = sum of the length of full-height sections, [ft]

6.4.1.2 2021 SDPWS:

- 6.4.1.2.1 R2+ BASE and R2+ BASE (Class A) shear walls are permitted to be designed in accordance with the methodology found in SDPWS for the design of shear walls using the methods set forth therein, including the perforated shear wall methodology, and subject to the SDPWS boundary conditions except as specifically allowed in this report. The following example shows how to calculate the capacity of a perforated shear wall with R2+ BASE and R2+ BASE (Class A) using 2015 SDPWS.



1. The total length of the perforated shear wall, L_{tot} , is 30'.
2. The height of the perforated shear wall, h , is 8'.
3. The sum of the perforated shear wall segment lengths, ΣL_i , is 10'.
4. The total area of the openings, A_o , is:
 - 4.1. Two (2) 7' x 6' 6" openings – 45.5 sq. ft. x 2 = 91 sq. ft.
 - 4.2. Two (2) 3' x 3' 6" openings – 10.5 sq. ft. x 2 = 21 sq. ft.
 - 4.3. Total opening area is: 91 + 21 = 112 sq. ft.
5. Using SDPWS Equation 4.3-6, the sheathing area ratio, r , is:

$$r = \frac{1}{1 + \frac{A_o}{h \Sigma L_i}} = \frac{1}{1 + \frac{112}{8 \times 10}} = 0.417$$

6. Using Table 4, the shear capacity adjustment factor, C_o , is:

$$C_o = \frac{r}{0.6 + 0.4 \times r} * \frac{L_{tot}}{\Sigma L_i} = \frac{0.417}{0.6 + 0.4 \times 0.417} * \frac{30}{10} = 1.63$$

7. From Table 1, the allowable unit shear capacity, v , is: 325 plf.
8. In accordance with SDPWS Section 4.3.3.5, the total ASD shear capacity of this perforated shear wall, $V_{perforated}$, is:

$$V_{perforated} = v \times \Sigma L_i \times C_o = 325 \text{ plf} \times 10 \text{ ft.} \times 1.63 = 5298 \text{ lbs.}$$

Figure 2. Example of a Perforated Shear Wall



6.5 Air Barrier

- 6.5.1 R2+ BASE and R2+ BASE (Class A) may be used as air barrier materials as prescribed in IRC Section N1102.4.1.1, IECC Section R303.1.5 and IECC Section C402.5.1 (see **Table 4**).

Table 4. Air Permeability^{1,2}

Product Name	Air Pressure (Pa)	Air Permeability [L/(s·m²)]
R2+ BASE	75	< 0.02
R2+ BASE (Class A)		
Imperial Units: 1 Pa = 0.000145 psi, 1 L/(s·m²) = 0.2 cfm/ft²		
1. Foam core tested in accordance with ASTM E2178.		
2. Air pressure and permeability numbers shown represent Air Permeability compliance and are not intended to represent the performance under actual conditions.		

6.6 Fire Safety Performance

6.6.1 Surface Burning Characteristics:

- 6.6.1.1 R2+ BASE and R2+ BASE (Class A) were evaluated to assess performance with regard to flame spread and smoke developed index as shown in **Table 5**.

Table 5. Surface Burning Characteristics^{1,2}

Product Name	Flame Spread Index	Smoke-Developed Index	Classification
R2+ BASE	≤ 75	≤ 450	Class B
R2+ BASE (Class A)	≤ 25	≤ 450	Class A
1. Foam core tested in accordance with ASTM E84. 2. Flame spread and smoke-developed indexes are shown for comparison purposes only and are not intended to represent the performance under actual fire conditions.			

- 6.7 Where the application falls outside of the performance evaluation, conditions of use and/or installation requirements set forth herein, alternative techniques shall be permitted in accordance with accepted engineering practice and experience. This includes but is not limited to the following areas of engineering: mechanics or materials, structural, building science and fire science.

7 Certified Performance²¹

- 7.1 All construction methods shall conform to accepted engineering practices to ensure durable, livable, and safe construction and shall demonstrate acceptable workmanship reflecting journeyman quality of work of the various trades.²²
- 7.2 The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.²³



8 Regulatory Evaluation and Accepted Engineering Practice

- 8.1 R2+ BASE and R2+ BASE (Class A) comply with the following legislatively adopted regulations and/or accepted engineering practice for the following reasons:
- 8.1.1 Structural performance for shear wall assemblies used as lateral force resisting systems in Seismic Design Categories A through F, have been tested and evaluated in accordance with the following standards:
 - 8.1.1.1 ASCE/SEI 7: Minimum Design Loads and Associated Criteria for Buildings and Other Structures
 - 8.1.1.2 ASTM D7989: Standard Practice for Demonstrating Equivalent In-Plane Lateral Seismic Performance to Wood-Frame Shear Walls Sheathed with Wood Structural Panels
 - 8.1.1.3 ASTM E72: Standard Test Methods of Conducting Strength Tests of Panels for Building Construction
 - 8.1.1.4 ASTM E564: Standard Practice for Static Load Test for Shear Resistance of Framed Walls for Buildings
 - 8.1.1.5 ASTM E2126: Standard Test Methods for Cyclic (Reversed) Load Test for Shear Resistance of Vertical Elements of the Lateral Force Resisting Systems for Buildings
 - 8.1.2 Lateral force resisting systems for use in both wind and seismic applications follow the performance-based provisions of [IBC Section 2306.1](#), [IBC Section 2306.3](#) and/or [Section 4.3 SDPWS](#) for light-frame wood wall assemblies.
 - 8.1.2.1 **Table 2** provides Seismic Design Coefficients (SDC) that conform to the requirements in ASCE 7 Section 12.2.1, 12.2.1.1 and Table 12.2-1 for design of wall assemblies in buildings that require seismic design.
 - 8.1.2.1.1 ASTM D7989 is accepted engineering practice used to establish SDC. Test data generated by ISO/IEC 17025 approved agencies and/or professional engineers, and all associated professional engineering evaluations, which use ASTM D7989 as their basis, are defined as intellectual property and/or trade secrets and are also defined as an independent design review (i.e., [Listings](#), [certified reports](#), [duly authenticated reports](#) from [approved agencies](#), and/or [research reports](#) prepared by [approved agencies](#) and/or [approved sources](#)).
 - 8.1.3 Structural performance under lateral load conditions for use as an alternative to the conventional wall bracing provisions of [IBC Section 2308.6](#), Method WSP for Type V construction.
 - 8.1.4 Structural performance under lateral load conditions for both wind and seismic loading for use with the IBC performance-based provisions, [IBC Section 2306.1](#) and [IBC Section 2306.3](#), for light-frame wood wall assemblies.
 - 8.1.4.1 **Table 2** provides SDC that conform to the requirements of ASCE 7 Section 12.2.1 and Table 12.2-1 for design of wall assemblies in buildings that require seismic design in accordance with ASCE 7 (i.e., all seismic design categories).
 - 8.1.4.2 The basis for equivalency testing is outlined in Section 12.2.1.1 of ASCE 7:

Use of seismic force-resisting systems not contained in Table 12.2-1 shall be permitted contingent on submittal to and approval by the Authority Having Jurisdiction and independent structural design review of an accompanying set of design criteria and substantiating analytical and test data. The design criteria shall specify any limitations on system use, including Seismic Design Category and height; required procedures for designing the system's components and connections; required detailing; and the values of the response modification coefficient, R ; overstrength factor Ω_0 ; and deflection amplification factor, C_d .
 - 8.1.4.3 The SDC evaluation uses the approach found in documentation entitled "[Establishing Seismic Equivalency for Proprietary Prefabricated Shear Panels](#)"²⁴ using code defined accepted engineering procedures, experience, and good technical judgement.



- 8.1.5 Structural performance under lateral load conditions for use as an alternative to Section 4.3 SDPWS Wood Frame Shear Walls.
- 8.1.6 Structural performance under lateral load conditions for use as a perforated shear wall.
- 8.1.7 Resistance to transverse loads for wall assemblies in accordance with IBC Section 1609.1.1.
- 8.1.8 Performance for use as an air barrier in accordance with IRC Section N1102.4.1.1, IECC Section R303.1.5 and IECC Section C402.5.1.1.
- 8.1.9 Performance in accordance with ASTM E84 for flame spread and smoke-developed index ratings in accordance with IBC Section 2603.5.4.
- 8.2 Fire resistance-rated wall assemblies in accordance with IBC Section 2603.5.1 are outside the scope of this report.
- 8.3 Any building code, regulation and/or accepted engineering evaluations (i.e., research reports, duly authenticated reports, etc.) that are conducted for this Listing were performed by DrJ Engineering, LLC (DrJ), an ISO/IEC 17065 accredited certification body and a professional engineering company operated by RDP/approved sources. DrJ is qualified²⁵ to practice product and regulatory compliance services within its scope of accreditation and engineering expertise, respectively.
- 8.4 Engineering evaluations are conducted with DrJ's ANAB accredited ICS code scope of expertise, which are also its areas of professional engineering competence.
- 8.5 Any regulation specific issues not addressed in this section are outside the scope of this report.

9 Installation

- 9.1 Installation shall comply with the approved construction documents, the manufacturer installation instructions, this report and the applicable building code.
- 9.2 In the event of a conflict between the manufacturer installation instructions and this report, the more restrictive shall govern.
- 9.3 *Installation Procedure*
 - 9.3.1 Protect surrounding areas and surfaces from damage.
 - 9.3.2 A water resistive barrier complying with IBC Section 1403.2²⁶ shall be installed over the R2+ BASE and R2+ BASE (Class A).
 - 9.3.3 R2+ BASE and R2+ BASE (Class A) shall not be applied over walls while they are vulnerable to water intrusion from above or behind.
 - 9.3.4 Do not block flashing, weeps or other drainage paths with R2+ BASE and R2+ BASE (Class A).
 - 9.3.5 Do not span expansion joints with R2+ BASE and R2+ BASE (Class A).
 - 9.3.6 During installation, take precautions to minimize moisture intrusion behind insulation.
 - 9.3.7 Beginning at the base of the wall, apply R2+ BASE and R2+ BASE (Class A) horizontally or vertically using maximum board lengths to minimize the number of joints.
 - 9.3.8 Pre-cut R2+ BASE and R2+ BASE (Class A) to fit openings and penetrations.
 - 9.3.9 Offset R2+ BASE and R2+ BASE (Class A) board joints a minimum of 6". Do not form four-corner intersections.
 - 9.3.10 Form a "corner lock" pattern by staggering vertical joints at inside and outside corners.
 - 9.3.11 Fill gaps greater than 1/8" between R2+ BASE and R2+ BASE (Class A) boards with expanding spray foam or approved sealant and strike flush. Expanding spray foam may also be applied onto the R2+ BASE and R2+ BASE (Class A) board edges during installation.
 - 9.3.12 Abut all joints tightly and ensure an overall flush, level surface.



- 9.3.13 Verify all materials are installed in accordance with current Carlisle Coatings and Waterproofing published literature and local code requirements.
- 9.3.14 Additional information on the installation and detailing of R2+ BASE and R2+ BASE (Class A) can be found at www.carlisleccw.com.
- 9.3.15 *Fastener Type:*
 - 9.3.15.1 Minimum 3 1/4" (82 mm) x 0.131" (3.5 mm) smooth shank nail with the underside of the head flush with the surface of the sheathing.
- 9.3.16 *Fastener Spacing:*
 - 9.3.16.1 Maximum 3" o.c. at the perimeter and 12" o.c. in the field with minimum 3/8" from board edges.
- 9.3.17 *Gypsum Wallboard (GWB):*
 - 9.3.17.1 Where required, GWB shall be installed with a minimum:
 - 9.3.17.1.1 #6 x 1 1/4" (32 mm) Type W or S screws
 - 9.3.17.1.2 5d cooler nails

10 Substantiating Data

- 10.1 Testing has been performed under the supervision of a professional engineer and/or under the requirements of ISO/IEC 17025 as follows:
 - 10.1.1 Flame spread and smoke developed ratings in accordance with ASTM E84
 - 10.1.2 Lateral load testing in accordance with ASTM E2126
 - 10.1.3 Air permeability testing in accordance with ASTM E2178
- 10.2 Information contained herein may include the result of testing and/or data analysis by sources that are approved agencies, approved sources and/or RDPs. Accuracy of external test data and resulting analysis is relied upon.
- 10.3 Where applicable, testing and/or engineering analysis are based upon provisions that have been codified into law through state or local adoption of regulations and standards. The developers of these regulations and standards are responsible for the reliability of published content. DrJ's engineering practice may use a regulation-adopted provision as the control. A regulation-endorsed control versus a simulation of the conditions of application to occur establishes a new material as being equivalent to the regulatory provision in terms of quality, strength, effectiveness, fire resistance, durability and safety.
- 10.4 The accuracy of the provisions provided herein may be reliant upon the published properties of raw materials, which are defined by the grade mark, grade stamp, mill certificate or duly authenticated reports from approved agencies and/or approved sources provided by the supplier. These are presumed to be minimum properties and relied upon to be accurate. The reliability of DrJ's engineering practice, as contained in this duly authenticated report, may be dependent upon published design properties by others.
- 10.5 Testing and engineering analysis: The strength, rigidity, and/or general performance of component parts and/or the integrated structure are determined by suitable tests that simulate the actual conditions of application that occur and/or by accepted engineering practice and experience.²⁷
- 10.6 Where additional condition of use and/or regulatory compliance information is required, please search for R2+ BASE and R2+ BASE (Class A) on the DrJ Certification website.



11 Findings

- 11.1 As outlined in **Section 6**, R2+ BASE and R2+ BASE (Class A) have performance characteristics that were tested and/or meet applicable regulations and are suitable for use pursuant to its specified purpose.
- 11.2 When used and installed in accordance with this duly authenticated report and the manufacturer installation instructions, R2+ BASE and R2+ BASE (Class A) shall be approved for the following applications:
- 11.2.1 Lateral load resistance due to wind and seismic loads carried by shear walls.
 - 11.2.2 Transverse load resistance due to components and cladding pressures on building surfaces.
 - 11.2.3 Performance for use as an air barrier material in accordance with IRC Section N1102.4.1.1, IECC Section R303.1.5 and IECC Section C402.5.1.
- 11.3 Unless exempt by state statute, when R2+ BASE and R2+ BASE (Class A) are to be used as a structural and/or building envelope component in the design of a specific building, the design shall be performed by an RDP.
- 11.4 Any application specific issues not addressed herein can be engineered by an RDP. Assistance with engineering is available from Carlisle Coatings and Waterproofing.
- 11.5 IBC Section 104.11 (IRC Section R104.11 and IFC Section 104.10²⁸ are similar) in pertinent part states:
- 104.11 Alternative materials, design and methods of construction and equipment.** The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code. Where the alternative material, design or method of construction is not approved, the building official shall respond in writing, stating the reasons the alternative was not approved.
- 11.6 **Approved:**²⁹ Building regulations require that the building official shall accept duly authenticated reports.³⁰
- 11.6.1 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited.
 - 11.6.2 An approved source is “approved” when an RDP is properly licensed to transact engineering commerce.
 - 11.6.3 Federal law, Title 18 US Code Section 242, requires that where the alternative product, material, service, design, assembly and/or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved. Denial without written reason deprives a protected right to free and fair competition in the marketplace.
- 11.7 DrJ is a licensed engineering company, employs licensed RDPs and is an ANAB-Accredited Product Certification Body – Accreditation #1131.
- 11.8 Through the IAF Multilateral Agreements (MLA), this duly authenticated report can be used to obtain product approval in any jurisdiction or country because all ANAB ISO/IEC 17065 duly authenticated reports are equivalent.³¹

12 Conditions of Use

- 12.1 Material properties shall not fall outside the boundaries defined in **Section 6**.
- 12.2 As defined in **Section 6**, where material and/or engineering mechanics properties are created for load resisting design purposes, the resistance to the applied load shall not exceed the ability of the defined properties to resist those loads using the principles of accepted engineering practice.
- 12.3 This report and the installation instructions, when required by a code official, shall be submitted at the time of permit application.
- 12.4 When R2+ BASE and R2+ BASE (Class A) are not installed for use as wall bracing as described in this report, the walls shall be braced by other materials, in accordance with the applicable code.



- 12.5 When used as part of a continuous air barrier assembly, all sheathing panel edges at the top and bottom of the wall assemblies and all joints between sheathing panels, shall be sealed with an approved construction tape.
- 12.6 When used in accordance with the IBC in Seismic Design Categories C, D, E, or F, special inspections shall comply with IBC Section 1705.13.³²
- 12.7 When used in accordance with the IBC in high wind areas, special inspections shall comply with IBC Section 1705.12.³³
- 12.8 Loads applied shall not exceed those recommended by the manufacturer as follows:
- 12.8.1 Allowable shear loads do not exceed values in **Table 1** for wind loads and **Table 2** for seismic loads.
 - 12.8.2 Transverse design loads shall not exceed those described in IBC Section 2304.6.1, unless an approved exterior wall covering capable of separately resisting loads perpendicular to the face of the walls is installed over the sheathing.
- 12.9 The manufacturer installation instructions shall be available on the jobsite for inspection.
- 12.10 When used in shear wall applications, all panel edges shall be supported by wall framing or solid blocking a minimum of 2" (51 mm) nominal in thickness.
- 12.11 When required by adopted legislation and enforced by the building official, also known as the authority having jurisdiction (AHJ) in which the project is to be constructed:
- 12.11.1 Any calculations incorporated into the construction documents shall conform to accepted engineering practice and, when prepared by an approved source, shall be approved when signed and sealed.
 - 12.11.2 This report and the installation instructions shall be submitted at the time of permit application.
 - 12.11.3 These innovative products have an internal quality control program and a third-party quality assurance program.
 - 12.11.4 At a minimum, these innovative products shall be installed per **Section 9** of this report.
 - 12.11.5 The review of this report by the AHJ shall comply with IBC Section 104 and IBC Section 105.4.
 - 12.11.6 These innovative products have an internal quality control program and a third party quality assurance program in accordance with IBC Section 104.4, IBC Section 110.4, IBC Section 1703, IRC Section R104.4 and IRC Section R109.2.
 - 12.11.7 The application of these innovative products in the context of this report is dependent upon the accuracy of the construction documents, implementation of installation instructions, inspection as required by IBC Section 110.3, IRC Section R109.2 and any other regulatory requirements that may apply.
- 12.12 The approval of this report by the AHJ shall comply with IBC Section 1707.1, where legislation states in part, *"the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new material or assemblies as provided for in Section 104.11,"* all of IBC Section 104, and IBC Section 105.4.
- 12.13 Design loads shall be determined in accordance with the regulations adopted by the jurisdiction in which the project is to be constructed and/or by the building designer (i.e., owner or RDP).
- 12.14 The actual design, suitability, and use of this report for any particular building, is the responsibility of the owner or the authorized agent of the owner.



13 Identification

- 13.1 The innovative products listed in **Section 1.1** are identified by a label on the board or packaging material bearing the manufacturer name, product name, this report number and other information to confirm code compliance.
- 13.2 Additional technical information can be found at www.carlisleccw.com.

14 Review Schedule

- 14.1 This report is subject to periodic review and revision. For the latest version, visit drjcertification.org.
- 14.2 For information on the status of this report, please contact [DrJ Certification](#).

15 Approved for Use Pursuant to U.S. and International Legislation Defined in Appendix A

- 15.1 R2+ BASE and R2+ BASE (Class A) are included in this report published by an approved agency that is concerned with evaluation of products or services, maintains periodic inspection of the production of listed materials or periodic evaluation of services. This report states either that the material, product or service meets recognized standards or has been tested and found suitable for a specified purpose. This report meets the legislative intent and definition of being acceptable to the AHJ.



Appendix A

1 Legislation that Authorizes AHJ Approval

- 1.1 **Fair Competition:** State legislatures have adopted Federal regulations for the examination and approval of building code referenced and alternative products, materials, designs, services, assemblies and/or methods of construction that:
 - 1.1.1 Advance innovation
 - 1.1.2 Promote competition so all businesses have the opportunity to compete on price and quality in an open market on a level playing field unhampered by anticompetitive constraints
 - 1.1.3 Benefit consumers through lower prices, better quality, and greater choice
- 1.2 **Adopted Legislation:** The following local, state and federal regulations affirmatively authorize these innovative products to be approved by AHJs, delegates of building departments and/or delegates of an agency of the federal government:
 - 1.2.1 Interstate commerce is governed by the Federal Department of Justice to encourage the use of innovative products, materials, designs, services, assemblies, and/or methods of construction. The goal is to “*protect economic freedom and opportunity by promoting free and fair competition in the marketplace.*”
 - 1.2.2 Title 18 US Code Section 242 affirms and regulates the right of individuals and businesses to freely and fairly have new products, materials, designs, services, assemblies and/or methods of construction approved for use in commerce. Disapproval of alternatives shall be based upon non-conformance with respect to specific provisions of adopted legislation and shall be provided in writing stating the reasons why the alternative was not approved, with reference to the specific legislation violated.
 - 1.2.3 The federal government and each state have a public records act. In addition, each state also has legislation that mimics the federal Defend Trade Secrets Act 2016 (DTSA),³⁴ where providing test reports, engineering analysis and/or other related IP/TS is subject to prison of not more than ten years³⁵ and/or a \$5,000,000 fine or 3 times the value of³⁶ the Intellectual Property (IP) and Trade Secrets (TS).
 - 1.2.3.1 Compliance with public records and trade secret legislation requires approval through the use of Listings, certified reports, Technical Evaluation Reports, duly authenticated reports and/or research reports prepared by approved agencies and/or approved sources.
 - 1.2.4 For new materials³⁷ that are not specifically provided for in any regulation, the design strengths and permissible stresses shall be established by tests, where suitable load tests simulate the actual loads and conditions of application that occur.
 - 1.2.5 The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design using accepted engineering practice.³⁸
 - 1.2.6 The commerce of approved sources (i.e., registered PEs) is regulated by professional engineering legislation. Professional engineering commerce shall always be approved by AHJs, except where there is evidence provided in writing, that specific legislation have been violated by an individual registered PE.
 - 1.2.7 The AHJ shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in IBC Section 104.11.³⁹



- 1.3 **Approved⁴⁰ by Los Angeles:** The Los Angeles Municipal Code (LAMC) states in pertinent part that the provisions of LAMC are not intended to prevent the use of any material, device or method of construction not specifically prescribed by LAMC. The Department shall use Part III, Recognized Standards in addition to Part II, Uniform Building Code Standards of Division 35, Article 1, Chapter IX of the LAMC in evaluation of products for approval where such standard exists for the product or the material and may use other approved standards that apply. Whenever tests or certificates of any material or fabricated assembly are required by Chapter IX of the LAMC, such tests or certification shall be made by a testing agency approved by the Superintendent of Building to conduct such tests or provide such certifications. The testing agency shall publish the scope and limitation(s) of the listed material or fabricated assembly.⁴¹ The Superintendent of Building Approved Testing Agency Roster is provided by the Los Angeles Department of Building and Safety (LADBS). The Center for Building Innovation (CBI) Certificate of Approval License is TA24945. Tests and certifications found in a DrJ Listing are LAMC approved. In addition, the Superintendent of Building shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in the California Building Code (CBC) Section 1707.1.⁴²
- 1.4 **Approved by Chicago:** The Municipal Code of Chicago (MCC) states in pertinent part that an Approved Agency is a Nationally Recognized Testing Laboratory (NRTL) acting within its recognized scope and/or a certification body accredited by the American National Standards Institute (ANSI) acting within its accredited scope. Construction materials and test procedures shall conform to the applicable standards listed in the MCC. Sufficient technical data shall be submitted to the building official to substantiate the proposed use of any product, material, service, design, assembly and/or method of construction not specifically provided for in the MCC. This technical data shall consist of research reports from approved sources (i.e., MCC defined Approved Agencies).
- 1.5 **Approved by New York City:** The 2022 NYC Building Code (NYCBC) states in part that an approved agency shall be deemed⁴³ an approved testing agency via ISO/IEC 17025 accreditation, an approved inspection agency via ISO/IEC 17020 accreditation, and an approved product evaluation agency via ISO/IEC 17065 accreditation. Accrediting agencies, other than federal agencies, must be members of an internationally recognized cooperation of laboratory and inspection accreditation bodies subject to a mutual recognition agreement⁴⁴ (i.e., ANAB, International Accreditation Forum also known as IAF, etc.).
- 1.6 **Approved by Florida:** Statewide approval of products, methods or systems of construction shall be approved, without further evaluation by:
- 1.6.1 A certification mark or listing of an approved certification agency,
 - 1.6.2 A test report from an approved testing laboratory,
 - 1.6.3 A product evaluation report based upon testing or comparative or rational analysis, or a combination thereof, from an approved product evaluation entity, or
 - 1.6.4 A product evaluation report based upon testing, comparative or rational analysis, or a combination thereof, developed, signed and sealed by a professional engineer or architect, licensed in Florida.
 - 1.6.5 For local product approval, products or systems of construction shall demonstrate compliance with the structural wind load requirements of the Florida Building Code (FBC) through one of the following methods:
 - 1.6.5.1 A certification mark, listing or label from a commission-approved certification agency indicating that the product complies with the code,
 - 1.6.5.2 A test report from a commission-approved testing laboratory indicating that the product tested complies with the code,
 - 1.6.5.3 A product-evaluation report based upon testing, comparative or rational analysis, or a combination thereof, from a commission-approved product evaluation entity which indicates that the product evaluated complies with the code,



- 1.6.5.4 A product-evaluation report or certification based upon testing or comparative or rational analysis, or a combination thereof, developed and signed and sealed by a Florida professional engineer or Florida registered architect, which indicates that the product complies with the code, or
- 1.6.5.5 A statewide product approval issued by the Florida Building Commission.
- 1.6.6 The [Florida Department of Business and Professional Regulation \(DBPR\)](#) website provides a listing of companies certified as a [Product Evaluation Agency](#) (i.e., EVLMiami 13692), a [Product Certification Agency](#) (i.e., CER10642), and as a [Florida Registered Engineer](#) (i.e., ANE13741).
- 1.7 **Approved by Miami-Dade County (i.e., Notice of Acceptance [NOA]):** A Florida statewide approval is an NOA. An NOA is a Florida local product approval. By Florida law, Miami-Dade County shall accept the statewide and local Florida Product Approval as provided for in Florida legislation [553.842](#) and [553.8425](#).
- 1.8 **Approved by New Jersey:** Pursuant to the 2018 Building Code of New Jersey in [IBC Section 1707.1 General](#),⁴⁵ it states: *"In the absence of approved rules or other approved standards, the building official shall accept duly authenticated reports from [approved agencies](#) in respect to the quality and manner of use of new materials or assemblies as provided for in the administrative provisions of the Uniform Construction Code (N.J.A.C. 5:23)"*.⁴⁶ Furthermore N.J.A.C 5:23-3.7 states: *"Municipal approvals of alternative materials, equipment, or methods of construction."*
- 1.8.1 **Approvals:** Alternative materials, equipment or methods of construction shall be approved by the appropriate subcode official provided the proposed design is satisfactory and that the materials, equipment or methods of construction are suitable for the intended use and are at least the equivalent in quality, strength, effectiveness, fire resistance, durability and safety of those conforming with the requirements of the regulations.
- 1.8.1.1 A field evaluation label and report or letter issued by a nationally recognized testing laboratory verifying that the specific material, equipment or method of construction meets the identified standards or has been tested and found to be suitable for the intended use, shall be accepted by the appropriate subcode official as meeting the requirements of the above.
- 1.8.1.2 Reports of engineering findings issued by nationally recognized evaluation service programs such as but not limited to, the Building Officials and Code Administrators (BOCA), the International Conference of Building Officials (ICBO), the Southern Building Code Congress International (SBCCI), the International Code Council (ICC), and the National Evaluation Service, Inc., shall be accepted by the appropriate subcode official as meeting the requirements of the above.
- 1.8.2 The [New Jersey Department of Community Affairs](#) has confirmed that technical evaluation reports, from any accredited entity listed by [ANAB](#), meets the requirements of item the previous paragraph, given that the listed entities are no longer in existence and/or do not provide *"reports of engineering findings."*
- 1.9 **Approved by the Code of Federal Regulations Manufactured Home Construction and Safety Standards:** Pursuant to Title 24, Subtitle B, Chapter XX, [Part 3282.14](#)⁴⁷ and [Part 3280](#),⁴⁸ the Department encourages innovation and the use of new technology in manufactured homes. The design and construction of a manufactured home shall conform to the provisions of Part 3282 and Part 3280 where key approval provisions in mandatory language follow:
- 1.9.1 *"All construction methods shall be in conformance with accepted engineering practices."*
- 1.9.2 *"The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur."*
- 1.9.3 *"The design stresses of all materials shall conform to accepted engineering practice."*



- 1.10 **Approval by US, Local and State Jurisdictions in General:** In all other local and state jurisdictions, the adopted building code legislation states in pertinent part that:
- 1.10.1 For new materials that are not specifically provided for in this code, the design strengths and permissible stresses shall be established by tests.⁴⁹
 - 1.10.2 For innovative alternatives and/or methods of construction, the building official shall accept duly authenticated reports from approved agencies with respect to the quality and manner of use of new materials or assemblies.⁵⁰
 - 1.10.2.1 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is in the ANAB directory.
 - 1.10.2.2 An approved source is “approved” when an RDP is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.⁵¹
 - 1.10.3 The design strengths and permissible stresses of any structural material...shall conform to the specifications and methods of design of accepted engineering practice performed by an approved source.⁵²
- 1.11 **Approval by International Jurisdictions:** The USMCA and GATT agreements provide for approval of innovative materials, designs, services, and/or methods of construction through the Agreement on Technical Barriers to Trade and the IAF Multilateral Recognition Arrangement (MLA), where these agreements:
- 1.11.1 State that conformity assessment procedures (i.e., ISO/IEC 17020, 17025, 17065, etc.) are prepared, adopted, and applied so as to grant access for suppliers of like products originating in the territories of other Members under conditions no less favourable than those accorded to suppliers of like products of national origin or originating in any other country, in a comparable situation.
 - 1.11.2 **Approved:** The purpose of the MLA is to ensure mutual recognition of accredited certification and validation/verification statements between signatories to the MLA and subsequently, acceptance of accredited certification and validation/verification statements in many markets based on one accreditation for the timely approval of innovative materials, designs, services, and/or methods of construction.
 - 1.11.3 ANAB is an IAF-MLA signatory where recognition of certificates, validation, and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA, with the appropriate scope, shall be approved.⁵³
 - 1.11.4 Therefore, all ANAB ISO/IEC 17065 duly authenticated reports are approval equivalent.⁵⁴
- 1.12 Approval equity is a fundamental commercial and legal principle.⁵⁵



Notes

- 1 For more information, visit drjcertification.org or call us at 608-310-6748.
- 2 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1702>
- 3 Alternative Materials, Design and Methods of Construction and Equipment: The provisions of any regulation code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by a regulation. Please review <https://www.justice.gov/atr/mission> and <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104.11>
- 4 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706>:-:text=the%20design%20strengths%20and%20permissible%20stresses%20shall%20be%20established%20by%20tests%20as
- 5 The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design of accepted engineering practice. <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706>:-:text=shall%20conform%20to%20the%20specifications%20and%20methods%20of%20design%20of%20accepted%20engineering%20practice
- 6 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>:-:text=the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies
- 7 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1703.4.2>
- 8 https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved_agency
- 9 https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved_source
- 10 <https://www.law.cornell.edu/uscode/text/18/1832> (b) Any organization that commits any offense described in subsection (a) shall be fined not more than the greater of \$5,000,000 or 3 times the value of the stolen trade secret to the organization, including expenses for research and design and other costs of reproducing the trade secret that the organization has thereby avoided. The federal government and each state have a public records act. To follow DTSA and comply state public records and trade secret legislation requires approval through ANAB ISO/IEC 17065 accredited certification bodies or approved sources. For more information, please review this website: [Intellectual Property and Trade Secrets](https://www.ipandts.com/).
- 11 <https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>
- 12 <https://www.cbiteest.com/accreditation/>
- 13 <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104>:-:text=to%20enforce%20the%20provisions%20of%20this%20code
- 14 <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104.11>:-:text=Where%20the%20alternative%20material%2C%20design%20or%20method%20of%20construction%20is%20not%20approved%2C%20the%20building%20official%20shall%20respond%20in%20writing%2C%20stating%20the%20reasons%20why%20the%20alternative%20was%20not%20approved AND <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#105.3.1>:-:text=If%20the%20application%20or%20the%20construction%20documents%20do%20not%20conform%20to%20the%20requirements%20of%20pertinent%20laws%2C%20the%20building%20official%20shall%20reject%20such%20application%20in%20writing%2C%20stating%20the%20reasons%20therefore
- 15 <https://up.codes/viewer/colorado/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>:-:text=the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies%20in%20respect%20to%20the%20quality%20and%20manner%20of%20use%20of%20new%20materials%20or%20assemblies%20as%20provided%20for%20in%20Section%20104.11
- 16 <https://iaf.eu/en/about-iaf-mia/#>:-:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope
- 17 True for all ANAB accredited product evaluation agencies and all International Trade Agreements.
- 18 <https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>
- 19 Unless otherwise noted, all references in this Listing are from the 2021 version of the codes and the standards referenced therein. This material, product, design, service and/or method of construction also complies with the 2000-2021 versions of the referenced codes and the standards referenced therein.
- 20 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2>(Listed%20or%20certified); <https://up.codes/viewer/colorado/ibc-2021/chapter/2/definitions#listed> AND <https://up.codes/viewer/colorado/ibc-2021/chapter/2/definitions#labeled>
- 21 <https://up.codes/viewer/colorado/ibc-2021/chapter/17/special-inspections-and-tests#1703.4>
- 22 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#>:-:text=All%20construction%20methods%20shall%20be%20in%20conformance%20with%20accepted%20engineering%20practices%20to%20insure%20durable%2C%20livable%2C%20and%20safe%20housing%20and%20shall%20demonstrate%20acceptable%20workmanship%20reflecting%20journeyman%20quality%20of%20work%20of%20the%20various%20trades
- 23 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#>:-:text=The%20strength%20and%20rigidity%20of%20the%20component%20parts%20and/or%20the%20integrated%20structure%20shall%20be%20determined%20by%20engineering%20analysis%20or%20by%20suitable%20load%20tests%20to%20simulate%20the%20actual%20loads%20and%20conditions%20of%20application%20that%20occur
- 24 <https://www.structuremag.org/wp-content/uploads/2014/08/C-StructuralPerformance-Nelson-Aug081.pdf>
- 25 Qualification is performed by a legislatively defined Accreditation Body. ANSI National Accreditation Board (ANAB) is the largest independent accreditation body in North America and provides services in more than 75 countries. DrJ is an ANAB accredited product certification body.
- 26 [2015 IBC Section 1404.2](https://www.internationalbuildingcode.org/IBC-2015-IBC-Section-1404.2)
- 27 See Code of Federal Regulations (CFR) Title 24 Subtitle B Chapter XX Part 3280 for definition.
- 28 [2018 IBC Section 104.9](https://www.internationalbuildingcode.org/IBC-2018-IBC-Section-104.9)
- 29 Approved is an adjective that modifies the noun after it. For example, Approved Agency means that the Agency is accepted officially as being suitable in a particular situation. This example conforms to IBC/IRC/IFC [Section 201.4](https://www.internationalbuildingcode.org/IBC-2015-IBC-Section-201.4) where the building code authorizes sentences to have an ordinarily accepted meaning such as the context implies.



<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>

Multilateral approval is true for all ANAB accredited product evaluation agencies and all International Trade Agreements.

[2018 IBC Section 1705.12](#)

[2018 IBC Section 1705.11](#)

<http://www.drjengineering.org/AppendixC> AND <https://www.drjcertification.org/cornell-2016-protection-trade-secrets>

<https://www.law.cornell.edu/uscode/text/18/1832#:~:text=imprisoned%20not%20more%20than%2010%20years>

<https://www.law.cornell.edu/uscode/text/18/1832#:~:text=Any%20organization%20that,has%20thereby%20avoided>

<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706.2>

IBC 2021, Section 1706.1 Conformance to Standards

IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General

See **Section 11** for the distilled building code definition of **Approved**

Los Angeles Municipal Code, SEC. 98.0503. TESTING AGENCIES

<https://up.codes/viewer/california/ca-building-code-2022/chapter/17/special-inspections-and-tests#1707.1>

New York City, The Rules of the City of New York, § 101-07 Approved Agencies

New York City, The Rules of the City of New York, § 101-07 Approved Agencies

https://up.codes/viewer/new_jersey/ibc-2018/chapter/17/special-inspections-and-tests#1707.1

<https://www.nj.gov/dca/divisions/codes/codreg/ucc.html>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3282/subpart-A/section-3282.14>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>

IBC 2021, Section 1706 Design Strengths of Materials, 1706.2 New Materials. Adopted law pursuant to IBC model code language 1706.2.

IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General. Adopted law pursuant to IBC model code language 1707.1.

<https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>

IBC 2021, Section 1706 Design Strengths of Materials, Section 1706.1 Conformance to Standards Adopted law pursuant to IBC model code language 1706.1.

<https://iaf.nu/en/about-iaf->

[mla/#:~:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope](#)

True for all ANAB accredited product evaluation agencies and all International Trade Agreements.

<https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>