

Listing and Technical Evaluation Report™

Report No: 1911-01



Issue Date: June 18, 1930

Revision Date: October 1, 2024

Subject to Renewal: October 1, 2025

Big Timber® BX and YTX General Purpose Screw Properties

Trade Secret Report Holder:

Western Builders Supply dba Big Timber®

Phone: 406-252-6309

Website: www.bigtimberfasteners.com

Email: sales@bigtimberfasteners.com

CSI Designations:

DIVISION: 06 00 00 - WOOD, PLASTICS AND COMPOSITES

Section: 06 05 23 - Wood, Plastic, and Composite Fastenings

1 Innovative Products Evaluated¹

- 1.1 BTX and YTX General Purpose Screws

2 Product Description and Materials

- 2.1 The innovative products evaluated in this report are shown in **Figure 1** and **Figure 2**.



Figure 1. BTX General Purpose Screw (For Exterior Use)



Figure 2. YTX General Purpose Screw (For Interior Use)

- 2.2 BTX and YTX General Purpose Screws have a round flat head with a star drive (Torx screw) and are partially threaded. The BTX General Purpose Screw (**Figure 1**) has a 1200hr Bronze coating for exterior use, and the YTX General Purpose Screw (**Figure 2**) has a gold zinc coating for interior use.

- 2.2.1 BTX General Purpose Screws are coated with a proprietary coating, designated as Bronze, which exceeds the protections provided by hot-dipped galvanized coatings conforming to ASTM A153.



- 2.3 BTX General Purpose Screws are approved for use in chemically treated or untreated lumber where ASTM A153, Class D coatings are used in accordance with IBC Section 2304.10 and IRC Section R317.3.
- 2.3.1 The proprietary coating has been tested and found to exceed the protection provided by code-approved hot-dipped galvanized coatings meeting ASTM A153, Class D (IBC Section 2304.10.6² and IRC Section R317.3), allowing for its use in pressure-treated wood.
- 2.3.2 BTX General Purpose Screws are approved for use in fire-retardant treated lumber, provided the conditions set forth by the fire retardant treated lumber manufacturer be met, including appropriate strength reductions.
- 2.4 YTX General Purpose Screws are coated with a proprietary zinc coating, designated as Gold Star.
- 2.5 BTX and YTX General Purpose Screws are described in **Table 1** and **Table 2**.

Table 1. BTX Fastener Specifications

Fastener Name	Designation	Head (in)		Nominal Length ¹ (in)	Thread Length ¹ (in)	Shank Diameter (in)	Thread Diameter (in)		Specified Min. Core Hardness ⁴ (HV 0.3)	Nominal Bending Yield Fyb (psi)	Allowable Fastener Strength (lbf)	
		Diameter	Drive Type				Minor	Major			Tensile	Shear ³
BTX	8 x 3/4"	0.325	T20	3/4	3/4	0.119	0.102	0.163	355	198,000	640	515
	8 x 1"			1	3/4							
	8 x 1 1/4"			1 1/4	3/4							
	8 x 1 1/2"			1 1/2	1							
	8 x 1 3/4"			1 3/4	1 1/4							
	8 x 2"			2	1 1/4							
	9 x 1 1/2"	0.344	T25	1 1/2	1	0.135	0.122	0.175	355	211,000	820	595
	9 x 2"			2	1 1/4							
	9 x 2 1/2"			2 1/2	1 1/2							
	9 x 2 3/4"			2 3/4	1 1/2							
	9 x 3"			3	1 1/2							
	9 x 3 1/8"			3 1/8	1 1/2							
	10 x 2"	0.374	T25	2	1 1/4	0.151	0.134	0.209	355	205,000	960	710
	10 x 2 1/2"			2 1/2	1 1/2							
	10 x 3"			3	1 1/2							
	10 x 3 1/2"			3 1/2	2							
	10 x 4"			4	2							
	10 x 5"			5	2 1/2							
	10 x 6"			6	2 1/2							

**Table 1. BTX Fastener Specifications**

Fastener Name	Designation	Head (in)		Nominal Length ¹ (in)	Thread Length ¹ (in)	Shank Diameter (in)	Thread Diameter (in)		Specified Min. Core Hardness ⁴ (HV 0.3)	Nominal Bending Yield Fyb (psi)	Allowable Fastener Strength (lbf)	
		Diameter	Drive Type				Minor	Major			Tensile	Shear ³
BTX (Continued)	14 x 5"	0.465	T30	5	2 1/2	0.169	0.145	0.232	286	211,000	1,270	960
	14 x 6"			6	2 1/2							
	14 x 7"			7	2 1/2							
	14 x 8"			8	2 1/2							

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N, 1 psi = 0.00689 MPa

1. Fastener length is measured from the top of the head to the tip. Thread length includes the tapered tip and excludes the knurl (see **Figure 1**).
2. Shank diameter based on manufactured thickness. Finished dimensions are larger, due to the proprietary coatings added.
3. Shear strength applicable at both the smooth shank and thread diameter.
4. Based on a 300-gram load using the Vickers indenter.

Table 2. YTX Fastener Specifications

Fastener Name	Designation	Head (in)		Nominal Length ¹ (in)	Thread Length ¹ (in)	Shank Diameter (in)	Thread Diameter (in)		Specified Min. Core Hardness ⁴ (HV 0.3)	Nominal Bending Yield Fyb (psi)	Allowable Fastener Strength (lbf)	
		Diameter	Drive Type				Minor	Major			Tensile	Shear ³
YTX	8 x 1"	0.325	T20	1	3/4	0.119	0.102	0.163	355	198,000	640	515
	8 x 1 1/4"			1 1/4	3/4							
	8 x 1 1/2"			1 1/2	1							
	8 x 1 3/4"			1 3/4	1 1/4							
	8 x 2"			2	1 1/4							
	8 x 2 1/2"			2 1/2	1 1/2							
	9 x 2"	0.344	T25	2	1 1/4	0.135	0.122	0.175	355	211,000	820	595
	9 x 2 1/2"			2 1/2	1 1/2							
	9 x 2 3/4"			2 3/4	1 1/2							
	9 x 3"			3	1 1/2							
	9 x 3 1/8"			3 1/8	1 1/2							

Table 2. YTX Fastener Specifications

Fastener Name	Designation	Head (in)		Nominal Length ¹ (in)	Thread Length ¹ (in)	Shank Diameter (in)	Thread Diameter (in)		Specified Min. Core Hardness ⁴ (HV 0.3)	Nominal Bending Yield Fyb (psi)	Allowable Fastener Strength (lbf)	
		Diameter	Drive Type				Minor	Major			Tensile	Shear ³
YTX (Continued)	10 x 1 1/2"	0.374	T25	1 1/2	1	0.151	0.134	0.209	355	205,000	960	710
	10 x 2"			2	1 1/4							
	10 x 2 1/2"			2 1/2	1 1/2							
	10 x 3"			3	1 1/2							
	10 x 3 1/8"			3 1/8	1 1/2							
	10 x 3 1/2"			3 1/2	2							
	10 x 4"			4	2							
	10 x 5"			5	2 1/2							
	10 x 6"			6	2 1/2							

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N, 1 psi = 0.00689 MPa

1. Fastener length is measured from the top of the head to the tip. Thread length includes the tapered tip and excludes the knurl (see **Figure 2**).
2. Shank diameter based on manufactured thickness. Finished dimensions are larger, due to the proprietary coatings added.
3. Shear strength applicable at both the smooth shank and thread diameter.
4. Based on a 300-gram load using the Vickers indenter.

2.6 As needed, review material properties for design in **Section 6** and to regulatory evaluation in **Section 8**.

3 Definitions

- 3.1 New Materials³ are defined as building materials, equipment, appliances, systems or methods of construction not provided for by prescriptive and/or legislatively adopted regulations, known as alternative materials.⁴ The design strengths and permissible stresses shall be established by tests⁵ and/or engineering analysis.⁶
- 3.2 Duly authenticated reports⁷ and research reports⁸ are test reports and related engineering evaluations, which are written by an approved agency⁹ and/or an approved source.¹⁰
 - 3.2.1 These reports contain intellectual property and/or trade secrets, which are protected by the Defend Trade Secrets Act (DTSA).¹¹
- 3.3 An approved agency is "approved" when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is listed in the ANAB directory.
- 3.4 An approved source is "approved" when a professional engineer (i.e., Registered Design Professional) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.¹²
- 3.5 Testing and/or inspections conducted for this duly authenticated report were performed by an ISO/IEC 17025 accredited testing laboratory, an ISO/IEC 17020 accredited inspection body and/or a licensed Registered Design Professional (RDP).
 - 3.5.1 The Center for Building Innovation (CBI) is ANAB¹³ ISO/IEC 17025 and ISO/IEC 17020 accredited.



- 3.6 The regulatory authority shall enforce¹⁴ the specific provisions of each legislatively adopted regulation. If there is a non-conformance, the specific regulatory section and language of the non-conformance shall be provided in writing¹⁵ stating the nonconformance and the path to its cure.
- 3.7 The regulatory authority shall accept duly authenticated reports from an approved agency and/or an approved source with respect to the quality and manner of use of new materials or assemblies as provided for in regulations regarding the use of alternative materials, designs, or methods of construction.¹⁶
- 3.8 ANAB is an International Accreditation Forum (IAF) Multilateral Recognition Arrangement (MLA) signatory where recognition of certificates, validation and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA with the appropriate scope, shall be approved.¹⁷ Therefore, all ANAB ISO/IEC 17065 duly authenticated reports are approval equivalent.¹⁸
- 3.9 Approval equity is a fundamental commercial and legal principle.¹⁹

4 Applicable Standards for the Listing; Regulations for the Regulatory Evaluation²⁰

4.1 Standards

- 4.1.1 *AISI S904: Standard Test Methods for Determining the Tensile and Shear Strength of Screws*
- 4.1.2 *ANSI/AWC NDS: National Design Specification (NDS) for Wood Construction*
- 4.1.3 *ASTM A153: Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*
- 4.1.4 *ASTM A510: Standard Specification for General Requirements for Wire Rods and Coarse Round Wire, Carbon Steel, and Alloy Steel*
- 4.1.5 *ASTM D1761: Standard Test Methods for Mechanical Fasteners in Wood*
- 4.1.6 *ASTM D2395: Standard Test Methods for Density and Specific Gravity (Relative Density) of Wood and Wood-Based Materials*
- 4.1.7 *ASTM D2915: Standard Practice for Sampling and Data-Analysis for Structural Wood and Wood-Based Products*
- 4.1.8 *ASTM D4442: Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials*
- 4.1.9 *ASTM F1575: Standard Test Method for Determining Bending Yield Moment of Nails*
- 4.1.10 *DOC PS 2: Performance Standard for Wood-based Structural-use Panels*

4.2 Regulations

- 4.2.1 *IBC – 15, 18, 21: International Building Code®*
- 4.2.2 *IRC – 15, 18, 21: International Residential Code®*
- 4.2.3 *IECC – 15, 18, 21: International Energy Conservation Code®*
- 4.2.4 *FBC-B—20, 23: Florida Building Code – Building²¹ (FL 35209)*
- 4.2.5 *FBC-R—20, 23: Florida Building Code – Residential²¹ (FL 35209)*

5 Listed²²

- 5.1 Equipment, materials, products or services included in a List published by a nationally recognized testing laboratory (i.e., CBI), approved agency (i.e., CBI and DrJ), and/or approved source (i.e., DrJ) or other organization concerned with product evaluation (i.e., DrJ) that maintains periodic inspection (i.e., CBI) of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner.



6 Tabulated Properties Generated from Nationally Recognized Standards

6.1 General

- 6.1.1 BTX and YTX General Purpose Screws are used to attach wood framing members in conventional light-frame construction and provide resistance against withdrawal, head pull-through, axial and shear loads. See **Section 9** for installation requirements.
- 6.1.2 BTX and YTX General Purpose Screws are installed without lead holes as prescribed in NDS.
- 6.1.3 Where the application exceeds the limitations set forth herein, design shall be permitted in accordance with accepted engineering procedures, experience and technical judgment.

6.2 Design

- 6.2.1 The design of BTX and YTX General Purpose Screws is governed by the applicable code and the provisions for dowel-type fasteners in NDS.
- 6.2.2 Unless otherwise noted, adjustment of the design stresses for duration of load shall be in accordance with the applicable code.

6.3 BTX and YTX Reference Lateral Design Values (Z)

- 6.3.1 Reference lateral design values (lbf) for shear load parallel and perpendicular to grain for BTX and YTX General Purpose Screws are specified in **Table 3** for Oriented Strand Board (OSB), and **Table 4** and **Table 5** for sawn lumber.

Table 3. Reference Lateral Design Values for SPF Main Member and OSB Side Member Connections¹

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁴ (in)	Lateral Design Value ^{2,3} , Z (lbf)	
						OSB ⁵ (SG = 0.50)	
						Z _⊥	Z
BTX	8 x 1 1/2"	1 1/2	1	23/32	3/4	55	55
	8 x 1 3/4"	1 3/4	1 1/4		1	60	60
	8 x 2"	2	1 1/4		1 1/4	150	160
	8 x 1 1/4"	1 1/4	3/4	7/16	3/4	40	40
	8 x 1 1/2"	1 1/2	1		1	50	50
	8 x 1 3/4"	1 3/4	1 1/4		1 1/4	55	55
	8 x 2"	2	1 1/4		1 1/2	165	135
YTX	8 x 1 1/2"	1 1/2	1	23/32	3/4	55	55
	8 x 1 3/4"	1 3/4	1 1/4		1	60	60
	8 x 2"	2	1 1/4		1 1/4	150	160
	8 x 2 1/2"	2 1/2	1 1/2	7/16	1 1/4	150	160
	8 x 1 1/4"	1 1/4	3/4		3/4	50	50
	8 x 1 1/2"	1 1/2	1		1	50	50
	8 x 1 3/4"	1 3/4	1 1/4		1 1/4	55	55
	8 x 2"	2	1 1/4		1 1/2	165	135
	8 x 2 1/2"	2 1/2	1 1/2		1 1/2	165	135

**Table 3.** Reference Lateral Design Values for SPF Main Member and OSB Side Member Connections¹

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁴ (in)	Lateral Design Value ^{2,3} , Z (lbf)	
						OSB ⁵ (SG = 0.50)	
						Z _⊥	Z
SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N							
1. Reference lateral design values apply to two-member single shear connections where the side member is OSB, the main member is SPF (SG = 0.42), and the fastener is installed in the face of the member and oriented perpendicular to grain. The main member shall have a minimum thickness of 1.5".							
2. Tabulated lateral design values (Z) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.							
3. Z _⊥ = Lateral Design Values Perpendicular to Main Member Grain, Z = Lateral Design Values Parallel to Main Member Grain.							
4. Fastener main member penetration is the length embedded in the main member, including the tip.							
5. OSB shall comply with DOC PS 2. OSB shall have a specific gravity of at least 0.50.							

Table 4. BTX Reference Lateral Design Values for Connections in Sawn Lumber^{1,2,3,4}

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁵ (in)	Lateral Design Value, Z (lbf)			
						SPF (SG = 0.42)		DF (SG = 0.50)	
						Z _⊥	Z	Z _⊥	Z
BTX	9 x 1 1/2"	1 1/2	1	3/4	3/4	65	65	70	70
	9 x 2"	2	1 1/4	3/4	1 1/4	80	80	100	100
	9 x 2 1/2"	2 1/2	1 1/2	3/4	1 1/2	90	90	100	100
	9 x 2 3/4"	2 3/4	1 1/2						
	9 x 3"	3	1 1/2	1 1/2	1 1/2	200	165	275	225
	9 x 3 1/8"	3 1/8	1 1/2						
	10 x 2"	2	1 1/4	3/4	1 1/4	90	90	105	105
	10 x 2 1/2"	2 1/2	1 1/2	1 1/2	1	100	100	115	115
	10 x 3"	3	1 1/2	1 1/2	1 1/2	230	180	290	255
	10 x 3 1/2"	3 1/2	2						
	10 x 4"	4	2						
	10 x 5"	5	2 1/2						
	10 x 6"	6	2 1/2						
	14 x 5"	5	2 1/2	1 1/2	1 1/2	305	320	395	325
	14 x 6"	6	2 1/2						
	14 x 7"	7	2 1/2						
	14 x 8"	8	2 1/2						

Table 4. BTX Reference Lateral Design Values for Connections in Sawn Lumber^{1,2,3,4}

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁵ (in)	Lateral Design Value, Z (lbf)			
						SPF (SG = 0.42)		DF (SG = 0.50)	
						Z _⊥	Z	Z _⊥	Z
SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N									
1. Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity, and the fastener is installed in the face of the member and oriented perpendicular to grain. Where the members are of different specific gravities, use the lower of the two.									
2. For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.									
3. Tabulated lateral design values (Z) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.									
4. Z _⊥ = Lateral Design Values Perpendicular to Grain, Z = Lateral Design Values Parallel to Grain.									
5. Fastener main member penetration is the length embedded in the main member, including the tip.									

Table 5. YTX Reference Lateral Design Values for Connections in Sawn Lumber^{1,2,3,4}

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁵ (in)	Lateral Design Value, Z (lbf)			
						SPF (SG = 0.42)		DF (SG = 0.50)	
						Z _⊥	Z	Z _⊥	Z
YTX	9 x 2"	2	1¼	¾	1¼	80	80	100	100
	9 x 2½"	2½	1½	¾	1½	90	90	100	100
	9 x 2¾"	2¾	1½	¾	1½	90	90	100	100
	9 x 3"	3	1½	1½	1½	200	165	275	225
	9 x 3⅛"	3⅛	1½						
	10 x 2"	2	1¼	¾	1¼	90	90	105	105
	10 x 2½"	2½	1½	1½	1	100	100	115	115
	10 x 3"	3	1½	1½	1½	230	180	290	255
	10 x 3⅛"	3⅛	1½						
	10 x 3½"	3½	2						
	10 x 4"	4	2						
	10 x 5"	5	2½						
	10 x 6"	6	2½						

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

- Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity, and the fastener is installed in the face of the member and oriented perpendicular to grain. Where the members are of different specific gravities, use the lower of the two.
- For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.
- Tabulated lateral design values (Z) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.
- Z_⊥ = Lateral Design Values Perpendicular to Grain, Z_{||} = Lateral Design Values Parallel to Grain.
- Fastener main member penetration is the length embedded in the main member, including the tip.



6.4 BTX and YTX Reference Withdrawal Design Values (W) in Side Grain Applications

6.4.1 Reference withdrawal design values (lbf/in) for BTX and YTX General Purpose Screws in sawn lumber are specified in **Table 6** and **Table 7**, respectively.

Table 6. BTX Reference Withdrawal Design Values¹

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Withdrawal Design Value ^{3,4} , W (lbf/in)	
				Wood Species ² (Specific Gravity)	
				SPF (0.42)	DF-L (0.50)
BTX	8 x 3/4"	3/4	3/4	195	295
	8 x 1"	1	3/4		
	8 x 1 1/4"	1 1/4	3/4		
	8 x 1 1/2"	1 1/2	1		
	8 x 1 3/4"	1 3/4	1 1/4		
	8 x 2"	2	1 1/4		
	9 x 1 1/2"	1 1/2	1	210	315
	9 x 2"	2	1 1/4		
	9 x 2 1/2"	2 1/2	1 1/2		
	9 x 2 3/4"	2 3/4	1 1/2		
	9 x 3"	3	1 1/2		
	9 x 3 1/8"	3 1/8	1 1/2		
	10 x 2"	2	1 1/4	235	315
	10 x 2 1/2"	2 1/2	1 1/2		
	10 x 3"	3	1 1/2		
	10 x 3 1/2"	3 1/2	2		
	10 x 4"	4	2		
	10 x 5"	5	2 1/2		
	10 x 6"	6	2 1/2		
	14 x 5"	5	2 1/2	250	350
	14 x 6"	6	2 1/2		
	14 x 7"	7	2 1/2		
	14 x 8"	8	2 1/2		

SI: 1 in. = 25.4 mm, 1 lb./ft. = 0.0146 kN/m

1. Tabulated withdrawal values (W) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.
2. For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.
3. The full design withdrawal value is equal to the reference withdrawal value multiplied by the length of the threaded portion of the fastener embedded in the main member.
4. Fastener penetration is the threaded length embedded in the main member, including the tip.



Table 7. YTX Reference Withdrawal Design Values¹

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Withdrawal Design Value ^{3,4} , W (lbf/in)	
				Wood Species ² (Specific Gravity)	
				SPF (0.42)	DF-L (0.50)
YTX	8 x 1"	1	3/4	195	295
	8 x 1 1/4"	1 1/4	3/4		
	8 x 1 1/2"	1 1/2	1		
	8 x 1 3/4"	1 3/4	1 1/4		
	8 x 2"	2	1 1/4		
	8 x 2 1/2"	2 1/2	1 1/2		
	9 x 2"	2	1 1/4	210	315
	9 x 2 1/2"	2 1/2	1 1/2		
	9 x 2 3/4"	2 3/4	1 1/2		
	9 x 3"	3	1 1/2		
	9 x 3 1/8"	3 1/8	1 1/2		
	10 x 1 1/2"	1 1/2	1	235	315
	10 x 2"	2	1 1/4		
	10 x 2 1/2"	2 1/2	1 1/2		
	10 x 3"	3	1 1/2		
	10 x 3 1/8"	3 1/8	1 1/2		
	10 x 3 1/2"	3 1/2	2		
	10 x 4"	4	2		
	10 x 5"	5	2 1/2		
	10 x 6"	6	2 1/2		

SI: 1 in. = 25.4 mm, 1 lb./ft. = 0.0146 kN/m

1. Tabulated withdrawal values (W) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.
2. For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.
3. The full design withdrawal value is equal to the reference withdrawal value multiplied by the length of the threaded portion of the fastener embedded in the main member.
4. Fastener penetration is the threaded length embedded in the main member, including the tip.



6.5 BTX and YTX Reference Head Pull-Through Design Values (P)

- 6.5.1 Reference design values for head pull-through (lbf) for BTX and YTX General Purpose Screws are specified in **Table 8** and **Table 9** for OSB, and sawn lumber specifications are shown in **Table 10** and **Table 11**.

Table 8. BTX Reference Head Pull-Through Design Values in OSB¹

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Head Pull-Through Design Value, P (lbf)	
				OSB ² Thickness (SG = 0.50)	
				23/32"	7/16"
BTX	8 x 3/4"	3/4	3/4	275	115
	8 x 1"	1	3/4		
	8 x 1 1/4"	1 1/4	3/4		
	8 x 1 1/2"	1 1/2	1		
	8 x 1 3/4"	1 3/4	1 1/4		
	8 x 2"	2	1 1/4		
	9 x 1 1/2"	1 1/2	1	275	115
	9 x 2"	2	1 1/4		
	9 x 2 1/2"	2 1/2	1 1/2		
	9 x 2 3/4"	2 3/4	1 1/2		
	9 x 3"	3	1 1/2		
	9 x 3 1/8"	3 1/8	1 1/2		
	10 x 2"	2	1 1/4	275	115
	10 x 2 1/2"	2 1/2	1 1/2		
	10 x 3"	3	1 1/2		
	10 x 3 1/2"	3 1/2	2		
	10 x 4"	4	2		
	10 x 5"	5	2 1/2		
	10 x 6"	6	2 1/2		
	14 x 5"	5	2 1/2	275	115
	14 x 6"	6	2 1/2		
	14 x 7"	7	2 1/2		
	14 x 8"	8	2 1/2		

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

- Tabulated pull-through values (P) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.
- OSB shall comply with DOC PS 2. OSB and have a specific gravity of at least 0.50. Listed thicknesses are minimums.



Table 9. YTX Reference Head Pull-Through Design Values in OSB¹

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Head Pull-Through Design Value, P (lbf)	
				OSB ² Thickness (SG = 0.50)	
				23/32"	7/16"
YTX	8 x 1"	1	3/4	275	115
	8 x 1 1/4"	1 1/4	3/4		
	8 x 1 1/2"	1 1/2	1		
	8 x 1 3/4"	1 3/4	1 1/4		
	8 x 2"	2	1 1/4		
	8 x 2 1/2"	2 1/2	1 1/2		
	9 x 2"	2	1 1/4	275	115
	9 x 2 1/2"	2 1/2	1 1/2		
	9 x 2 3/4"	2 3/4	1 1/2		
	9 x 3"	3	1 1/2		
	9 x 3 1/8"	3 1/8	1 1/2		
	10 x 1 1/2"	1 1/2	1	275	115
	10 x 2"	2	1 1/4		
	10 x 2 1/2"	2 1/2	1 1/2		
	10 x 3"	3	1 1/2		
	10 x 3 1/8"	3 1/8	1 1/2		
	10 x 3 1/2"	3 1/2	2		
	10 x 4"	4	2		
	10 x 5"	5	2 1/2		
	10 x 6"	6	2 1/2		

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

1. Tabulated pull-through values (P) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.
2. OSB shall comply with DOC PS 2. OSB shall have a specific gravity of at least 0.50. Listed thicknesses are minimums.



Table 10. BTX Reference Head Pull-Through Design Values in Sawn Lumber¹

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Head Pull-Through Design Value ³ , P (lbf)	
				Wood Species ² (Specific Gravity)	
				SPF (0.42)	DF-L (0.50)
BTX	9 x 1½"	1½	1	215	335
	9 x 2"	2	1¼		
	9 x 2½"	2½	1½		
	9 x 2¾"	2¾	1½		
	9 x 3"	3	1½		
	9 x 3⅛"	3⅛	1½		
	10 x 2"	2	1¼	280	380
	10 x 2½"	2½	1½		
	10 x 3"	3	1½		
	10 x 3½"	3½	2		
	10 x 4"	4	2		
	10 x 5"	5	2½		
	10 x 6"	6	2½		
	14 x 5"	5	2½	490	605
	14 x 6"	6	2½		
	14 x 7"	7	2½		
	14 x 8"	8	2½		

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

1. Tabulated pull-through values (P) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.
2. For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42. For wood species with a specific gravity greater than 0.50, use the tabulated values for specific gravity of 0.50.
3. Pull-through design values apply to connections having a minimum wood side member thickness of at least 1.5".

Table 11. YTX Reference Head Pull-Through Design Values in Sawn Lumber¹

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Head Pull-Through Design Value ³ , P (lbf)	
				Wood Species ² (Specific Gravity)	
				SPF (0.42)	DF-L (0.50)
YTX	9 x 2"	2	1¼	215	335
	9 x 2½"	2½	1½		
	9 x 2¾"	2¾	1½		
	9 x 3"	3	1½		
	9 x 3⅛"	3⅛	1½		
	10 x 1½"	1½	1	280	380
	10 x 2"	2	1¼		
	10 x 2½"	2½	1½		
	10 x 3"	3	1½		
	10 x 3⅛"	3⅛	1½		
	10 x 3½"	3½	2		
	10 x 4"	4	2		
	10 x 5"	5	2½		
	10 x 6"	6	2½		
SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N					
1. Tabulated pull-through values (P) shall be adjusted by all applicable adjustment factors per NDS Table 11.3.1.					
2. For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42. For wood species with a specific gravity greater than 0.50, use the tabulated values for specific gravity of 0.50.					
3. Pull-through design values apply to connections having a minimum wood side member thickness of at least 1.5".					

- 6.6 Where the application falls outside of the performance evaluation, conditions of use and/or installation requirements set forth herein, alternative techniques shall be permitted in accordance with accepted engineering practice and experience. This includes but is not limited to the following areas of engineering: mechanics or materials, structural, building science and fire science.

7 Certified Performance²³

- 7.1 All construction methods shall conform to accepted engineering practices to ensure durable, livable, and safe construction and shall demonstrate acceptable workmanship reflecting journeyman quality of work of the various trades.²⁴
- 7.2 The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.²⁵



8 Regulatory Evaluation and Accepted Engineering Practice

- 8.1 BTX and YTX General Purpose Screws comply with the following legislatively adopted regulations and/or accepted engineering practice for the following reasons:
- 8.1.1 Bending yield in accordance with ASTM F1575
 - 8.1.2 Tensile strength in accordance with AISI S904
 - 8.1.3 Shear strength in accordance with AISI S904
 - 8.1.4 Lateral shear in accordance with ASTM D1761
 - 8.1.5 Withdrawal strength in accordance with ASTM D1761
 - 8.1.6 Head pull-through in accordance with ASTM D1761
- 8.2 BTX and YTX General Purpose Screws were tested and evaluated for corrosion resistance of fasteners meeting or exceeding the protection afforded hot-dipped galvanized fasteners in accordance with ASTM A153, Class D.
- 8.2.1 Corrosion resistance of BTX and YTX General Purpose Screws are outside the scope of this report.
- 8.3 Use of BTX and YTX General Purpose Screws in locations exposed to saltwater or saltwater spray is outside the scope of this report.
- 8.4 Any building code, regulation and/or accepted engineering evaluations (i.e., research reports, duly authenticated reports, etc.) that are conducted for this Listing were performed by DrJ Engineering, LLC (DrJ), an ISO/IEC 17065 accredited certification body and a professional engineering company operated by RDP/approved sources. DrJ is qualified²⁶ to practice product and regulatory compliance services within its scope of accreditation and engineering expertise, respectively.
- 8.5 Engineering evaluations are conducted with DrJ's ANAB accredited ICS code scope of expertise, which are also its areas of professional engineering competence.
- 8.6 Any regulation specific issues not addressed in this section are outside the scope of this report.

9 Installation

- 9.1 Installation shall comply with the approved construction documents, the manufacturer installation instructions, this report and the applicable building code.
- 9.2 In the event of a conflict between the manufacturer installation instructions and this report, the more restrictive shall govern.
- 9.3 *Installation Procedure*
- 9.3.1 Minimum penetration is 1", unless otherwise stated in this report. Install fasteners with head flush to the surface of the wood member.
 - 9.3.2 Lead holes are not required.
 - 9.3.3 Screws shall be installed with the appropriate rotating powered driver.



- 9.3.4 Minimum requirements for screw spacing, edge distance and end distance shall be in accordance with **Table 12**.

Table 12. BTX and YTX Screw Spacing, Edge Distance and End Distance Requirements^{1,2}

Connection Geometry	Minimum Spacing/Distance (in)			
	BTX8 and YTX8	BTX9 and YTX9	BTX10 and YTX10	BTX14
Edge Distance – Load in any direction	$\frac{3}{8}$	$\frac{3}{8}$	$\frac{1}{2}$	$\frac{1}{2}$
End Distance – Load parallel to grain, towards end	$1\frac{7}{8}$	$2\frac{1}{4}$	$2\frac{3}{8}$	$2\frac{3}{4}$
End Distance – Load parallel to grain, away from end	$1\frac{1}{4}$	$1\frac{3}{8}$	$1\frac{5}{8}$	$1\frac{3}{4}$
End Distance – Load perpendicular to grain	$1\frac{1}{4}$	$1\frac{3}{8}$	$1\frac{5}{8}$	$1\frac{3}{4}$
Spacing between Fasteners in a Row – Parallel to grain	$1\frac{7}{8}$	$2\frac{1}{4}$	$2\frac{3}{8}$	$2\frac{3}{4}$
Spacing between Fasteners in a Row – Perpendicular to grain	$1\frac{1}{4}$	$1\frac{3}{8}$	$1\frac{5}{8}$	$1\frac{3}{4}$
Spacing between Rows of Fasteners – In-line	$\frac{3}{4}$	$\frac{3}{4}$	$\frac{7}{8}$	$\frac{7}{8}$
Spacing between Rows of Fasteners – Staggered	$\frac{3}{8}$	$\frac{3}{8}$	$\frac{1}{2}$	$\frac{3}{8}$
SI: 1 in. = 25.4 mm 1. Edge distances, end distances and spacing of fasteners shall be sufficient to prevent splitting of the wood or as shown in this table, whichever is the more restrictive. 2. Values for “Spacing between Rows of Fasteners-Staggered” apply where the screws in adjacent rows are offset by one-half of the “Spacing between Fasteners in a Row”.				

10 Substantiating Data

- 10.1 Testing has been performed under the supervision of a professional engineer and/or under the requirements of ISO/IEC 17025 as follows:
- 10.1.1 Bending yield testing in accordance with ASTM F1575
 - 10.1.2 Tensile strength testing in accordance with AISI S904
 - 10.1.3 Shear strength testing in accordance with AISI S904
 - 10.1.4 Lateral strength testing in accordance with ASTM D1761
 - 10.1.5 Withdrawal testing in accordance with ASTM D1761
 - 10.1.6 Head pull-through testing in accordance with ASTM D1037
 - 10.1.7 Corrosion resistance testing in accordance with ASTM B117 and ASTM G85
- 10.2 Information contained herein may include the result of testing and/or data analysis by sources that are approved agencies, approved sources and/or RDPs. Accuracy of external test data and resulting analysis is relied upon.
- 10.3 Where applicable, testing and/or engineering analysis are based upon provisions that have been codified into law through state or local adoption of regulations and standards. The developers of these regulations and standards are responsible for the reliability of published content. DrJ's engineering practice may use a regulation-adopted provision as the control. A regulation-endorsed control versus a simulation of the conditions of application to occur establishes a new material as being equivalent to the regulatory provision in terms of quality, strength, effectiveness, fire resistance, durability and safety.



- 10.4 The accuracy of the provisions provided herein may be reliant upon the published properties of raw materials, which are defined by the grade mark, grade stamp, mill certificate or duly authenticated reports from approved agencies and/or approved sources provided by the supplier. These are presumed to be minimum properties and relied upon to be accurate. The reliability of DrJ's engineering practice, as contained in this duly authenticated report, may be dependent upon published design properties by others.
- 10.5 Testing and engineering analysis: The strength, rigidity, and/or general performance of component parts and/or the integrated structure are determined by suitable tests that simulate the actual conditions of application that occur and/or by accepted engineering practice and experience.²⁷
- 10.6 Where additional condition of use and/or regulatory compliance information is required, please search for BTX and YTX General Purpose Screws on the DrJ Certification website.

11 Findings

- 11.1 As outlined in **Section 6**, BTX and YTX General Purpose Screws have performance characteristics that were tested and/or meet applicable regulations and are suitable for use pursuant to its specified purpose.
- 11.2 When used and installed in accordance with this duly authenticated report and the manufacturer installation instructions, BTX and YTX General Purpose Screws shall be approved for the following applications:
- 11.2.1 Use as fasteners in accordance with the listed design values in **Table 3** through **Table 11**, and with the applicable codes.
- 11.3 Unless exempt by state statute, when BTX and YTX General Purpose Screws are to be used as a structural and/or building envelope component in the design of a specific building, the design shall be performed by an RDP.
- 11.4 Any application specific issues not addressed herein can be engineered by an RDP. Assistance with engineering is available from Big Timber.
- 11.5 IBC Section 104.11 (IRC Section R104.11 and IFC Section 104.10²⁸ are similar) in pertinent part states:
- 104.11 Alternative materials, design and methods of construction and equipment.** The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code. Where the alternative material, design or method of construction is not approved, the building official shall respond in writing, stating the reasons the alternative was not approved.
- 11.6 **Approved:**²⁹ Building regulations require that the building official shall accept duly authenticated reports.³⁰
- 11.6.1 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited.
- 11.6.2 An approved source is “approved” when an RDP is properly licensed to transact engineering commerce.
- 11.6.3 Federal law, Title 18 US Code Section 242, requires that where the alternative product, material, service, design, assembly and/or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved. Denial without written reason deprives a protected right to free and fair competition in the marketplace.
- 11.7 DrJ is a licensed engineering company, employs licensed RDPs and is an ANAB-Accredited Product Certification Body – Accreditation #1131.
- 11.8 Through the IAF Multilateral Agreements (MLA), this duly authenticated report can be used to obtain product approval in any jurisdiction or country because all ANAB ISO/IEC 17065 duly authenticated reports are equivalent.³¹



12 Conditions of Use

- 12.1 Material properties shall not fall outside the boundaries defined in **Section 6**.
- 12.2 As defined in **Section 6**, where material and/or engineering mechanics properties are created for load resisting design purposes, the resistance to the applied load shall not exceed the ability of the defined properties to resist those loads using the principles of accepted engineering practice.
- 12.3 As listed herein, BTX and YTX General Purpose Screws shall not be used:
 - 12.3.1 In sawn lumber with moisture content greater than nineteen percent (19%)
 - 12.3.2 In OSB with moisture content greater than sixteen percent (16%).
- 12.4 When required by adopted legislation and enforced by the building official, also known as the authority having jurisdiction (AHJ) in which the project is to be constructed:
 - 12.4.1 Any calculations incorporated into the construction documents shall conform to accepted engineering practice and, when prepared by an approved source, shall be approved when signed and sealed.
 - 12.4.2 This report and the installation instructions shall be submitted at the time of permit application.
 - 12.4.3 These innovative products have an internal quality control program and a third-party quality assurance program.
 - 12.4.4 At a minimum, these innovative products shall be installed per **Section 9** of this report.
 - 12.4.5 The review of this report by the AHJ shall comply with IBC Section 104 and IBC Section 105.4.
 - 12.4.6 These innovative products have an internal quality control program and a third party quality assurance program in accordance with IBC Section 104.4, IBC Section 110.4, IBC Section 1703, IRC Section R104.4 and IRC Section R109.2.
 - 12.4.7 The application of these innovative products in the context of this report is dependent upon the accuracy of the construction documents, implementation of installation instructions, inspection as required by IBC Section 110.3, IRC Section R109.2 and any other regulatory requirements that may apply.
- 12.5 The approval of this report by the AHJ shall comply with IBC Section 1707.1, where legislation states in part, *"the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new material or assemblies as provided for in Section 104.11,"* all of IBC Section 104, and IBC Section 105.4.
- 12.6 Design loads shall be determined in accordance with the regulations adopted by the jurisdiction in which the project is to be constructed and/or by the building designer (i.e., owner or RDP).
- 12.7 The actual design, suitability, and use of this report for any particular building, is the responsibility of the owner or the authorized agent of the owner.



13 Identification

- 13.1 The innovative products listed in **Section 1.1** are identified by a label on the board or packaging material bearing the manufacturer name, product name, this report number and other information to confirm code compliance.
- 13.2 Additional technical information can be found at www.bigtimberfasteners.com.

14 Review Schedule

- 14.1 This report is subject to periodic review and revision. For the latest version, visit drjcertification.org.
- 14.2 For information on the status of this report, please contact [DrJ Certification](#).

15 Approved for Use Pursuant to U.S. and International Legislation Defined in Appendix A

- 15.1 BTX and YTX General Purpose Screws are included in this report published by an approved agency that is concerned with evaluation of products or services, maintains periodic inspection of the production of listed materials or periodic evaluation of services. This report states either that the material, product or service meets recognized standards or has been tested and found suitable for a specified purpose. This report meets the legislative intent and definition of being acceptable to the AHJ.



Appendix A

1 Legislation that Authorizes AHJ Approval

- 1.1 **Fair Competition:** State legislatures have adopted Federal regulations for the examination and approval of building code referenced and alternative products, materials, designs, services, assemblies and/or methods of construction that:
 - 1.1.1 Advance innovation
 - 1.1.2 Promote competition so all businesses have the opportunity to compete on price and quality in an open market on a level playing field unhampered by anticompetitive constraints
 - 1.1.3 Benefit consumers through lower prices, better quality, and greater choice
- 1.2 **Adopted Legislation:** The following local, state and federal regulations affirmatively authorize these innovative products to be approved by AHJs, delegates of building departments and/or delegates of an agency of the federal government:
 - 1.2.1 Interstate commerce is governed by the Federal Department of Justice to encourage the use of innovative products, materials, designs, services, assemblies, and/or methods of construction. The goal is to “*protect economic freedom and opportunity by promoting free and fair competition in the marketplace.*”
 - 1.2.2 Title 18 US Code Section 242 affirms and regulates the right of individuals and businesses to freely and fairly have new products, materials, designs, services, assemblies and/or methods of construction approved for use in commerce. Disapproval of alternatives shall be based upon non-conformance with respect to specific provisions of adopted legislation and shall be provided in writing stating the reasons why the alternative was not approved, with reference to the specific legislation violated.
 - 1.2.3 The federal government and each state have a public records act. In addition, each state also has legislation that mimics the federal Defend Trade Secrets Act 2016 (DTSA),³² where providing test reports, engineering analysis and/or other related IP/TS is subject to prison of not more than ten years³³ and/or a \$5,000,000 fine or 3 times the value of³⁴ the Intellectual Property (IP) and Trade Secrets (TS).
 - 1.2.3.1 Compliance with public records and trade secret legislation requires approval through the use of Listings, certified reports, Technical Evaluation Reports, duly authenticated reports and/or research reports prepared by approved agencies and/or approved sources.
 - 1.2.4 For new materials³⁵ that are not specifically provided for in any regulation, the design strengths and permissible stresses shall be established by tests, where suitable load tests simulate the actual loads and conditions of application that occur.
 - 1.2.5 The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design using accepted engineering practice.³⁶
 - 1.2.6 The commerce of approved sources (i.e., registered PEs) is regulated by professional engineering legislation. Professional engineering commerce shall always be approved by AHJs, except where there is evidence provided in writing, that specific legislation have been violated by an individual registered PE.
 - 1.2.7 The AHJ shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in IBC Section 104.11.³⁷



- 1.3 **Approved³⁸ by Los Angeles:** The Los Angeles Municipal Code (LAMC) states in pertinent part that the provisions of LAMC are not intended to prevent the use of any material, device or method of construction not specifically prescribed by LAMC. The Department shall use Part III, Recognized Standards in addition to Part II, Uniform Building Code Standards of Division 35, Article 1, Chapter IX of the LAMC in evaluation of products for approval where such standard exists for the product or the material and may use other approved standards that apply. Whenever tests or certificates of any material or fabricated assembly are required by Chapter IX of the LAMC, such tests or certification shall be made by a testing agency approved by the Superintendent of Building to conduct such tests or provide such certifications. The testing agency shall publish the scope and limitation(s) of the listed material or fabricated assembly.³⁹ The Superintendent of Building Approved Testing Agency Roster is provided by the Los Angeles Department of Building and Safety (LADBS). The Center for Building Innovation (CBI) Certificate of Approval License is TA24945. Tests and certifications found in a DrJ Listing are LAMC approved. In addition, the Superintendent of Building shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in the California Building Code (CBC) Section 1707.1.⁴⁰
- 1.4 **Approved by Chicago:** The Municipal Code of Chicago (MCC) states in pertinent part that an Approved Agency is a Nationally Recognized Testing Laboratory (NRTL) acting within its recognized scope and/or a certification body accredited by the American National Standards Institute (ANSI) acting within its accredited scope. Construction materials and test procedures shall conform to the applicable standards listed in the MCC. Sufficient technical data shall be submitted to the building official to substantiate the proposed use of any product, material, service, design, assembly and/or method of construction not specifically provided for in the MCC. This technical data shall consist of research reports from approved sources (i.e., MCC defined Approved Agencies).
- 1.5 **Approved by New York City:** The 2022 NYC Building Code (NYCBC) states in part that an approved agency shall be deemed⁴¹ an approved testing agency via ISO/IEC 17025 accreditation, an approved inspection agency via ISO/IEC 17020 accreditation, and an approved product evaluation agency via ISO/IEC 17065 accreditation. Accrediting agencies, other than federal agencies, must be members of an internationally recognized cooperation of laboratory and inspection accreditation bodies subject to a mutual recognition agreement⁴² (i.e., ANAB, International Accreditation Forum also known as IAF, etc.).
- 1.6 **Approved by Florida:** Statewide approval of products, methods or systems of construction shall be approved, without further evaluation by:
- 1.6.1 A certification mark or listing of an approved certification agency,
 - 1.6.2 A test report from an approved testing laboratory,
 - 1.6.3 A product evaluation report based upon testing or comparative or rational analysis, or a combination thereof, from an approved product evaluation entity, or
 - 1.6.4 A product evaluation report based upon testing, comparative or rational analysis, or a combination thereof, developed, signed and sealed by a professional engineer or architect, licensed in Florida.
 - 1.6.5 For local product approval, products or systems of construction shall demonstrate compliance with the structural wind load requirements of the Florida Building Code (FBC) through one of the following methods:
 - 1.6.5.1 A certification mark, listing or label from a commission-approved certification agency indicating that the product complies with the code,
 - 1.6.5.2 A test report from a commission-approved testing laboratory indicating that the product tested complies with the code,
 - 1.6.5.3 A product-evaluation report based upon testing, comparative or rational analysis, or a combination thereof, from a commission-approved product evaluation entity which indicates that the product evaluated complies with the code,



- 1.6.5.4 A product-evaluation report or certification based upon testing or comparative or rational analysis, or a combination thereof, developed and signed and sealed by a Florida professional engineer or Florida registered architect, which indicates that the product complies with the code, or
- 1.6.5.5 A statewide product approval issued by the Florida Building Commission.
- 1.6.6 The [Florida Department of Business and Professional Regulation \(DBPR\)](#) website provides a listing of companies certified as a [Product Evaluation Agency](#) (i.e., EVLMiami 13692), a [Product Certification Agency](#) (i.e., CER10642), and as a [Florida Registered Engineer](#) (i.e., ANE13741).
- 1.7 **Approved by Miami-Dade County (i.e., Notice of Acceptance [NOA]):** A Florida statewide approval is an NOA. An NOA is a Florida local product approval. By Florida law, Miami-Dade County shall accept the statewide and local Florida Product Approval as provided for in Florida legislation [553.842](#) and [553.8425](#).
- 1.8 **Approved by New Jersey:** Pursuant to the 2018 Building Code of New Jersey in [IBC Section 1707.1 General](#),⁴³ it states: “*In the absence of approved rules or other approved standards, the building official shall accept duly authenticated reports from [approved agencies](#) in respect to the quality and manner of use of new materials or assemblies as provided for in the administrative provisions of the Uniform Construction Code (N.J.A.C. 5:23)*”.⁴⁴ Furthermore N.J.A.C 5:23-3.7 states: “*Municipal approvals of alternative materials, equipment, or methods of construction.*”
 - 1.8.1 **Approvals:** Alternative materials, equipment or methods of construction shall be approved by the appropriate subcode official provided the proposed design is satisfactory and that the materials, equipment or methods of construction are suitable for the intended use and are at least the equivalent in quality, strength, effectiveness, fire resistance, durability and safety of those conforming with the requirements of the regulations.
 - 1.8.1.1 A field evaluation label and report or letter issued by a nationally recognized testing laboratory verifying that the specific material, equipment or method of construction meets the identified standards or has been tested and found to be suitable for the intended use, shall be accepted by the appropriate subcode official as meeting the requirements of the above.
 - 1.8.1.2 Reports of engineering findings issued by nationally recognized evaluation service programs such as but not limited to, the Building Officials and Code Administrators (BOCA), the International Conference of Building Officials (ICBO), the Southern Building Code Congress International (SBCCI), the International Code Council (ICC), and the National Evaluation Service, Inc., shall be accepted by the appropriate subcode official as meeting the requirements of the above.
 - 1.8.2 The [New Jersey Department of Community Affairs](#) has confirmed that technical evaluation reports, from any accredited entity listed by [ANAB](#), meets the requirements of item the previous paragraph, given that the listed entities are no longer in existence and/or do not provide “*reports of engineering findings.*”
- 1.9 **Approved by the Code of Federal Regulations Manufactured Home Construction and Safety Standards:** Pursuant to Title 24, Subtitle B, Chapter XX, [Part 3282.14](#)⁴⁵ and [Part 3280](#),⁴⁶ the Department encourages innovation and the use of new technology in manufactured homes. The design and construction of a manufactured home shall conform to the provisions of Part 3282 and Part 3280 where key approval provisions in mandatory language follow:
 - 1.9.1 “*All construction methods shall be in conformance with accepted engineering practices.*”
 - 1.9.2 “*The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.*”
 - 1.9.3 “*The design stresses of all materials shall conform to accepted engineering practice.*”



- 1.10 **Approval by US, Local and State Jurisdictions in General:** In all other local and state jurisdictions, the adopted building code legislation states in pertinent part that:
- 1.10.1 For new materials that are not specifically provided for in this code, the design strengths and permissible stresses shall be established by tests.⁴⁷
 - 1.10.2 For innovative alternatives and/or methods of construction, the building official shall accept duly authenticated reports from approved agencies with respect to the quality and manner of use of new materials or assemblies.⁴⁸
 - 1.10.2.1 An approved agency is “*approved*” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is in the ANAB directory.
 - 1.10.2.2 An approved source is “*approved*” when an RDP is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.⁴⁹
 - 1.10.3 The design strengths and permissible stresses of any structural material...shall conform to the specifications and methods of design of accepted engineering practice performed by an approved source.⁵⁰
- 1.11 **Approval by International Jurisdictions:** The USMCA and GATT agreements provide for approval of innovative materials, designs, services, and/or methods of construction through the Agreement on Technical Barriers to Trade and the IAF Multilateral Recognition Arrangement (MLA), where these agreements:
- 1.11.1 State that conformity assessment procedures (i.e., ISO/IEC 17020, 17025, 17065, etc.) are prepared, adopted, and applied so as to grant access for suppliers of like products originating in the territories of other Members under conditions no less favourable than those accorded to suppliers of like products of national origin or originating in any other country, in a comparable situation.
 - 1.11.2 **Approved:** The purpose of the MLA is to ensure mutual recognition of accredited certification and validation/verification statements between signatories to the MLA and subsequently, acceptance of accredited certification and validation/verification statements in many markets based on one accreditation for the timely approval of innovative materials, designs, services, and/or methods of construction.
 - 1.11.3 ANAB is an IAF-MLA signatory where recognition of certificates, validation, and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA, with the appropriate scope, shall be approved.⁵¹
 - 1.11.4 Therefore, all ANAB ISO/IEC 17065 duly authenticated reports are approval equivalent.⁵²
- 1.12 Approval equity is a fundamental commercial and legal principle.⁵³



Issue Date: December 22, 2020
Subject to Renewal: October 1, 2025

FBC Supplement to Report Number 1911-01

REPORT HOLDER: Big Timber

1 Evaluation Subject

- 1.1 BTX and YTX General Purpose Screws

2 Purpose and Scope

- 2.1 Purpose
 - 2.1.1 The purpose of this Report Supplement is to show BTX and YTX General Purpose Screws, recognized in Report Number 1911-01, have also been evaluated for compliance with the codes listed below as adopted by the Florida Building Commission.
- 2.2 *Applicable Code Editions*
 - 2.2.1 *FBC-B—20, 23: Florida Building Code – Building (FL35209)*
 - 2.2.2 *FBC-R—20, 23: Florida Building Code – Residential (FL35209)*

3 Conclusions

- 3.1 BTX and YTX General Purpose Screws, described in Report Number 1911-01, comply with the FBC-B and FBC-R and are subject to the conditions of use described in this supplement.
- 3.2 Where there are variations between the IBC and IRC and the FBC-B and FBC-R applicable to this report, they are listed here:
 - 3.2.1 FBC-B Section 104.4 and Section 110.4 are reserved.
 - 3.2.2 FBC-R Section R104 and Section R109 are reserved.
 - 3.2.3 FBC-B Section 2304.10 replaces IBC Section 2304.10.
 - 3.2.4 FBC-B Section 2304.10.5 replaces IBC Section 2304.10.6.

4 Conditions of Use

- 4.1 BTX and YTX General Purpose Screws, described in Report Number 1911-01, must comply with all of the following conditions:
 - 4.1.1 All applicable sections in Report Number 1911-01.
 - 4.1.2 The design, installation, and inspections are in accordance with additional requirements of FBC-B Chapter 16 and Chapter 17, as applicable.



For more information, visit [drcertification.org](https://www.drcertification.org) or call us at 608-310-6748.

2018 IBC Section 2304.10.5
<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1702>

Alternative Materials, Design and Methods of Construction and Equipment: The provisions of any regulation code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by a regulation. Please review <https://www.justice.gov/atr/mission> and <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104.11>

<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706>:~:text=the%20design%20strengths%20and%20permissible%20stresses%20shall%20be%20established%20by%20tests%20as

The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design of accepted engineering practice.
<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706>:~:text=shall%20conform%20to%20the%20specifications%20and%20methods%20of%20design%20of%20accepted%20engineering%20practice

<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>:~:text=the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies

<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1703.4.2>

https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved_agency

https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved_source

<https://www.law.cornell.edu/uscode/text/18/1832> (b) Any organization that commits any offense described in subsection (a) shall be fined not more than the greater of \$5,000,000 or 3 times the value of the stolen trade secret to the organization, including expenses for research and design and other costs of reproducing the trade secret that the organization has thereby avoided. The federal government and each state have a [public records act](#). To follow DTSA and comply state public records and trade secret legislation requires approval through ANAB ISO/IEC 17065 accredited certification bodies or [approved sources](#). For more information, please review this website: [Intellectual Property and Trade Secrets](#).

<https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>

<https://www.cbiteest.com/accreditation/>

<https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104>:~:text=to%20enforce%20the%20provisions%20of%20this%20code

<https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104.11>:~:text=Where%20the%20alternative%20material%2C%20design%20or%20method%20of%20construction%20is%20not%20approved%2C%20the%20building%20official%20shall%20respond%20in%20writing%2C%20stating%20the%20reasons%20why%20the%20alternative%20was%20not%20approved AND

<https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#105.3.1>:~:text=If%20the%20application%20or%20the%20construction%20documents%20do%20not%20conform%20to%20the%20requirements%20of%20pertinent%20laws%2C%20the%20building%20official%20shall%20reject%20such%20application%20in%20writing%2C%20stating%20the%20reasons%20therefore

<https://up.codes/viewer/colorado/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>:~:text=the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies%20in%20respect%20to%20the%20quality%20and%20manner%20of%20use%20of%20new%20materials%20or%20assemblies%20as%20provided%20for%20in%20Section%20104.11

<https://iaf.nu/en/about-iaf-mia/#>:~:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope

True for all ANAB accredited product evaluation agencies and all International Trade Agreements.

<https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>

Unless otherwise noted, all references in this Listing are from the 2021 version of the codes and the standards referenced therein. This material, product, design, service and/or method of construction also complies with the 2000-2021 versions of the referenced codes and the standards referenced therein.

All references to the FBC-B and FBC-R are the same as the 2021 IBC and 2021 IRC unless otherwise noted in the Florida Supplement at the end of this report.

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2>(Listed%20or%20certified); <https://up.codes/viewer/colorado/ibc-2021/chapter/2/definitions#listed> AND <https://up.codes/viewer/colorado/ibc-2021/chapter/2/definitions#labeled>

<https://up.codes/viewer/colorado/ibc-2021/chapter/17/special-inspections-and-tests#1703.4>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#>:~:text=All%20construction%20methods%20shall%20be%20in%20conformance%20with%20accepted%20engineering%20practices%20to%20insure%20durable%2C%20livable%2C%20and%20safe%20housing%20and%20shall%20demonstrate%20acceptable%20workmanship%20reflecting%20journeyman%20quality%20of%20work%20of%20the%20various%20trades

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#>:~:text=The%20strength%20and%20rigidity%20of%20the%20component%20parts%20and/or%20the%20integrated%20structure%20shall%20be%20determined%20by%20engineering%20analysis%20or%20by%20suitable%20load%20tests%20to%20simulate%20the%20actual%20loads%20and%20conditions%20of%20application%20that%20occur

Qualification is performed by a legislatively defined [Accreditation Body](#). ANSI National Accreditation Board (ANAB) is the largest independent accreditation body in North America and provides services in more than 75 countries. [DrJ](#) is an ANAB accredited product certification body.

See Code of Federal Regulations (CFR) [Title 24 Subtitle B Chapter XX Part 3280](#) for definition.

2018 IFC Section 104.9

Approved is an adjective that modifies the noun after it. For example, Approved Agency means that the Agency is accepted officially as being suitable in a particular situation. This example conforms to IBC/IRC/IFC [Section 201.4](#) where the building code authorizes sentences to have an ordinarily accepted meaning such as the context implies.

<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>



Multilateral approval is true for all ANAB accredited product evaluation agencies and all International Trade Agreements.

<http://www.drjengineering.org/AppendixC> AND <https://www.drjcertification.org/comell-2016-protection-trade-secrets>

<https://www.law.cornell.edu/uscode/text/18/1832#:~:text=imprisoned%20not%20more%20than%2010%20years>

<https://www.law.cornell.edu/uscode/text/18/1832#:~:text=Any%20organization%20that,has%20thereby%20avoided>

<https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706.2>

IBC 2021, Section 1706.1 Conformance to Standards

IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General

See **Section 11** for the distilled building code definition of **Approved**

Los Angeles Municipal Code, SEC. 98.0503. TESTING AGENCIES

<https://up.codes/viewer/california/ca-building-code-2022/chapter/17/special-inspections-and-tests#1707.1>

New York City, The Rules of the City of New York, § 101-07 Approved Agencies

New York City, The Rules of the City of New York, § 101-07 Approved Agencies

<https://up.codes/viewer/new-jersey/ibc-2018/chapter/17/special-inspections-and-tests#1707.1>

<https://www.nj.gov/dca/divisions/codes/codreg/ucc.html>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3282/subpart-A/section-3282.14>

<https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>

IBC 2021, Section 1706 Design Strengths of Materials, 1706.2 New Materials. Adopted law pursuant to IBC model code language 1706.2.

IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General. Adopted law pursuant to IBC model code language 1707.1.

<https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>

IBC 2021, Section 1706 Design Strengths of Materials, Section 1706.1 Conformance to Standards Adopted law pursuant to IBC model code language 1706.1.

[https://iaf.nu/en/about-iaf-](https://iaf.nu/en/about-iaf-mla/#:~:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope)

[mla/#:~:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope](https://iaf.nu/en/about-iaf-mla/#:~:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope)

True for all ANAB accredited product evaluation agencies and all International Trade Agreements.

<https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>