



Listing and Technical Evaluation Report™

A Duly Authenticated Report from an Approved Agency

Report No: 1911-03



Issue Date: September 24, 2020

Revision Date: September 8, 2025

Subject to Renewal: October 1, 2026

Big Timber® GDW, CAB, RWH™, and VEN™ Screw Properties

Trade Secret Report Holder:

Western Builders Supply dba Big Timber®

Phone: 406-252-6309

Website: bigtimberfasteners.com

Email: info@bigtimberfasteners.com

CSI Designations:

DIVISION: 06 00 00 - WOOD, PLASTICS AND COMPOSITES

Section: 06 05 23 - Wood, Plastic, and Composite Fastenings

1 Innovative Products Evaluated¹

1.1 Big Timber Round Washer Head Screws:

- 1.1.1 CAB²/RWH Screws
- 1.1.2 VEN Screw (Stone Veneer Screw)
- 1.1.3 GDW Screw (Garage Door Weather-Strip Screw)

2 Product Description and Materials

2.1 The innovative products evaluated in this report are shown in **Figure 1** and **Figure 2**.



Figure 1. GDW/CAB/RWH Screws



Figure 2. VEN Screw

2.2 Big Timber Round Washer Head Screws have a round washer head and are Torx-driven.

- 2.2.1 RWH/CAB and GDW Screws are partially threaded.
- 2.2.2 VEN Screws are fully threaded.



- 2.3 Big Timber Round Washer Head Screws are manufactured using a standard cold-formed process followed by a heat-treating process, then subsequently coated.
- 2.3.1 Big Timber Round Washer Head Screws are coated with a proprietary coating, which exceeds the protections provided by hot dipped galvanized coatings conforming to ASTM A153.
 - 2.3.2 Big Timber Round Washer Head Screws are available in multiple colors from the manufacturer.
 - 2.3.2.1 RWH/CAB screws are available in bronze, black (Ruspert^{®3}), or white colors.
 - 2.3.2.2 VEN Screws are only available in bronze color.
 - 2.3.2.3 GDW Screws are available in brown, sandstone (tan), or white.
- 2.4 Big Timber Round Washer Head Screws are approved for use in chemically treated or untreated lumber where ASTM A153, Class D coatings are approved for use in accordance with [IBC Section 2304.10](#) and [IRC Section R304.3](#).⁴
- 2.4.1 The proprietary coating has been tested and found to exceed the protection provided by code-approved hot dipped galvanized coatings meeting ASTM A153, Class D in accordance with [IBC Section 2304.10.6](#)⁵ and [IRC Section R304.3](#),⁶ allowing for its use in pressure-treated wood provided the conditions set forth by the pressure-treated lumber manufacturer be met, including appropriate strength reductions.
 - 2.4.2 Fasteners are approved for use in fire-retardant treated lumber, provided the conditions set forth by the fire retardant treated lumber manufacturer be met, including appropriate strength reductions.
- 2.5 Specifications for Big Timber Round Washer Head Screws are described in **Table 1**.

Table 1. Big Timber Round Washer Head Screws Specifications

Screw Name	Designation	Head (in)		Nominal Length ¹ (in)	Thread Length ¹ (in)	Shank Diameter ² (in)	Thread Diameter (in)		Specified Minimum Core Hardness ⁴ (HV 0.3)	Nominal Bending Yield, F _{yb} (psi)	Allowable Screw Strength (lbf)	
		Diameter	Drive Type				Minor	Major			Tensile	Shear ³
GDW/ CAB/ RWH	#7 x 1¼"	0.410	T15	1¼	0.827	0.121	0.110	0.171	376	179,000	480	415
	#8 x 1¼"	0.433	T20	1¼	7/8	0.119	0.107	0.171	240	179,000	480	415
	#8 x 1⅝"			1⅝	1							
	#8 x 2"			2	1⅜							
	#8 x 2½"			2½	2							
	#8 x 3"			3	2							
	#10 x 2½"	0.500	T25	2½	1½	0.145	0.122	0.190	240	190,000	885	680
#10 x 3"	3			2								
VEN	#8 x 1⅝"	0.433	T20	1⅝	Full	-	0.107	0.171	240	179,000	480	415
	#8 x 2¼"			2¼								

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N, 1 psi = 0.00689 MPa

1. Screw length is measured from the underside of the head to the tip. Thread length includes tapered tip.
2. Shank diameter based on manufactured thickness. Finished dimensions are larger due to the proprietary coatings added.
3. Shear strength applicable at both the smooth shank and thread diameter.
4. Based on a 300-gram load using the Vickers indenter.

2.6 As needed, review material properties for design in **Section 6** and the regulatory evaluation in **Section 8**.



3 Definitions⁷

- 3.1 New Materials⁸ are defined as building materials, equipment, appliances, systems, or methods of construction, not provided for by prescriptive and/or legislatively adopted regulations, known as alternative materials.⁹ The design strength and permissible stresses shall be established by tests¹⁰ and/or engineering analysis.¹¹
- 3.2 Duly authenticated reports¹² and research reports¹³ are test reports and related engineering evaluations that are written by an approved agency¹⁴ and/or an approved source.¹⁵
 - 3.2.1 These reports utilize intellectual property and/or trade secrets to create public domain material properties for commercial end-use.
 - 3.2.1.1 This report protects confidential Intellectual Property and trade secrets under the regulation, 18.U.S.Code.90, also known as Defend Trade Secrets Act of 2016 (DTSA).¹⁶
- 3.3 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is accredited and listed in the ANAB directory.
- 3.4 An approved source is “approved” when a professional engineer (i.e., Registered Design Professional, hereinafter RDP) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.¹⁷
- 3.5 Testing and/or inspections conducted for this duly authenticated report were performed by an ISO/IEC 17025 accredited testing laboratory, an ISO/IEC 17020 accredited inspection body, and/or a licensed RDP.
 - 3.5.1 The Center for Building Innovation (CBI) is ANAB¹⁸ ISO/IEC 17025 and ISO/IEC 17020 accredited.
- 3.6 The regulatory authority shall enforce¹⁹ the specific provisions of each legislatively adopted regulation. If there is a non-conformance, the specific regulatory section and language of the non-conformance shall be provided in writing²⁰ stating the nonconformance and the path to its cure.
- 3.7 The regulatory authority shall accept duly authenticated reports from an approved agency and/or an approved source with respect to the quality and manner of use of new materials or assemblies as provided for in regulations regarding the use of alternative materials, designs, or methods of construction.²¹
- 3.8 ANAB is an International Accreditation Forum (IAF) Multilateral Recognition Arrangement (MLA) signatory. Therefore, recognition of certificates and validation statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA with the appropriate scope shall be approved.²² Thus, all ANAB ISO/IEC 17065 duly authenticated reports are approval equivalent,²³ and can be used in any country that is an MLA signatory found at this link: <https://iaf.nu/en/recognised-abs/>
- 3.9 Approval equity is a fundamental commercial and legal principle.²⁴

4 Applicable Local, State, and Federal Approvals; Standards; Regulations²⁵

- 4.1 *Local, State, and Federal*
 - 4.1.1 Approved in all local jurisdictions pursuant to ISO/IEC 17065 duly authenticated report use, which includes, but is not limited to, the following featured local jurisdictions: Austin, Baltimore, Broward County, Chicago, Clark County, Dade County, Dallas, Detroit, Denver, DuPage County, Fort Worth, Houston, Kansas City, King County, Knoxville, Las Vegas, Los Angeles City, Los Angeles County, Miami, Nashville, New York City, Omaha, Philadelphia, Phoenix, Portland, San Antonio, San Diego, San Jose, San Francisco, Seattle, Sioux Falls, South Holland, Texas Department of Insurance, and Wichita.²⁶
 - 4.1.2 Approved in all state jurisdictions pursuant to ISO/IEC 17065 duly authenticated report use, which includes, but is not limited to, the following featured states: California, Florida, New Jersey, Oregon, New York, Texas, Washington, and Wisconsin.²⁷



4.1.3 Approved by the Code of Federal Regulations Manufactured Home Construction: Pursuant to Title 24, Subtitle B, Chapter XX, Part 3282.14²⁸ and Part 3280²⁹ pursuant to the use of ISO/IEC 17065 duly authenticated reports.

4.1.4 Approved means complying with the requirements of local, state, or federal legislation.

4.2 Standards

4.2.1 *AISI S904: Standard Test Methods for Determining the Tensile and Shear Strength of Screws*

4.2.2 *ANSI A208.1 Particleboard*

4.2.3 *ANSI/AWC NDS: National Design Specification (NDS) for Wood Construction*

4.2.4 *ASTM A153: Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*

4.2.5 *ASTM A510: Standard Specification for General Requirements for Wire Rods and Coarse Round Wire, Carbon Steel, and Alloy Steel*

4.2.6 *ASTM B117: Standard Practice for Operating Salt Spray (Fog) Apparatus*

4.2.7 *ASTM D1554: Standard Terminology Relating to Wood-Base Fiber and Particle Panel Materials*

4.2.8 *ASTM D1761: Standard Test Methods for Mechanical Fasteners in Wood and Wood-Based Materials*

4.2.9 *ASTM D2395: Standard Test Methods for Density and Specific Gravity (Relative Density) of Wood and Wood-Based Materials*

4.2.10 *ASTM D2915: Standard Practice for Sampling and Data-Analysis for Structural Wood and Wood-Based Products*

4.2.11 *ASTM D4442: Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials*

4.2.12 *ASTM F1575-21: Standard Test Method for Determining Bending Yield Moment of Nails*

4.2.13 *ASTM G85: Standard Practice for Modified Salt Spray (Fog) Testing*

4.2.14 *DOC PS 1: Structural Plywood*

4.3 Regulations

4.3.1 *IBC – 18, 21, 24: International Building Code®*

4.3.2 *IRC – 18, 21, 24: International Residential Code®*

4.3.3 *FBC-B – 20, 23: Florida Building Code³⁰ – Building (FL 35216)*

4.3.4 *FBC-B – 20, 23: Florida Building Code³⁰ – Residential (FL 35216)*

5 Listed³¹

5.1 Equipment, materials, products, or services included in a List published by a nationally recognized testing laboratory (i.e., CBI), an approved agency (i.e., CBI and DrJ), and/or an approved source (i.e., DrJ), or other organization(s) concerned with product evaluation (i.e., DrJ), that maintains periodic inspection (i.e., CBI) of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner.



6 Tabulated Properties Generated from Nationally Recognized Standards

6.1 General

- 6.1.1 Big Timber Round Washer Head Screws are used for conventional light-frame construction and provide resistance against withdrawal, head pull-through, axial, and shear loads. See **Section 9** for installation requirements.
- 6.1.2 Where the application exceeds the limitations set forth herein, design shall be permitted in accordance with accepted engineering procedures, experience, and technical judgment.

6.2 Design

- 6.2.1 Design of Big Timber Round Washer Head Screws is governed by the applicable code and the provisions for dowel-type fasteners in the NDS.
- 6.2.2 Unless otherwise noted, adjustment of the design stresses for duration of load shall be in accordance with the applicable code.

6.3 Reference Lateral Design Values (Z)

- 6.3.1 Reference lateral design values (lbf) for shear load parallel and perpendicular to grain for Big Timber Round Washer Head Screws are specified in:
 - 6.3.1.1 **Table 2** for plywood with Gypsum Wall Board (GWB) between the main and side members.
 - 6.3.1.2 **Table 3** for sawn lumber main and side members.

Table 2. Reference Lateral Design Values (Z) for ²³/₃₂" Plywood Side Member with ⁵/₈" GWB

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁴ (in)	Lateral Design Value, ^{1,2,3,6} Z (lbf)	
						Main Member Wood Species ⁵ (Specific Gravity)	
						SPF (0.42)	DF-L (0.50)
GDW/CAB/RWH	#8 x 3"	3	2	²³ / ₃₂	1 1/2	125	150
	#10 x 3"	3	2	²³ / ₃₂	1 1/2	200	200

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

1. Reference lateral design values apply to two-member single shear connections where the side member is plywood and GWB, the main member is DF-L (Specific Gravity = 0.50) or SPF (Specific Gravity = 0.42) respectively, and the screw is installed in the face of the member. The main member shall have a minimum thickness of 1.5".
2. Tabulated lateral design values (Z) shall be adjusted by all applicable adjustment factors per [NDS Table 11.3.1](#).
3. Lateral design values apply to both perpendicular (Z_⊥) and parallel (Z_∥) to main member grain orientations.
4. Screw main member penetration is the length embedded in the main member, including the tip.
5. For wood species of main member with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.
6. Plywood shall comply with DOC PS 1. Plywood shall have a specific gravity of at least 0.42.



Table 3. Reference Lateral Design Values (Z) for Sawn Lumber Main and Side Members

Fastener Name	Designation	Nominal Length (in)	Thread Length (in)	Minimum Side Member Thickness (in)	Minimum Main Member Penetration ⁵ (in)	Lateral Design Value, ^{1,2,3,4} Z (lbf)			
						SPF (SG = 0.42)		DF-L (SG = 0.50)	
						Z _⊥	Z _∥	Z _⊥	Z _∥
GDW/ CAB/ RWH	#8 x 1 ⁵ / ₈ "	1 ⁵ / ₈	1	3/4	7/8	50	50	70	70
	#8 x 2"	2	1 ³ / ₈	3/4	1 ¹ / ₄	60	60	75	75
	#8 x 2 ¹ / ₂ "	2 ¹ / ₂	2	1 ¹ / ₂	1	65	65	80	80
	#8 x 3"	3	2	1 ¹ / ₂	1 ¹ / ₂	75	75	85	85
	#10 x 2 ¹ / ₂ "	2 ¹ / ₂	1 ¹ / ₂	1 ¹ / ₂	1	80	80	100	100
	#10 x 3"	3	2	1 ¹ / ₂	1 ¹ / ₂	100	165	115	225
VEN	#8 x 1 ⁵ / ₈ "	1 ⁵ / ₈	Full	3/4	7/8	50	50	70	70
	#8 x 2 ¹ / ₄ "	2 ¹ / ₄		3/4	1 ¹ / ₂	60	60	75	75

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity and the screw is installed in the face of the member and oriented perpendicular to grain. Where the members are of different specific gravities, use the lower of the two.
2. For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.
3. Tabulated lateral design values (Z) shall be adjusted by all applicable adjustment factors per [NDS Table 11.3.1](#).
4. Z_⊥ = Lateral Design Values Perpendicular to Grain, Z_∥ = Lateral Design Values Parallel to Grain.
5. Screw main member penetration is the length embedded in the main member, including the tip.



6.4 Reference Withdrawal Design Values (W) in Side Grain Applications

6.4.1 Reference withdrawal design values (lbf/in.) for Big Timber Round Washer Head Screws in sawn lumber are specified in **Table 4**.

Table 4. Reference Withdrawal Design Values (W)

Screw Name	Designation	Nominal Length (in)	Thread Length (in)	Withdrawal Design Value, ^{1,3,4} W (lbf/in)	
				Wood Species ² (Specific Gravity)	
				SPF (0.42)	DF-L (0.50)
GDW/ CAB/ RWH	#7 x 1 1/4"	1 1/4	0.827	175	225
	#8 x 1 1/4"	1 1/4	7/8	175	225
	#8 x 1 5/8"	1 5/8	1		
	#8 x 2"	2	1 3/8		
	#8 x 2 1/2"	2 1/2	2		
	#8 x 3"	3	2		
	#10 x 2 1/2"	2 1/2	1 1/2		
	#10 x 3"	3	2		
VEN	#8 x 1 5/8"	1 5/8	Full		
	#8 x 2 1/4"	2 1/4			

SI: 1 in. = 25.4 mm, 1 lb./ft. = 0.0146 kN/m

1. Tabulated withdrawal values (W) shall be adjusted by all applicable adjustment factors per [NDS Table 11.3.1](#).
2. For wood species with a specific gravity between 0.42 and 0.50, use the tabulated values for specific gravity of 0.42.
3. The full design withdrawal value is equal to the reference withdrawal value multiplied by the length of the threaded portion of the screw embedded in the main member.
4. Screw penetration is the threaded length embedded in the main member, including the tip.



6.5 Reference Head Pull-Through Design Values (P)

6.5.1 Reference design values for head pull through (lbf) for Big Timber Round Washer Head Screws are specified in **Table 5** for particleboard, plywood, and sawn lumber.

Table 5. Reference Head Pull-Through Design Values

Screw Name	Designation	Nominal Length (in)	Thread Length (in)	Head Pull-Through Design Value (P), ^{1,5} (lbf)		
				Side Member		
				³ / ₄ " Particleboard ²	²³ / ₃₂ " Plywood ³	1.5" SPF ⁴
GDW/ CAB/ RWH	#7 x 1 1/4"	1 1/4	0.827	240	310	-
	#8 x 1 1/4"	1 1/4	7/8	255	350	-
	#8 x 1 5/8"	1 5/8	1			180
	#8 x 2"	2	1 3/8			
	#8 x 2 1/2"	2 1/2	2			
	#8 x 3"	3	2	255	380	525
	#10 x 2 1/2"	2 1/2	1 1/2			
	#10 x 3"	3	2			
VEN	#8 x 1 5/8"	1 5/8	Full	255	350	180
	#8 x 2 1/4"	2 1/4				

SI: 1 in. = 25.4 mm, 1 lb. = 4.45 N

1. Tabulated pull-through values (P) shall be adjusted by all applicable adjustment factors per [NDS Table 11.3.1](#).
2. Particleboard shall be medium density and comply with ANSI A208.1, per [IBC Section 2303.1.8](#). Particleboard shall have a minimum density of 40 lb/ft³ (640 kg/m³).
3. Plywood shall comply with DOC PS 1. Plywood shall have a specific gravity of at least 0.42.
4. Wood species shall have a specific gravity of at least 0.42.
5. Pull-through design values apply to connections having the listed minimum wood side member thickness.

6.6 Where the application falls outside of the performance evaluation, conditions of use, and/or installation requirements set forth herein, alternative techniques shall be permitted in accordance with accepted engineering practice and experience. This includes but is not limited to the following areas of engineering: mechanics or materials, structural, building science, and fire science.

7 Certified Performance³²

7.1 All construction methods shall conform to accepted engineering practices to ensure durable, livable, and safe construction and shall demonstrate acceptable workmanship reflecting journeyman quality of work of the various trades.³³

7.2 The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.³⁴



8 Regulatory Evaluation and Accepted Engineering Practice

- 8.1 Big Timber Round Washer Head Screws comply with the following legislatively adopted regulations and/or accepted engineering practice for the following reasons:
- 8.1.1 Bending yield in accordance with ASTM F1575
 - 8.1.2 Tensile strength in accordance with AISI S904
 - 8.1.3 Shear strength in accordance with AISI S904
 - 8.1.4 Lateral shear in accordance with ASTM D1761
 - 8.1.5 Withdrawal strength in accordance with ASTM D1761
 - 8.1.6 Head pull-through in accordance with ASTM D1761
- 8.2 Big Timber Round Washer Head Screws were tested and evaluated for corrosion resistance of fasteners meeting or exceeding the protection afforded hot-dipped galvanized fasteners in accordance with ASTM A153, Class D.
- 8.3 Use of screws in locations exposed to saltwater or saltwater spray are outside the scope of this report.
- 8.4 Any building code, regulation and/or accepted engineering evaluations (i.e., research reports, duly authenticated reports, etc.) that are conducted for this Listing were performed by DrJ, which is an ISO/IEC 17065 accredited certification body and a professional engineering company operated by RDP or approved sources. DrJ is qualified³⁵ to practice product and regulatory compliance services within its scope of accreditation and engineering expertise,³⁶ respectively.
- 8.5 Engineering evaluations are conducted with DrJ's ANAB accredited ICS code scope of expertise, which is also its areas of professional engineering competence.
- 8.6 Any regulation specific issues not addressed in this section are outside the scope of this report.

9 Installation

- 9.1 Installation shall comply with the approved construction documents, the manufacturer installation instructions, this report, and the applicable building code.
- 9.2 In the event of a conflict between the manufacturer installation instructions and this report, contact the manufacturer for counsel on the proper installation method.
- 9.3 *Installation Procedure*
- 9.3.1 Unless otherwise stated in this report, minimum penetration is 1".
 - 9.3.2 Install Big Timber Round Washer Head Screws with head flush to the surface of the wood member.
 - 9.3.3 Lead holes are not required.
 - 9.3.4 Big Timber Round Washer Head Screws shall be installed with the appropriate rotating powered driver.
 - 9.3.5 Minimum requirements for screw spacing, edge distance, and end distance shall be in accordance with **Table 6**.



Table 6. GDW/CAB/RWH/VEN Screw Spacing, Edge Distance, and End Distance Requirements^{1,2}

Connection Geometry	Minimum Spacing/Distance (in)		
	#7	#8	#10
Edge Distance – Load in any direction	3/8	3/8	3/8
End Distance – Load parallel to grain, towards end	1 6/8	1 7/8	2 1/4
End Distance – Load parallel to grain, away from end	1 1/8	1 1/4	1 1/2
End Distance – Load perpendicular to grain	1 1/8	1 1/4	1 1/2
Spacing Between Screws in a Row – Parallel to grain	1 6/8	1 7/8	2 1/4
Spacing Between Screws in a Row – Perpendicular to grain	1 1/8	1 1/4	1 1/2
Spacing Between Rows of Screws – In-line	5/8	5/8	3/4
Spacing Between Rows of Screws – Staggered	3/8	3/8	3/8

SI: 1 in. = 25.4 mm

- Edge distances, end distances, and spacing of screws shall be sufficient to prevent splitting of the wood or as shown in this table, whichever is more restrictive.
- Values for "Spacing between Rows of Screws-Staggered" apply where the screws in adjacent rows are offset by one-half of the "Spacing between Screws in a Row."

10 Substantiating Data

- 10.1 Testing has been performed under the supervision of a professional engineer and/or under the requirements of ISO/IEC 17025 as follows:
- 10.1.1 Bending yield testing in accordance with ASTM F1575
 - 10.1.2 Tensile strength testing in accordance with AISI S904
 - 10.1.3 Shear strength testing in accordance with AISI S904
 - 10.1.4 Lateral strength testing in accordance with ASTM D1761
 - 10.1.5 Withdrawal testing in accordance with ASTM D1761
 - 10.1.6 Head pull-through testing in accordance with ASTM D1761
 - 10.1.7 Corrosion resistance testing in accordance with ASTM B117 and ASTM G85
- 10.2 Information contained herein may include the result of testing and/or data analysis by sources that are approved agencies, approved sources, and/or an RDP. Accuracy of external test data and resulting analysis is relied upon.
- 10.3 Where applicable, testing and/or engineering analysis are based upon provisions that have been codified into law through state or local adoption of regulations and standards. The developers of these regulations and standards are responsible for the reliability of published content. DrJ's engineering practice may use a regulation-adopted provision as the control. A regulation-endorsed control versus a simulation of the conditions of application to occur establishes a new material as being equivalent to the regulatory provision in terms of quality, strength, effectiveness, fire resistance, durability, and safety.
- 10.4 The accuracy of the provisions provided herein may be reliant upon the published properties of raw materials, which are defined by the grade mark, grade stamp, mill certificate, or duly authenticated reports from approved agencies and/or approved sources provided by the supplier. These are presumed to be minimum properties and relied upon to be accurate. The reliability of DrJ's engineering practice, as contained in this duly authenticated report, may be dependent upon published design properties by others.



10.5 Testing and Engineering Analysis

10.5.1 The strength, rigidity, and/or general performance of component parts and/or the integrated structure are determined by suitable tests that simulate the actual conditions of application that occur and/or by accepted engineering practice and experience.³⁷

10.6 Where additional condition of use and/or regulatory compliance information is required, please search for Big Timber Round Washer Head Screws on the [DrJ Certification website](#).

11 Findings

11.1 As outlined in **Section 6**, Big Timber Round Washer Head Screws have performance characteristics that were tested and/or meet applicable regulations. In addition, they are suitable for use pursuant to its specified purpose.

11.2 When used and installed in accordance with this [duly authenticated report](#) and the manufacturer installation instructions, Big Timber Round Washer Head Screws shall be approved for the following applications:

11.2.1 Use as fasteners in accordance with the reference design value properties defined in **Table 2** through **Table 5**, and are approved for use in accordance with the applicable code.

11.3 Unless exempt by state statute, when Big Timber Round Washer Head Screws are to be used as a structural and/or building envelope component in the design of a specific building, the design shall be performed by an [RDP](#).

11.4 Any application specific issues not addressed herein can be engineered by an [RDP](#). Assistance with engineering is available from Big Timber.

11.5 [IBC Section 104.2.3](#)³⁸ ([IRC Section R104.2.2](#)³⁹ and [IFC Section 104.2.3](#)⁴⁰ are similar) in pertinent part state:

104.2.3 Alternative Materials, Design and Methods of Construction and Equipment. The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code, provided that any such alternative is not specifically prohibited by this code and has been approved.

11.6 **Approved:**⁴¹ Building regulations require that the [building official](#) shall accept [duly authenticated reports](#).⁴²

11.6.1 An [approved agency](#) is “*approved*” when it is [ANAB ISO/IEC 17065 accredited](#).

11.6.2 An [approved source](#) is “*approved*” when an [RDP](#) is properly licensed to transact engineering commerce.

11.6.3 Federal law, [Title 18 US Code Section 242](#), requires that, where the alternative product, material, service, design, assembly, and/or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved. Denial without written reason deprives a protected right to free and fair competition in the marketplace.

11.7 DrJ is a licensed engineering company, employs licensed [RDPs](#) and is an [ANAB Accredited Product Certification Body – Accreditation #1131](#).

11.8 Through the [IAF Multilateral Arrangement \(MLA\)](#), this [duly authenticated report](#) can be used to obtain product approval in any [jurisdiction](#) or [country](#) because all ANAB ISO/IEC 17065 [duly authenticated reports](#) are equivalent.⁴³



12 Conditions of Use

- 12.1 Material properties shall not fall outside the boundaries defined in **Section 6**.
- 12.2 As defined in **Section 6**, where material and/or engineering mechanics properties are created for load resisting design purposes, the resistance to the applied load shall not exceed the ability of the defined properties to resist those loads using the principles of accepted engineering practice.
- 12.3 Moisture content of wood members shall be the following:
- 12.3.1 *Sawn Lumber*: less than or equal to nineteen percent (19%) per NDS Section 4.1.4
 - 12.3.2 *Plywood*: less than sixteen percent (16%) per NDS Section 9.1.4
 - 12.3.3 *Particleboard*: less than ten percent (10%) per ANSI A208.1
- 12.4 Use of screws in locations exposed to saltwater or saltwater spray is outside the scope of this report.
- 12.5 When required by adopted legislation and enforced by the building official, also known as the Authority Having Jurisdiction (AHJ) in which the project is to be constructed:
- 12.5.1 Any calculations incorporated into the construction documents shall conform to accepted engineering practice and, when prepared by an approved source, shall be approved when signed and sealed.
 - 12.5.2 This report and the installation instructions shall be submitted at the time of permit application.
 - 12.5.3 These innovative products have an internal quality control program and a third-party quality assurance program.
 - 12.5.4 At a minimum, these innovative products shall be installed per **Section 9**.
 - 12.5.5 The review of this report by the AHJ shall comply with IBC Section 104.2.3.2 and IBC Section 105.3.1.
 - 12.5.6 These innovative products have an internal quality control program and a third party quality assurance program in accordance with IBC Section 104.7.2, IBC Section 110.4, IBC Section 1703, IRC Section R104.7.2, and IRC Section R109.2.
 - 12.5.7 The application of these innovative products in the context of this report is dependent upon the accuracy of the construction documents, implementation of installation instructions, inspection as required by IBC Section 110.3, IRC Section R109.2, and any other regulatory requirements that may apply.
- 12.6 The approval of this report by the AHJ shall comply with IBC Section 1707.1, where legislation states in part, *“the building official shall make, or cause to be made, the necessary tests and investigations; or the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in Section 104.2.3”*, all of IBC Section 104, and IBC Section 105.3.
- 12.7 Design loads shall be determined in accordance with the regulations adopted by the jurisdiction in which the project is to be constructed and/or by the building designer (i.e., owner or RDP).
- 12.8 The actual design, suitability, and use of this report for any particular building, is the responsibility of the owner or the authorized agent of the owner.



13 Identification

- 13.1 Big Timber Round Washer Head Screws, as listed in **Section 1.1**, are identified by a label on the board or packaging material bearing the manufacturer name, product name, this report number, and other information to confirm code compliance.
- 13.2 Additional technical information can be found at bigtimberfasteners.com.

14 Review Schedule

- 14.1 This report is subject to periodic review and revision. For the latest version, visit www.drjcertification.org.
- 14.2 For information on the status of this report, please contact [DrJ Certification](#).



Issue Date: December 22, 2020
Subject to Renewal: October 1, 2026

FBC Supplement to Report Number 1911-03

REPORT HOLDER: Big Timber

1 Evaluation Subject

- 1.1 Big Timber Round Washer Head Screws:
 - 1.1.1 CAB/RWH Screws
 - 1.1.2 VEN Screw (Stone Veneer Screw)
 - 1.1.3 GDW Screw (Garage Door Weather-Strip Screw)

2 Purpose and Scope

- 2.1 Purpose
 - 2.1.1 The purpose of this Report Supplement is to show Big Timber Round Washer Head Screws, recognized in Report Number 1911-03, have also been evaluated for compliance with the codes listed below as adopted by the Florida Building Commission.
- 2.2 *Applicable Code Editions*
 - 2.2.1 *FBC-B – 20, 23: Florida Building Code – Building (FL 35216)*
 - 2.2.2 *FBC-B – 20, 23: Florida Building Code – Residential (FL 35216)*

3 Conclusions

- 3.1 Big Timber Round Washer Head Screws, described in Report Number 1911-03, comply with the FBC-B and FBC-R and are subject to the conditions of use described in this supplement.
- 3.2 Where there are variations between the IBC and IRC and the FBC-B and FBC-R applicable to this report, they are listed here:
 - 3.2.1 FBC-B Section 104 is reserved.
 - 3.2.2 FBC-B Section 110.4 is reserved and replaces IBC Section 110.4.
 - 3.2.3 FBC-B Section 104.6 is reserved and replaces IBC Section 104.4.
 - 3.2.4 FBC-B Section 104.11 replaces IBC Section 104.2.3 and Section 104.2.3.2.
 - 3.2.5 FBC-B Section 105.3 replaces IBC Section 105.3.
 - 3.2.6 FBC-B Section 105.3.1 replaces IBC Section 105.3.1.
 - 3.2.7 FBC-B Section 110.3 replaces IBC Section 110.3.
 - 3.2.8 FBC-B Section 1707.1 replaces IBC Section 1707.1.
 - 3.2.9 FBC-B Section 2304.10 replaces IBC Section 2304.10.
 - 3.2.10 FBC-B Section 2304.10.5 replaces IBC Section 2304.10.6.
 - 3.2.11 FBC-B Section 2306.1 replaces IBC Section 2306.1.
 - 3.2.12 FBC-B Section 2306.3 replaces IBC Section 2306.3.



3.2.13 FBC-R Section R104 and Section R109 are reserved.

3.2.14 FBC-R Section R317.3 replaces IRC Section R304.3.

4 Conditions of Use

4.1 Big Timber Round Washer Head Screws, described in Report Number 1911-03, must comply with all of the following conditions:

4.1.1 All applicable sections in Report Number 1911-03.

4.1.2 The design, installation, and inspections are in accordance with additional requirements of FBC-B Chapter 16 and Chapter 17, as applicable.



Notes

- 1 For more information, visit drjcertification.org or call us at 608-310-6748.
- 2 Formerly known as "CAB, CAB WHT, and CAB BLK Cabinet Screws".
- 3 Ruspert® is a high-grade protective coating applied to metals to prevent environmental corrosion.
- 4 [2021 IRC Section R317.3](#)
- 5 [2018 IBC Section 2304.10.5](#)
- 6 [2021 IRC Section R317.3](#)
- 7 Capitalized terms and responsibilities are defined pursuant to the applicable building code, applicable reference standards, the latest edition of [TPI 1](#), the [NDS](#), [AISI S202](#), [US professional engineering law](#), [Canadian building code](#), [Canada professional engineering law](#), [Qualtim External Appendix A: Definitions/Commentary](#), [Qualtim External Appendix B: Project/Deliverables](#), [Qualtim External Appendix C: Intellectual Property and Trade Secrets](#), definitions created within Design Drawings and/or definitions within Reference Sheets. Beyond this, terms not defined shall have ordinarily accepted meanings as the context implies. Words used in the present tense include the future; words stated in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural, the singular.
- 8 <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1702>
- 9 Alternative Materials, Design and Methods of Construction and Equipment: The provisions of any regulation code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by a regulation. Please review <https://www.justice.gov/atr/mission> and <https://up.codes/viewer/mississippi/ibc-2024/chapter/11/scope-and-administration#104.2.3>
- 10 <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1706.2>:-:text=the%20design%20strengths%20and%20permissible%20stresses%20shall%20be%20established%20by%20tests
- 11 The [design strengths](#) and permissible stresses of any structural material shall conform to the specifications and methods of design of accepted engineering practice. <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1706.1>:-:text=Conformance%20to%20Standards-.The%20design%20strengths%20and%20permissible%20stresses,-of%20any%20structural
- 12 <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1>:-:text=the%20building%20official%20shall%20make%20or%20cause%20to%20be%20made%20the%20necessary%20tests%20and%20investigations%3B%20or%20the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies%20in%20respect%20to%20the%20quality%20and%20manner%20of%20use%20of%20new%20materials%20or%20assemblies%20as%20provided%20for%20in%20Section%20104.2.3.
- 13 <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1703.4.2>
- 14 https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#approved_agency
- 15 https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#approved_source
- 16 <https://www.law.cornell.edu/uscode/text/18/1832> (b) Any organization that commits any offense described in subsection (a) shall be fined not more than the greater of \$5,000,000 or 3 times the value of the stolen trade secret to the organization, including expenses for research and design and other costs of reproducing the trade secret that the organization has thereby avoided. The [federal government](#) and each state have a [public records act](#). To follow DTSA and comply state public records and trade secret legislation requires approval through ANAB ISO/IEC 17065 accredited certification bodies or approved sources. For more information, please review this website: [Intellectual Property and Trade Secrets](#).
- 17 <https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>
- 18 <https://www.cbiteest.com/accreditation/>
- 19 <https://up.codes/viewer/mississippi/ibc-2024/chapter/11/scope-and-administration#104.1>:-:text=directed%20to%20enforce%20the%20provisions%20of%20this%20code
- 20 <https://up.codes/viewer/mississippi/ibc-2024/chapter/11/scope-and-administration#104.2.3> AND <https://up.codes/viewer/mississippi/ibc-2024/chapter/11/scope-and-administration#105.3.1>
- 21 <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1>
- 22 <https://iaf.nu/en/about-iaf-mia/#>:-:text=Once%20an%20accreditation%20body%20is%20a%20signatory%20of%20the%20IAF%20MLA%20it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%20with%20the%20appropriate%20scope
- 23 True for all ANAB accredited product evaluation agencies and all International Trade Agreements.
- 24 <https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>
- 25 Unless otherwise noted, the links referenced herein use un-amended versions of the [2024 International Code Council \(ICC\) 2024 International Code Council \(ICC\) model codes](#) as foundation references. Mississippi versions of the [IBC 2024](#) and the [IRC 2024](#) are un-amended. This material, product, design, service and/or method of construction also complies with the 2000-2012 versions of the referenced codes and the standards referenced therein. As pertinent to this technical and code compliance evaluation, CBI and/or DrJ staff have reviewed any state or local regulatory amendments to assure this report is in compliance.
- 26 See [Adoptions by Publisher](#) for the latest adoption of a non-amended or amended model code by the local jurisdiction. <https://up.codes/codes/general>
- 27 See [Adoptions by Publisher](#) for the latest adoption of a non-amended or amended model code by state. <https://up.codes/codes/general>
- 28 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3282/subpart-A/section-3282.14>
- 29 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>
- 30 All references to the FBC-B and FBC-R are the same as the 2024 IBC and 2024 IRC, unless otherwise noted in the Florida Supplement at the end of this report.
- 31 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2>(Listed%20or%20certified); <https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#listed> AND <https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#labeled>
- 32 <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1703.4>



- 33 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#:~:text=All%20construction%20methods%20shall%20be%20in%20conformance%20with%20accepted%20engineering%20practices%20to%20insure%20durable%2C%20livable%2C%20and%20safe%20housing%20and%20shall%20demonstrate%20acceptable%20workmanship%20reflecting%20journeyman%20quality%20of%20work%20of%20the%20various%20trades>
- 34 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#:~:text=The%20strength%20and%20rigidity%20of%20the%20component%20parts%20and/or%20the%20integrated%20structure%20shall%20be%20determined%20by%20engineering%20analysis%20or%20by%20suitable%20load%20tests%20to%20simulate%20the%20actual%20loads%20and%20conditions%20of%20application%20that%20occur>
- 35 Qualification is performed by a legislatively defined Accreditation Body. ANSI National Accreditation Board (ANAB) is the largest independent accreditation body in North America and provides services in more than 75 countries. DrJ is an ANAB accredited product certification body.
- 36 <https://anabpd.ansi.org/Accreditation/product-certification/AllDirectoryDetails?prqID=1&orgID=2125&statusID=4#:~:text=Bill%20Payment%20Date-,Accredited%20Scopes-,13%20ENVIRONMENT.%20HEALTH>
- 37 See Code of Federal Regulations (CFR) Title 24 Subtitle B Chapter XX Part 3280 for definition: <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>
- 38 [2021 IBC Section 104.11](#)
- 39 [2021 IRC Section R104.11](#)
- 40 2018: <https://up.codes/viewer/wyoming/ifc-2018/chapter/1/scope-and-administration#104.9> AND 2021: <https://up.codes/viewer/wyoming/ibc-2021/chapter/1/scope-and-administration#104.11>
- 41 Approved is an adjective that modifies the noun after it. For example, Approved Agency means that the Agency is accepted officially as being suitable in a particular situation. This example conforms to IBC/IRC/IFC Section 201.4 (<https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#201.4>) where the building code authorizes sentences to have an ordinarily accepted meaning such as the context implies.
- 42 <https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1>
- 43 Multilateral approval is true for all ANAB accredited product evaluation agencies and all International Trade Agreements.