Listing and Technical Evaluation Report™

A Duly Authenticated Report from an Approved Agency

Report No: 1911-05

Issue Date: April 28, 2021

Revision Date: August 26, 2026

Subject to Renewal: October 1, 2027

Big Timber® Screws Used in Wall Connections: Truss/Rafter/Joist to Top Plate and Bottom Plate to Rim Board

Trade Secret Report Holder:

Western Builders Supply dba Big Timber®

Phone: 406-252-6309 Website: www.marmonfasteners.com/big-timber-us Email: sales@bigtimberfasteners.com

CSI Designations:

DIVISION: 06 00 00 - WOOD, PLASTICS AND COMPOSITES Section: 06 00 90 - Wood and Plastic Fastenings

1 Innovative Products Evaluated[1]

1.1 Big Timber Screws:

1.1.1 CTX Construction Lag Screws

1.1.2 BL Log, Timber, and Landscape Screws

1.1.3 SCTX Construction Lag Stainless Steel Screws

2 Product Description and Materials

2.1 *Fastener Descriptions*

2.1.1 Big Timber CTX Construction Lag Screws have a round washer head with a star drive and are partially threaded. The CTX Construction Lag Screw is shown in **Figure 1**.



Figure 1. CTX Construction Lag Screw

2.1.2 Big Timber BL Log, Timber, and Landscape Screws have a hex head washer head and are partially threaded. The BL Log, Timber and Landscape Screw is shown in **Figure 2**.



Figure 2. BL Log, Timber, and Landscape Screw

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

2.1.3 Big Timber SCTX Construction Lag Stainless Steel Screws are made from Grade 316 stainless steel, have a round washer head with a star drive, and are partially threaded. The SCTX Construction Lag Stainless Steel Screw is shown in **Figure 3**.



Figure 3. SCTX Construction Lag Stainless Steel Screw

2.1.4 CTX and BL screws are manufactured using a standard cold-formed process followed by a heat-treating process.

2.1.5 SCTX screws are manufactured using a standard cold-formed process.

2.2 *Fastener Coatings*

2.2.1 CTX screws are coated with a proprietary coating designated as Bronze Star, which exceeds the protections provided by hot-dipped galvanized coatings conforming to ASTM A153.

2.2.2 BL screws are coated with a proprietary coating designated as Black Log, which exceeds the protections provided by hot-dipped galvanized coatings conforming to ASTM A153.

2.3 Big Timber Screws are approved for use in chemically treated or untreated lumber where ASTM A153, Class D coatings are approved for use in accordance with IBC Section 2304.10 and IRC Section R304.3.[2]

2.3.1 The proprietary coating and stainless material have been tested and found to exceed the protection provided by code-approved hot-dipped galvanized coatings meeting ASTM A153, Class D (IBC Section 2304.10.6[3] and IRC Section R304.3[4]), allowing for its use in pressure treated wood.

2.3.2 Fasteners are approved for use in fire-retardant treated lumber, provided the conditions set forth by the fire-retardant treated lumber manufacturer be met, including appropriate strength reductions.

2.4 SCTX screws are approved for use in chemically treated wood with exposure to saltwater, including coastal construction applications.

2.5 Big Timber Screws are specified in **Table 1**.

Table 1. Fastener Specifications

Fastener Name	Desig-nation	Head		Nominal Length[1] (in)	Thread Length[1] (in)	Shank Diameter[2] (in)	Thread Diameter (in)		Specified Minimum Core Hardness[4] (HV 0.3)	Nominal Bending Yield, F_{yb} (psi)	Allowable Fastener Strength (lb)	
		Diameter (in)	Drive Type				Minor	Major			Tensile	Shear[3]
CTX	14 x 4"	0.531	Torx 25	4	2	0.168	0.146	0.242	355	141,300	930	725
	14 x 6"			6	3							
BL	14 x 4"	0.487	Hex 5/16	4	2	0.189	0.171	0.258	355	177,700	1,085	725
	14 x 6"			6								
SCTX	15 x 4"	0.620	Torx 30	4	2 1/2	0.202	0.179	0.275	N/A	111,000	855	725
	15 x 6"			6	3							

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1-psi = 0.00689 MPa

1. Fastener length is measured from the underside of the head to the tip. Thread length includes tapered tip.
2. Shank diameter based on manufactured thickness. Finished dimensions are larger, due to the proprietary coatings added (CTX and BL only).
3. Shear determined at smooth shank diameter.
4. Based on a 300-gram load using the Vickers indenter.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

2.6 As needed, review material properties for design in **Section 6** and the regulatory evaluation in **Section 8**.

3 Definitions[5]

3.1 New Materials[6] are defined as building materials, equipment, appliances, systems, or methods of construction, not provided for by prescriptive and/or legislatively adopted regulations, known as alternative materials.[7] The design strength and permissible stresses shall be established by tests[8] and/or engineering analysis.[9]

3.2 Duly authenticated reports[10] and research reports[11] are test reports and related engineering evaluations that are written by an approved agency[12] and/or an approved source.[13]

3.2.1 This report utilizes intellectual property and/or trade secrets to create public domain material properties for commercial end-use.

3.2.1.1 This report protects confidential Intellectual Property and trade secrets under the regulation, 18.US.Code.90, also known as Defend Trade Secrets Act of 2016 (DTSA).[14]

3.3 An approved agency is *"approved"* when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is accredited and listed in the ANAB directory.

3.4 An approved source is *"approved"* when a professional engineer (i.e., Registered Design Professional, hereinafter RDP) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.[15]

3.5 Testing and/or inspections conducted for this duly authenticated report were performed by an ISO/IEC 17025 accredited testing laboratory, an ISO/IEC 17020 accredited inspection body, and/or a licensed RDP.

3.5.1 The Center for Building Innovation (CBI) is ANAB[16] ISO/IEC 17025 and ISO/IEC 17020 accredited.

3.6 The regulatory authority shall enforce[17] the specific provisions of each legislatively adopted regulation. If there is a non-conformance, the specific regulatory section and language of the non-conformance shall be provided in writing[18] stating the nonconformance and the path to its cure.

3.7 The regulatory authority shall accept duly authenticated reports from an approved agency and/or an approved source with respect to the quality and manner of use of new materials or assemblies as provided for in regulations regarding the use of alternative materials, designs, or methods of construction.[19]

3.8 ANAB is an International Accreditation Forum (IAF) Multilateral Recognition Arrangement (MLA) signatory. Therefore, recognition of certificates and validation statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA with the appropriate scope shall be approved.[20] Thus, all ANAB ISO/IEC 17065 duly authenticated reports are approval equivalent,[21] and can be used in any country that is an MLA signatory found at this link: https://iaf.nu/en/recognised-abs/

3.9 Approval equity is a fundamental commercial and legal principle.[22]

4 Applicable Local, State, and Federal Approvals; Standards; Regulations[23]

4.1 *Local, State, and Federal*

4.1.1 Approved in all local jurisdictions pursuant to ISO/IEC 17065 duly authenticated report use, which includes, but is not limited to, the following featured local jurisdictions: Austin, Baltimore, Broward County, Chicago, Clark County, Dade County, Dallas, Detroit, Denver, DuPage County, Fort Worth, Houston, Kansas City, King County, Knoxville, Las Vegas, Los Angeles City, Los Angeles County, Miami, Nashville, New York City, Omaha, Philadelphia, Phoenix, Portland, San Antonio, San Diego, San Jose, San Francisco, Seattle, Sioux Falls, South Holland, St. Louis County, Texas Department of Insurance, and Wichita.[24]

4.1.2 Approved in all state jurisdictions pursuant to ISO/IEC 17065 duly authenticated report use, which includes, but is not limited to, the following featured states: California, Florida, New Jersey, Oregon, New York, Texas, Washington, and Wisconsin.[25]

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

4.1.3 Approved by the Code of Federal Regulations Manufactured Home Construction: Pursuant to Title 24, Subtitle B, Chapter XX, Part 3282.14[26] and Part 3280[27] pursuant to the use of ISO/IEC 17065 duly authenticated reports.

4.1.4 Approved means complying with the requirements of local, state, or federal legislation.

4.2 *Regulations*

4.2.1 *IBC – 18, 21, 24: International Building Code®*

4.2.2 *IRC – 18, 21, 24: International Residential Code®*

4.3 *Standards*

4.3.1 *AISI S904: Standard Test Methods for Determining the Tensile and Shear Strengths of Screws*

4.3.2 *ANSI/AWC NDS: National Design Specification (NDS) for Wood Construction*

4.3.3 *ASTM A153: Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*

4.3.4 *ASTM A493: Standard Specification for Stainless Steel Wire and Wire Rods for Cold Heading and Cold Forging*

4.3.5 *ASTM A510: Standard Specification for General Requirements for Wire Rods and Coarse Round Wire, Carbon Steel, and Alloy Steel*

4.3.6 *ASTM B117: Standard Practice for Operating Salt Spray (Fog) Apparatus*

4.3.7 *ASTM D1761: Standard Test Method for Mechanical Fasteners in Wood and Wood-Based Materials*

4.3.8 *ASTM D2395: Standard Test Method for Density and Specific Gravity (Relative Density) of Wood and Wood-Based Materials*

4.3.9 *ASTM D2915: Standard Practice for Sampling and Data-Analysis for Structural Wood and Wood-Based Products*

4.3.10 *ASTM D4442: Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials*

4.3.11 *ASTM F1575-21: Standard Test Method for Determining Bending Yield Moment of Nails, Spikes, and Dowel-type Threaded Fasteners*

4.3.12 *ASTM G85: Standard Practice for Modified Salt Spray (Fog) Testing*

5 Listed[28]

5.1 Equipment, materials, products, or services included in a List published by a nationally recognized testing laboratory (e.g., CBI), an approved agency (e.g., CBI and DrJ), and/or an approved source (e.g., DrJ), or other organization(s) concerned with product evaluation (e.g., DrJ), that maintains periodic inspection (e.g., CBI) of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner.

6 Tabulated Properties Generated from Nationally Recognized Standards

6.1 Big Timber Screws are used in the construction of walls that meet the requirements of IBC Section 2308 or IRC Section R602 for the following applications:

6.1.1 To attach minimum 1½" thick wood trusses, rafters, or floor joists to wood walls

6.1.2 To attach wall bottom plates to rim boards in the construction of walls

6.2 See **Section 6.8** and **Section 6.9** for allowable design loads.

6.3 Allowable design loads are applicable to fasteners installed in accordance with **Section 9**.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

6.4 Walls shall consist of, at a minimum, a double top plate installed in accordance with IBC Section 2308.9.2 or IRC Section R602.3.2.

6.5 Big Timber Screws are used in buildings requiring design in accordance with IBC Section 1609 or wind analysis in accordance with IRC Section R301.2.1.

6.6 Big Timber Screws are used in buildings requiring design in accordance with IBC Section 1613, or seismic analysis in accordance with IRC Section R301.2.2.

6.7 To maintain a continuous uplift load path, connections in the same area must be stacked on the same side of the wall (i.e., rafter to top plate connection and top plate to stud connection).

6.8 *Allowable Design Loads – Truss/Rafter/Joist to Top Plate Connection*

6.8.1 Allowable design loads for uplift and lateral resistance for truss, rafter, and joist to top plate connections are provided in **Table 2**.

6.8.2 Loads parallel to the wall are labeled F1 and loads perpendicular to the wall are labeled F2. See **Figure 4** for load directions.

6.8.3 Allowable design loads are applicable to fasteners installed in accordance with **Section 9.4** in double top plate applications.

Table 2. Allowable Uplift and Lateral Loads for Fasteners in Truss/Rafter/Joist to Top Plate Connections

Fastener	Minimum Penetration into Truss/Rafter/Joist[1] (in)	Top Plate(s)	Fastener Angle to Vertical[7]	Allowable Loads[2,3,4,5,6] (lb)								
				HF/SPF (0.42)			DF-L (0.50)			SP (0.55)		
				Uplift	F1	F2	Uplift	F1	F2	Uplift	F1	F2
CTX 14 x 6"	2½	Double	22.5°	535	415	495	450	230	515	810	425	655
			90°	550	195	410	550	230	410	650	250	410
BL 14 x 6"		Double	22.5°	430	295	530	385	325	385	655	435	705
			90°	335	240	410	335	280	410	385	305	410
SCTX 15 x 6"		Double	22.5°	420	235	235	515	280	280	600	305	305
			90°	545	200	200	550	235	235	775	255	255

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. Wood truss, rafter, or floor joist members shall be a minimum of 2" nominal thickness. Design of truss, rafter, or floor joist is by others.
2. Equivalent specific gravity of Structural Composite Lumber (SCL) shall be equal to or greater than the specific gravities provided in this table. Refer to product information from SCL manufacturer.
3. For wood species with an assigned specific gravity between two of the specific gravities above, use the tabulated values for the next lowest specific gravity. For wood species with an assigned specific gravity greater than or equal to 0.55, use the tabulated value for specific gravity of 0.55.
4. For applications involving members with different specific gravities, use the allowable load corresponding to the lowest specific gravity.
5. Includes 1.6 duration of load increase for wind and seismic. No further duration of load increases permitted. Reduce design values for other load durations as applicable.
6. See Figure 4 for load directions. See Figure 5 and Figure 6 for installation details.
7. Install fastener at an upward angle from the vertical of 20° to 30° (22.5° is optimal) or 90° (See Figure 5 and Figure 6). For installation between 20° and 30°, design values for 22.5° may be used.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC




Figure 4. Uplift and Lateral Load Orientations




Figure 5. Installation of Fasteners at an Angle in Double Top Plate to Truss/Rafter/Joist Applications

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC




Figure 6. Installation of Fasteners in Double Top Plate Perpendicular to Truss/Rafter/Joist Applications

6.9 *Allowable Design Loads – Bottom Plate to Rim Board Connection*

6.9.1 Allowable design loads for lateral resistance parallel to grain in bottom plate to rim board connections are provided in **Table 3**. The connection configuration is shown in **Figure 7**.

6.9.1.1 A Wood Structural Panel (WSP) up $1^1/_8$" thick is permitted between the rim board and the bottom plate, so long as it is independently fastened to the rim board per the building code, and the minimum 2" screw penetration for the Big Timber Screws be met.

6.9.1.2 Double bottom plates are permitted as long as they are independently fastened per the building code, and the minimum 2" screw penetration for the Big Timber Screws be met.

6.9.2 Allowable design loads are applicable to fasteners installed in accordance with **Section 9.5**.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

Table 3. Allowable Shear Loads Parallel to Grain for Bottom Plate to Rim Board Connections

Fastener	Nominal Bottom Plate Thickness	Minimum Penetration into Rim Board (in)	Allowable Shear Loads, Parallel to Grain (lb)[1,2,3]								
			Rim Board Species (Specific Gravity)								
			2x HF/SPF (0.42)			2x DF-L or 1¼" LVL/LSL (0.50)			2x SP (0.55)		
			Bottom Plate Species (Specific Gravity)								
			HF/SPF (0.42)	DF-L (0.50)	SP (0.55)	HF/SPF (0.42)	DF-L (0.50)	SP (0.55)	HF/SPF (0.42)	DF-L (0.50)	SP (0.55)
CTX 14 x 4"	2x	2	120	130	135	130	145	150	135	150	155
CTX 14 x 6"											
BL 14 x 4"			170	200	210	180	220	230	185	230	240
BL 14 x 6"											
SCTX 15 x 4"			155	170	175	170	185	190	175	190	200
SCTX 15 x 6"											

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

1. For wood species with an assigned specific gravity between two of the specific gravities above, use the tabulated values for the next lowest specific gravity. For wood species with an assigned specific gravity greater than or equal to 0.55, use the tabulated value for specific gravity of 0.55.
2. For applications involving members with different specific gravities, use the allowable load corresponding to the lowest specific gravity.
3. Tabulated loads are based on a load duration factor of C_D = 1.00. Loads may be increased for load duration per NDS.




Figure 7. Fastener in Bottom Plate to Rim Board Connection

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

6.10 Where it is anticipated that loads will be applied to a single fastener simultaneously in more than one direction, additional evaluation is required to account for combined effect of these loads using accepted engineering practice.

6.10.1 As needed, consult a professional engineer for complex design conditions.

6.11 Alternative techniques shall be permitted in accordance with accepted engineering practice and experience. These provisions for the use of alternative materials, designs, and methods of construction are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed herein. This includes, but is not limited to, the following areas of engineering: mechanics of materials, structures, building science, and fire science.

7 Certified Performance[29]

7.1 All construction methods shall conform to accepted engineering practices to ensure durable, livable, and safe construction and shall demonstrate acceptable workmanship reflecting journeyman quality of work of the various trades.[30]

7.2 The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.[31]

8 Regulatory Evaluation and Accepted Engineering Practice

8.1 Big Timber Screws comply with the following legislatively adopted regulations and/or accepted engineering practice for the following reasons:

8.1.1 Big Timber Screws were evaluated as an alternate means of attaching metal plate connected wood trusses, rafters, or floor joists to the tops of walls for the purpose of providing uplift and lateral load resistance. The following conditions were evaluated:

8.1.1.1 Withdrawal strength for use as an alternative to toenail connections, metal hurricane and seismic clips/straps, or nails in tension (uplift) load applications.

8.1.1.2 Head pull-through strength for use as an alternative to toenail connections, hurricane and seismic clips/straps, or nails in tension (uplift) load applications.

8.1.1.3 Shear strength for use as an alternative to toenail connections, hurricane and seismic clips/straps, or nails in shear (lateral) loaded applications, either parallel or perpendicular to wood grain.

8.1.2 Big Timber Screws were also evaluated as an alternative means of attaching wall bottom plates to the rim board. The following condition was evaluated:

8.1.2.1 Shear strength to resist shear (lateral) loads applied parallel to the bottom plate and rim board.

8.2 Connections other than those addressed in this section are outside the scope of this report.

8.3 With the exception of SCTX stainless steel screws, use of Big Timber Screws in locations exposed to saltwater or saltwater spray is outside the scope of this report.

8.3.1 SCTX screws are allowed for use in locations exposed to saltwater or saltwater spray.

8.4 Any building code, regulation and/or accepted engineering evaluations (e.g., research reports, duly authenticated reports, etc.) that are conducted for this Listing were performed by DrJ, which is an ISO/IEC 17065 accredited certification body and a professional engineering company operated by RDP or approved sources. DrJ is qualified[32] to practice product and regulatory compliance services within its scope of accreditation and engineering expertise,[33] respectively.

8.5 Engineering evaluations are conducted with DrJ's ANAB accredited ICS code scope of expertise, which is also its areas of professional engineering competence.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

9 Installation

9.1 Installation shall comply with the approved construction documents, the manufacturer installation instructions, this report, and the applicable building code.

9.2 In the event of a conflict between the manufacturer installation instructions and this report, contact the manufacturer for counsel on the proper installation method.

9.3 *Installation Procedure*

9.3.1 CTX and SCTX screws shall be installed using Torx 25 and Torx 30 driver bits, respectively.

9.3.2 BL screws shall be installed with a $^{5}/_{16}$ hex.

9.3.3 Fasteners shall not be struck with a hammer during installation.

9.3.4 Lead holes are not required.

9.3.5 The underside of the fastener head must be installed flush to the surface of the wood member being connected. The fastener must not be overdriven.

9.4 *Truss/Rafter/Joist to Top Plate Connection*

9.4.1 Install Big Timber Screws upward through the wall top plates or wood structural framing member at the bottom corner of the top plates and into the center of the wood truss or rafter. The fastener should be installed at an upward angle from the vertical of 20° to 30° (see **Figure 5**) and should penetrate the wood truss, rafter, or joist within $^{1}/_{4}$" of the centerline. Fasteners located between studs may be installed at a 90° angle (see **Figure 6**).

9.4.1.1 If the wood truss, rafter, or floor joist is located directly over a top plate splice, offset the fastener $^{1}/_{4}$" to one side of the splice. Note that the splice may be in either top plate.

9.4.2 Minimum penetration for truss/rafter/joist to top plate connections is 2.5".

9.4.3 Minimum requirements for fasteners spacing, edge distance, and end distance shall be in accordance with **Table 4**.

Table 4. Minimum Spacing, Edge Distance, and End Distance Requirements

Connection Geometry	Minimum Spacing/Distance[1,2] (in)		
	CTX14	BL14	SCTX15
Edge Distance – Load in any direction	$^{1}/_{2}$	$^{1}/_{2}$	$^{5}/_{8}$
End Distance – Load parallel to grain, towards end	$2^{1}/_{2}$	$2^{7}/_{8}$	$3^{1}/_{8}$
End Distance – Load parallel to grain, away from end	$1^{5}/_{8}$	$1^{7}/_{8}$	$2^{1}/_{8}$
End Distance – Load perpendicular to grain	$1^{5}/_{8}$	$1^{7}/_{8}$	$3^{1}/_{8}$
Spacing between Fasteners in a Row – Parallel to grain	$2^{1}/_{2}$	$2^{7}/_{8}$	$3^{1}/_{8}$
Spacing between Fasteners in a Row – Perpendicular to grain	$1^{5}/_{8}$	$1^{7}/_{8}$	$2^{1}/_{8}$
Spacing between Rows of Fasteners – In-line	$^{7}/_{8}$	1	$1^{1}/_{8}$
Spacing between Rows of Fasteners – Staggered	$^{1}/_{2}$	$^{1}/_{2}$	$^{5}/_{8}$

SI: 1 in = 25.4 mm

1. Edge distances, end distances, and spacing of fasteners shall be sufficient to prevent splitting of the wood or as shown in this table, whichever is the more restrictive.
2. Values for *"Spacing between Rows of Fasteners – Staggered"* apply where the fasteners in adjacent rows are offset by one half of the *"Spacing between Fasteners in a Row"*.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

9.5 *Bottom Plate to Rim Board Connection*

9.5.1 Install Big Timber Screws downward at a 90° angle, a minimum of 1/2" from outside face of wall, through the plate, and into the rim board (see **Figure 7**).

9.5.2 Minimum penetration for bottom plate to rim board connections is 2.0".

9.5.2.1 Minimum requirements for fastener spacing, edge distance, and end distance shall be in accordance with **Table 4**.

10 Substantiating Data

10.1 Testing has been performed under the supervision of a professional engineer and/or under the requirements of ISO/IEC 17025 as follows:

10.1.1 Assembly testing in accordance with ASTM D1761

10.2 Connection design value calculations by DrJ Engineering, LLC in accordance with the NDS and accepted engineering practice.

10.3 Properties for Big Timber CTX Construction Lag Screws are from Report Number 1907-01.

10.4 Properties for Big Timber BL Log, Timber and Landscape Screws are from Report Number 1907-02.

10.5 Properties for Big Timber SCTX Stainless Steel Screws are from Report Number 1911-02.

10.6 Information contained herein may include the result of testing and/or data analysis by sources that are approved agencies, approved sources, and/or an RDP. Accuracy of external test data and resulting analysis is relied upon.

10.7 Where applicable, testing and/or engineering analysis are based upon provisions that have been codified into law through state or local adoption of regulations and standards. The developers of these regulations and standards are responsible for the reliability of published content. DrJ's engineering practice may use a regulation-adopted provision as the control. A regulation-endorsed control versus a simulation of the conditions of application to occur establishes a new material as being equivalent to the regulatory provision in terms of quality, strength, effectiveness, fire resistance, durability, and safety.

10.8 The accuracy of the provisions provided herein may be reliant upon the published properties of raw materials, which are defined by the grade mark, grade stamp, mill certificate, or duly authenticated reports from approved agencies and/or approved sources provided by the supplier. These are presumed to be minimum properties and relied upon to be accurate. The reliability of DrJ's engineering practice, as contained in this duly authenticated report, may be dependent upon published design properties by others.

10.9 *Testing and Engineering Analysis*

10.9.1 The strength, rigidity, and/or general performance of component parts and/or the integrated structure are determined by suitable tests that simulate the actual conditions of application that occur and/or by accepted engineering practice and experience.[34]

10.10 Where additional condition of use and/or regulatory compliance information is required, please search for Big Timber Screws on the DrJ Certification website.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

11 Findings

11.1 As outlined in **Section 6**, Big Timber Screws have performance characteristics that were tested and/or meet applicable regulations. In addition, they are suitable for use pursuant to its specified purpose.

11.2 When used and installed in accordance with this duly authenticated report and the manufacturer installation instructions, Big Timber Screws shall be approved for the following applications:

11.2.1 An acceptable alternative means of attaching metal plate connected wood trusses, rafters or floor joists to the tops of walls to provide uplift and lateral load resistance due to wind and seismic forces as provided in **Table 2**.

11.2.2 An acceptable alternative means of attached wall bottom plates to rim boards to provide lateral load resistance parallel to the bottom plates as provided in **Table 3**.

11.3 Unless exempt by state statute, when Big Timber Screws are to be used as a structural and/or building envelope component in the design of a specific building, the design shall be performed by an RDP.

11.4 Any application specific issues not addressed herein can be engineered by an RDP. Assistance with engineering is available from Big Timber or Western Builders Supply.

11.5 IBC Section 104.2.3[35] (IRC Section R104.2.2[36] and IFC Section 104.2.3[37] are similar) in pertinent part state:

> 104.2.3 Alternative Materials, Design and Methods of Construction and Equipment. The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code, provided that any such alternative is not specifically prohibited by this code and has been approved.

11.6 **Approved:**[38] Building regulations require that the building official shall accept duly authenticated reports.[39]

11.6.1 An approved agency is *"approved"* when it is ANAB ISO/IEC 17065 accredited.

11.6.2 An approved source is *"approved"* when an RDP is properly licensed to transact engineering commerce.

11.6.3 Federal law, Title 18 US Code Section 242, requires that, where the alternative product, material, service, design, assembly, and/or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved. Denial without written reason deprives a protected right to free and fair competition in the marketplace.

11.7 DrJ is a licensed engineering company, employs licensed RDPs and is an ANAB Accredited Product Certification Body – Accreditation #1131.

11.8 Through the IAF Multilateral Arrangement (MLA), this duly authenticated report can be used to obtain product approval in any jurisdiction or country because all ANAB ISO/IEC 17065 duly authenticated reports are equivalent.[40]

12 Conditions of Use

12.1 As defined in **Section 6**, where material and/or engineering mechanics properties are created for load resisting design purposes, the resistance to the applied load shall not exceed the ability of the defined properties to resist those loads using the principles of accepted engineering practice.

12.2 For conditions not covered in this report, connections shall be designed in accordance with accepted engineering practice.

12.3 As listed herein, Big Timber Screws shall be used:

12.3.1 Only in sawn lumber members that have a moisture content of less than or equal to nineteen percent (19%).

12.4 Use of fasteners in locations exposed to saltwater or saltwater spray is outside the scope of this report, with the exception of the SCTX screws where exposure to saltwater or saltwater spray is allowed.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

12.5 When required by adopted legislation and enforced by the building official, also known as the Authority Having Jurisdiction (AHJ) in which the project is to be constructed:

12.5.1 Any calculations incorporated into the construction documents shall conform to accepted engineering practice and, when prepared by an approved source, shall be approved when signed and sealed.

12.5.2 This report and the installation instructions shall be submitted at the time of permit application.

12.5.3 At a minimum, these innovative products shall be installed per **Section 9**.

12.5.4 The review of this report by the AHJ shall comply with IBC Section 104.2.3.2 and IBC Section 105.3.1.

12.5.5 These innovative products have an internal quality control program and a third party quality assurance program in accordance with IBC Section 104.7.2, IBC Section 110.4, IBC Section 1703, IRC Section R104.7.2, and IRC Section R109.2.

12.5.6 The application of these innovative products in the context of this report is dependent upon the accuracy of the construction documents, implementation of installation instructions, inspection as required by IBC Section 110.3, IRC Section R109.2, and any other regulatory requirements that may apply.

12.6 The approval of this report by the AHJ shall comply with IBC Section 1707.1, where legislation states in part, *"the building official shall make, or cause to be made, the necessary tests and investigations; or the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in Section 104.2.3"*, all of IBC Section 104, and IBC Section 105.3.

12.7 Design loads shall be determined in accordance with the regulations adopted by the jurisdiction in which the project is to be constructed and/or by the building designer (i.e., owner or RDP).

12.8 The actual design, suitability, and use of this report for any particular building, is the responsibility of the owner or the authorized agent of the owner.

13 Identification

13.1 Big Timber Screws (CTX Construction Lag Screws, BL Log, Timber and Landscape Screws, and SCTX Construction Lag Stainless Steel Screws), as listed in **Section 1.1**, are identified by a label on the board or packaging material bearing the manufacturer name, product name, this report number, and other information to confirm code compliance.

13.2 Additional technical information can be found at www.marmonfasteners.com/big-timber-us.

14 Review Schedule

14.1 This report is subject to periodic review and revision. For the latest version, visit www.drjcertification.org.

14.2 For information on the status of this report, please contact DrJ Certification.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

Notes

1 For more information, visit drjcertification.org or call us at 608-310-6748.

2 2021 IRC Section R317.3

3 2018 IBC Section 2304.10.5

4 2021 IRC Section R317.3

5 Capitalized terms and responsibilities are defined pursuant to the applicable building code, applicable reference standards, the latest edition of TPI 1, the NDS, AISI S202, US professional engineering law, Canadian building code, Canada professional engineering law, Qualtim External Appendix A: Definitions/Commentary, Qualtim External Appendix B: Project/Deliverables, Qualtim External Appendix C: Intellectual Property and Trade Secrets, definitions created within Design Drawings and/or definitions within Reference Sheets. Beyond this, terms not defined shall have ordinarily accepted meanings as the context implies. Words used in the present tense include the future; words stated in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural, the singular.

6 https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1702

7 Alternative Materials, Design and Methods of Construction and Equipment: The provisions of any regulation code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by a regulation. Please review https://www.justice.gov/atr/mission and https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#104.2.3

8 https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1706.2:~:text=the%20design%20strengths%20and%20permissible%20stresses%20shall%20be%20established%20by%20tests

9 The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design of accepted engineering practice. https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1706.1:~:text=Conformance%20to%20Standards-,The%20design%20strengths%20and%20permissible%20stresses,-of%20any%20structural

10 https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1:~:text=the%20building%20official%20shall%20make%2C%20or%20cause%20to%20be%20made%2C%20the%20necessary%20tests%20and%20investigations%3B%20or%20the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies%20in%20respect%20to%20the%20quality%20and%20manner%20of%20use%20of%20new%20materials%20or%20assemblies%20as%20provided%20for%20in%20Section%20104.2.3.

11 https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1703.4.2

12 https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#approved_agency

13 https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#approved_source

14 https://www.law.cornell.edu/uscode/text/18/1832 (b) Any organization that commits any offense described in subsection (a) shall be fined not more than the greater of $5,000,000 or 3 times the value of the stolen trade secret to the organization, including expenses for research and design and other costs of reproducing the trade secret that the organization has thereby avoided. The federal government and each state have a public records act. To follow DTSA and comply state public records and trade secret legislation requires approval through ANAB ISO/IEC 17065 accredited certification bodies or approved sources. For more information, please review this website: Intellectual Property and Trade Secrets.

15 https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional AND https://apassociation.org/list-of-engineering-boards-in-each-state-archive/

16 https://www.cbitest.com/accreditation/

17 https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#104.1:~:text=directed%20to%20enforce%20the%20provisions%20of%20this%20code

18 https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#104.2.3 AND https://up.codes/viewer/mississippi/ibc-2024/chapter/1/scope-and-administration#105.3.1

19 https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1

20 https://iaf.nu/en/about-iaf-mla/#:~:text=Once%20an%20accreditation%20body%20is%20a%20signatory%20of%20the%20IAF%20MLA%2C%20it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope

21 True for all ANAB accredited product evaluation agencies and all International Trade Agreements.

22 https://www.justice.gov/crt/deprivation-rights-under-color-law AND https://www.justice.gov/atr/mission

23 Unless otherwise noted, the links referenced herein use un-amended versions of the 2024 International Code Council (ICC) 2024 International Code Council (ICC) model codes as foundation references. Mississippi versions of the IBC 2024 and the IRC 2024 are un-amended. This material, product, design, service and/or method of construction also complies with the 2000-2012 versions of the referenced codes and the standards referenced therein. As pertinent to this technical and code compliance evaluation, CBI and/or DrJ staff have reviewed any state or local regulatory amendments to assure this report is in compliance.

24 See Adoptions by Publisher for the latest adoption of a non-amended or amended model code by the local jurisdiction. https://up.codes/codes/general

25 See Adoptions by Publisher for the latest adoption of a non-amended or amended model code by state. https://up.codes/codes/general

26 https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3282/subpart-A/section-3282.14

27 https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280

28 https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2(Listed%20or%20certified); https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#listed AND https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#labeled

29 https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1703.4

30 https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#:~:text=All%20construction%20methods%20shall%20be%20in%20conformance%20with%20accepted%20engineering%20practices%20to%20insure%20durable%2C%20livable%2C%20and%20safe%20housing%20and%20shall%20demonstrate%20acceptable%20workmanship%20reflecting%20journeyman%20quality%20of%20work%20of%20the%20various%20trades

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC

[31] https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#:~:text=The%20strength%20and%20rigidity%20of%20the%20component%20parts%20and/or%20the%20integrated%20structure%20shall%20be%20determined%20by%20engineering%20analysis%20or%20by%20suitable%20load%20tests%20to%20simulate%20the%20actual%20loads%20and%20conditions%20of%20application%20that%20occur

[32] Qualification is performed by a legislatively defined Accreditation Body. ANSI National Accreditation Board (ANAB) is the largest independent accreditation body in North America and provides services in more than 75 countries. DrJ is an ANAB accredited product certification body.

[33] https://anabpd.ansi.org/Accreditation/product-certification/AllDirectoryDetails?prgID=1&orgID=2125&statusID=4#:~:text=Bill%20Payment%20Date-,Accredited%20Scopes,-13%20ENVIRONMENT.%20HEALTH

[34] See Code of Federal Regulations (CFR) Title 24 Subtitle B Chapter XX Part 3280 for definition: https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280

[35] 2021 IBC Section 104.11

[36] 2021 IRC Section R104.11

[37] 2018: https://up.codes/viewer/wyoming/ifc-2018/chapter/1/scope-and-administration#104.9 AND 2021: https://up.codes/viewer/wyoming/ibc-2021/chapter/1/scope-and-administration#104.11

[38] Approved is an adjective that modifies the noun after it. For example, Approved Agency means that the Agency is accepted officially as being suitable in a particular situation. This example conforms to IBC/IRC/IFC Section 201.4 (https://up.codes/viewer/mississippi/ibc-2024/chapter/2/definitions#201.4) where the building code authorizes sentences to have an ordinarily accepted meaning such as the context implies.

[39] https://up.codes/viewer/mississippi/ibc-2024/chapter/17/special-inspections-and-tests#1707.1

[40] Multilateral approval is true for all ANAB accredited product evaluation agencies and all International Trade Agreements.

Information contained in this report was developed using report holder's confidential intellectual property (IP) and trade secrets (TS), which is protected by Defend Trade Secrets Act 2016, © DrJ Engineering, LLC