



Listing and Technical Evaluation Report

Report No: 2304-120



Issue Date: November 20, 2023

Revision Date: November 20, 2023

Subject to Renewal: January 1, 2025

Use of EcoSmart™ Studs in Wood Framed Construction

Trade Secret Report Holder:

ViCa3 Ventures

Phone: 612-887-5200

Website: www.ecosmartstud.com

CSI Designations:

DIVISION: 06 00 00 - WOOD, PLASTICS AND COMPOSITES

Section: 06 10 00 - Rough Carpentry

Section: 06 11 00 - Wood Framing

Section: 06 17 00 - Shop-Fabricated Structural Wood

1 Innovative Product Evaluated¹

1.1 EcoSmart™ Stud

2 Product Description and Materials

2.1 The innovative product evaluated in this report is shown in **Figure 1** and **Table 1**.



2x6 EcoSmart Stud



2x8 EcoSmart Stud



2x6 Auxiliary EcoSmart Stud

Figure 1. EcoSmart Stud Products

Table 1. Product Information

| Product | Description | Thickness |
|-----------------------------|--|-----------|
| 2x6 EcoSmart Stud | EcoSmart Stud (2x6) is a specially cut lumber framing member that provides the ability to increase thermal resistance in wall assemblies and are lighter weight than solid sawn lumber. One row of slots cut through the stud allows for insulation and wiring to be installed without boring and drilling. Additionally, nubs incorporated in the exterior side of the EcoSmart stud allow insulation to be installed around the stud. | 1.5 in |
| 2x8 EcoSmart Stud | EcoSmart Stud (2x8) is a specially cut lumber framing member that provides the ability to increase thermal resistance in wall assemblies and are lighter weight than solid sawn lumber. Two rows of slots cut through the stud allow for insulation and wiring to be installed without boring and notching of the studs. Additionally, nubs incorporated in the exterior side of the EcoSmart stud allow insulation to be installed around the stud. | 1.5 in |
| 2x6 Auxiliary EcoSmart Stud | 2x6 Auxiliary EcoSmart Stud is a specially cut lumber framing member that provides the ability to increase thermal resistance in wall assemblies and are lighter weight than solid sawn lumber. Two rows of slots cut through the stud allow insulation and wiring to be installed without additional boring or drilling. There are no nubs on the Auxiliary EcoSmart Stud allow use as rough opening framing where a solid surface is needed for nailing fins on windows and doors. | 1.5 in |

2.2 As needed, review material properties for design in Section 6 and to regulatory evaluation in Section 8.

3 Definitions

- 3.1 New Materialsⁱⁱ are defined as building materials, equipment, appliances, systems or methods of construction not provided for by prescriptive and/or legislatively adopted regulations, known as alternative materials.ⁱⁱⁱ The design strengths and permissible stresses shall be established by tests^{iv} and/or engineering analysis.^v
- 3.2 Duly Authenticated Reports^{vi} and Research Reports^{vii} are test reports and related engineering evaluations, which are written by an approved agency^{viii} and/or an approved source.^{ix}
 - 3.2.1 These reports contain intellectual property and/or trade secrets, which are protected by the Defend Trade Secrets Act (DTSA).^x
- 3.3 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is listed in the ANAB directory.
- 3.4 An approved source is “approved” when a professional engineer (i.e., Registered Design Professional [RDP]) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.^{xi}
- 3.5 Testing and/or inspections conducted for this Duly Authenticated Report were performed by an ISO/IEC 17025 accredited testing laboratory, an ISO/IEC 17020 accredited inspection body and/or a licensed RDP.
 - 3.5.1 The Center for Building Innovation (CBI) is ANAB^{xii} ISO/IEC 17025 and ISO/IEC 17020 accredited.
- 3.6 The regulatory authority shall enforce^{xiii} the specific provisions of each legislatively adopted regulation. If there is a non-conformance, the specific regulatory section and language of the non-conformance shall be provided in writing^{xiv} stating the nonconformance and the path to its cure.
- 3.7 The regulatory authority shall accept Duly Authenticated Reports from an approved agency and/or an approved source with respect to the quality and manner of use of new materials or assemblies as provided for in regulations regarding the use of alternative materials, designs or methods of construction.^{xv}



- 3.8 ANAB is an International Accreditation Forum (IAF) Multilateral Recognition Arrangement (MLA) signatory where recognition of certificates, validation and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA with the appropriate scope, shall be approved.^{xvi} Therefore, all ANAB ISO/IEC 17065 Duly Authenticated Reports are approval equivalent.^{xvii}
- 3.9 Approval equity is a fundamental commercial and legal principle.^{xviii}

4 Applicable Standards for the Listing; Regulations for the Regulatory Evaluation^{xix}

4.1 Standards

- 4.1.1 *ANSI/AWC NDS: National Design Specification (NDS) for Wood Construction*
 - 4.1.2 *ANSI/AWC SDPWS: Special Design Provisions for Wind and Seismic*
 - 4.1.3 *ASTM D198: Standard Test Methods of Static Tests of Lumber in Structural Sizes*
 - 4.1.4 *ASTM D5456: Standard Specification for Evaluation of Structural Composite Lumber Products*
 - 4.1.5 *ASTM D4442: Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials*
 - 4.1.6 *ASTM D2395: Standard Test Methods for Density and Specific Gravity (Relative Density) of Wood and Wood-Based Materials*
 - 4.1.7 *ASTM E564: Standard Practice for Static Load Test for Shear Resistance of Framed Walls for Buildings*
- 4.2 Structural performance for shear wall assemblies used as lateral force resisting systems in Seismic Design Categories A through F, have been tested and evaluated in accordance with the following standards:
- 4.2.1 *ASCE/SEI 7: Minimum Design Loads and Associated Criteria for Buildings and Other Structures*
 - 4.2.2 *ASTM D7989: Standard Practice for Demonstrating Equivalent In-Plane Lateral Seismic Performance to Wood-Frame Shear Walls Sheathed with Wood Structural Panels*
 - 4.2.3 *ASTM E72: Standard Test Methods of Conducting Strength Tests of Panels for Building Construction*
 - 4.2.4 *ASTM E564: Standard Practice for Static Load Test for Shear Resistance of Framed Walls for Buildings*
 - 4.2.5 *ASTM E2126: Standard Test Methods for Cyclic (Reversed) Load Test for Shear Resistance of Vertical Elements of the Lateral Force Resisting Systems for Buildings*
- 4.2.5.1 ASTM D7989 is accepted engineering practice used to establish Seismic Design Coefficients (SDCs). Test data generated by ISO/IEC 17025 approved agencies and/or professional engineers and all associated professional engineering evaluations which use ASTM D7989 as their basis, are defined as intellectual property and/or trade secrets and are also defined as an Independent Design Review (i.e., Listings, certified reports, duly authenticated reports from approved agencies and/or research reports prepared by approved agencies and/or approved sources).

4.3 Regulations

- 4.3.1 *IBC – 15, 18, 21: International Building Code®*
- 4.3.2 *IRC – 15, 18, 21: International Residential Code®*
- 4.3.3 *IECC – 15, 18, 21: International Energy Conservation Code®*

5 Listed^{xx}

- 5.1 A nationally recognized testing laboratory such as CBI, states that the materials, designs, methods of construction and/or equipment have met nationally recognized standards and/or have been tested and found suitable for use in a specified manner.

6 Tabulated Properties Generated from Nationally Recognized Standards

6.1 General Provisions

- 6.1.1 Except as otherwise described in this TER, EcoSmart™ Studs shall be installed in accordance with the applicable building codes listed in Section 4.

6.2 Prescriptive Provisions

- 6.2.1 Wall assemblies constructed with EcoSmart™ Studs are an alternative to solid sawn lumber wall assemblies.
- 6.2.2 EcoSmart™ Studs used as wall framing members shall be fastened as specified in the [IRC Table R602.3\(1\)](#).
- 6.2.3 EcoSmart™ Studs may be used on braced wall lines with $7/16$ " WSP sheathing as an equivalent alternative to Method WSP and CS-WSP of the IRC, when installed in accordance with [IRC Section R602.10](#) and this report.
- 6.2.4 Holes and notches in the flange material are not permitted.
- 6.2.5 The Auxiliary 2x6 EcoSmart™ Studs are designed to be used for rough opening framing where a solid surface is required for nailing fenestration (windows and doors) flanges to the face of the wall. Use Auxiliary 2x6 EcoSmart™ Studs at all window and door rough opening jambs when flanged fenestrations are used.
- 6.2.6 The minimum aspect ratio shall be x:x or minimum panel width shall be xx", whichever is greater.
- 6.2.7 *Simplified IRC Bracing Provisions:*
- 6.2.7.1 EcoSmart™ Studs are permitted to be used in accordance with the IRC simplified bracing method of [IRC Section R602.12](#) and **Table 2**.

Table 2. EcoSmart Stud Simplified Bracing Table for Wall Assemblies
Constructed with Wood Structural Panels^{1,2,3,4,5,6,7,8}

| Wall Framing Product | Ultimate Design Wind Speed (mph) | Story Level | Eave to Ridge Height (ft) | Minimum Number of Bracing Units Required (Long Side) | | | | | | Minimum Number of Bracing Units Required (Short Side) | | | | | |
|----------------------|----------------------------------|---|---------------------------|--|----|----|----|----|----|---|----|----|----|----|----|
| | | | | Length of Short Side (ft) | | | | | | Length of Long Side (ft) | | | | | |
| | | | | 10 | 20 | 30 | 40 | 50 | 60 | 10 | 20 | 30 | 40 | 50 | 60 |
| EcoSmart Stud | 115 | One Story or Top of Two or Three Story | 10 | 1 | 2 | 2 | 3 | 4 | 4 | 1 | 2 | 2 | 3 | 4 | 4 |
| | | First of Two Story or Second of Three Story | | 2 | 3 | 4 | 5 | 6 | 7 | 2 | 3 | 4 | 5 | 6 | 7 |
| | | First of Three Story | | 3 | 4 | 6 | 7 | 9 | 11 | 3 | 4 | 6 | 7 | 9 | 11 |
| | | One Story or Top of Two or Three Story | 15 | 1 | 2 | 3 | 4 | 5 | 5 | 1 | 2 | 3 | 4 | 5 | 5 |
| | | First of Two Story or Second of Three Story | | 2 | 3 | 5 | 6 | 7 | 9 | 2 | 3 | 5 | 6 | 7 | 9 |
| | | First of Three Story | | 3 | 5 | 6 | 8 | 10 | 12 | 3 | 5 | 6 | 8 | 10 | 12 |
| | 130 | One Story or Top of Two or Three Story | 10 | 1 | 2 | 3 | 4 | 4 | 5 | 1 | 2 | 3 | 4 | 4 | 5 |
| | | First of Two Story or Second of Three Story | | 2 | 4 | 5 | 7 | 8 | 9 | 2 | 4 | 5 | 7 | 8 | 9 |
| | | First of Three Story | | 3 | 5 | 7 | 9 | 11 | 14 | 3 | 5 | 7 | 9 | 11 | 14 |

Table 2. EcoSmart Stud Simplified Bracing Table for Wall Assemblies
Constructed with Wood Structural Panels^{1,2,3,4,5,6,7,8}

| Wall Framing Product | Ultimate Design Wind Speed (mph) | Story Level | Eave to Ridge Height (ft) | Minimum Number of Bracing Units Required (Long Side) | | | | | | Minimum Number of Bracing Units Required (Short Side) | | | | | |
|----------------------|----------------------------------|---|---------------------------|--|----|----|----|----|----|---|----|----|----|----|----|
| | | | | Length of Short Side (ft) | | | | | | Length of Long Side (ft) | | | | | |
| | | | | 10 | 20 | 30 | 40 | 50 | 60 | 10 | 20 | 30 | 40 | 50 | 60 |
| | | One Story or Top of Two or Three Story | 15 | 2 | 3 | 4 | 5 | 5 | 7 | 2 | 3 | 4 | 5 | 5 | 7 |
| | | First of Two Story or Second of Three Story | | 2 | 4 | 6 | 7 | 9 | 10 | 2 | 4 | 6 | 7 | 9 | 10 |
| | | First of Three Story | | 3 | 6 | 8 | 10 | 13 | 15 | 3 | 6 | 8 | 10 | 13 | 15 |

SI: 1 in = 25.4 mm

- This simplified bracing table is based on the provisions of [IRC Section R602.12](#). All provisions therein shall be observed, except that this table shall replace [IRC Table R602.12.4](#), and EcoSmart Studs shall replace the wall stud framing.
- Interpolation shall not be permitted.
- Cripple walls or wood-framed basement walls in a walk-out condition shall be designated as the first story and the stories above shall be re-designated as the second and third stories respectively, and shall be prohibited in a three-story structure.
- Actual lengths of the sides of the circumscribed rectangle shall be rounded to the next highest unit of 10 when using [Table 2](#).
- For Exposure Category C, multiply bracing units by a factor of 1.20 for a one-story building, 1.30 for a two-story building, and 1.40 for a three-story building. Actual length of the sides of the circumscribed rectangle shall be rounded to the next highest unit of 10 when using [Table 2](#).
- Maximum stud spacing is 24" o.c.
- $\frac{7}{16}$ " wood structural panels attached with minimum $2\frac{3}{8}$ " x 0.113" nails fastened 6" o.c. at panel edges and 12" o.c. in the field.
- Minimum $\frac{1}{2}$ " gypsum wallboard (GWB) attached to the interior side of the wall in accordance with [IRC Section R702.3.5](#) and [IRC Table R702.3.5](#).

6.2.8 IRC WSP and CS-WSP Bracing Methods Using EcoSmart Stud Equivalency Factor:

- 6.2.8.1 Required braced wall panel lengths for wall assemblies constructed with EcoSmart™ Studs shall be as determined by the equivalency factor shown in [Table 3](#), [IRC Table R602.10.3\(1\)](#) and [IRC Table R602.10.3\(2\)](#) including all footnotes.
- 6.2.8.2 The braced wall line length equivalency factors in [Table 3](#) are based on equivalency testing and are used to comply with Method WSP and CS-WSP of the IRC.
- 6.2.8.3 EcoSmart™ Stud tested equivalency factors in [Table 3](#) allow the user to determine the length of bracing required, by multiplying the factor from [Table 3](#) by the length shown in the WSP or CS columns in [IRC Table R602.10.3\(1\)](#), as modified by all applicable factors in [IRC Table R602.10.3\(2\)](#), respectively.
- 6.2.8.4 All IRC prescriptive bracing minimums, spacing requirements and rules must also be met.
- 6.2.8.5 Where a building, or portion thereof, does not comply with one or more of the bracing requirements within the prescriptive section of the IRC, those portions shall be designed and constructed in accordance with [IRC Section R301.1](#).

Table 3. IRC Braced Wall Panel Equivalency for EcoSmart Stud Wall Assemblies^{1,2}

| Product | Maximum Stud Spacing (in) | Sheathing Fastener | Maximum Fastener Spacing (edge:field) (in) | Gypsum Wallboard ³ Fastening Spacing (blocked or unblocked) (edge:field) | Wind |
|----------------|---------------------------|--|--|---|---|
| | | | | | SPF Framing |
| | | | | | Equivalency Factors ³ to IRC WSP or CS-WSP |
| EcoSmart Studs | 24 o.c. | 2 ³ / ₈ " x 0.113" Nails | 6:12 | As required by IRC Table R702.3.5 | 1.39 |

SI: 1 in = 25.4 mm

- EcoSmart stud tested equivalency factors allow the user to determine the length of bracing required, by multiplying the factor by the length of bracing shown in the WSP or CS-WSP columns in [IRC Table R602.10.3\(1\)](#) and [IRC Table R602.10.3\(3\)](#) as modified by all applicable factors in [IRC Table R602.10.3\(2\)](#) and [IRC Table R602.10.3\(4\)](#), respectively.
- Valid for single top plate (advanced framing method) wall installations or double top plate wall installations.
- When used, GWB shall be installed according to the provision listed in [IRC Table R702.3.5](#).

6.2.9 IRC WSP and CS-WSP Bracing Methods using EcoSmart Stud Prescriptive Bracing Table:

- 6.2.9.1 EcoSmart™ Studs may be used on braced wall lines as an equivalent alternative to IRC Method WSP when installed in accordance with [IRC Section R602.10](#) and this report.
- 6.2.9.2 Wind design, required braced wall panel lengths for EcoSmart™ Stud wall assemblies shall be as shown in **Table 4** and shall be used in conjunction with [IRC Table R602.10.3\(2\)](#), which provides the required adjustments.
- 6.2.9.3 For seismic design, EcoSmart™ Stud wall assemblies are permitted in all buildings constructed under the provisions of the IRC in Seismic Design Categories (SDCs) A and B. In addition, EcoSmart™ Stud wall assemblies are permitted in detached buildings constructed under the provisions of the IRC in SDC C using the bracing lengths in **Table 4**.

Table 4. Required Bracing Lengths for EcoSmart Stud Wall Assemblies – Wind^{1,2,3,4}

| Condition | Braced Wall Line Spacing (ft) | Minimum Total Length (ft) of Braced Wall Panels Required Along Each Braced Wall Line | | | | | | | | | | | |
|---|-------------------------------|--|-------|-------|-------|-------|-------|----------------------|-------|-------|-------|-------|-------|
| | | Intermittent Sheathing | | | | | | Continuous Sheathing | | | | | |
| | | Ultimate Design Wind Speed, V_{ult} (mph) | | | | | | | | | | | |
| | | < 95 | ≤ 110 | ≤ 115 | ≤ 120 | ≤ 130 | ≤ 140 | < 95 | ≤ 110 | ≤ 115 | ≤ 120 | ≤ 130 | ≤ 140 |
| One Story or the Top of Two or Three Stories | 10 | 2.1 | 2.8 | 2.8 | 3.5 | 3.5 | 4.2 | 2.1 | 2.1 | 2.8 | 2.8 | 3.5 | 3.5 |
| | 20 | 3.5 | 4.9 | 4.9 | 5.6 | 7.0 | 7.6 | 3.5 | 4.2 | 4.9 | 4.9 | 5.6 | 7.0 |
| | 30 | 5.6 | 7.0 | 7.6 | 8.3 | 9.7 | 11.1 | 4.9 | 6.3 | 6.3 | 7.0 | 8.3 | 9.7 |
| | 40 | 7.0 | 9.0 | 9.7 | 11.1 | 12.5 | 14.6 | 5.6 | 7.6 | 8.3 | 9.0 | 10.4 | 12.5 |
| | 50 | 8.3 | 11.1 | 12.5 | 13.2 | 15.3 | 18.1 | 7.0 | 9.7 | 10.4 | 11.1 | 13.2 | 15.3 |
| | 60 | 9.7 | 13.2 | 14.6 | 16.0 | 18.1 | 20.9 | 8.3 | 11.1 | 12.5 | 13.2 | 15.3 | 18.1 |
| First Story of Two Stories or Second Story of Three Stories | 10 | 4.2 | 4.9 | 5.6 | 6.3 | 7.0 | 8.3 | 3.5 | 4.2 | 4.9 | 4.9 | 6.3 | 7.0 |
| | 20 | 7.0 | 9.0 | 10.4 | 11.1 | 13.2 | 15.3 | 6.3 | 7.6 | 9.0 | 9.7 | 11.1 | 12.5 |
| | 30 | 9.7 | 13.2 | 14.6 | 16.0 | 18.8 | 21.5 | 8.3 | 11.1 | 12.5 | 13.2 | 16.0 | 18.1 |
| | 40 | 13.2 | 17.4 | 18.8 | 20.9 | 24.3 | 27.8 | 11.1 | 14.6 | 16.0 | 17.4 | 21.5 | 23.6 |
| | 50 | 16.0 | 21.5 | 22.9 | 25.0 | 29.9 | 34.1 | 13.9 | 18.1 | 19.5 | 21.5 | 25.0 | 29.2 |
| | 60 | 18.8 | 25.0 | 27.8 | 29.9 | 34.8 | 40.3 | 16.0 | 21.5 | 23.6 | 25.7 | 29.9 | 34.8 |
| | 10 | 5.6 | 7.6 | 8.3 | 9.0 | 10.4 | 11.8 | 4.9 | 6.3 | 7.0 | 7.6 | 9.0 | 10.4 |

Table 4. Required Bracing Lengths for EcoSmart Stud Wall Assemblies – Wind^{1,2,3,4}

| Condition | Braced Wall Line Spacing (ft) | Minimum Total Length (ft) of Braced Wall Panels Required Along Each Braced Wall Line | | | | | | | | | | | |
|------------------------------|-------------------------------|--|-------|-------|-------|-------|-------|----------------------|-------|-------|-------|-------|-------|
| | | Intermittent Sheathing | | | | | | Continuous Sheathing | | | | | |
| | | Ultimate Design Wind Speed, V_{ult} (mph) | | | | | | | | | | | |
| | | < 95 | ≤ 110 | ≤ 115 | ≤ 120 | ≤ 130 | ≤ 140 | < 95 | ≤ 110 | ≤ 115 | ≤ 120 | ≤ 130 | ≤ 140 |
| First Story of Three Stories | 20 | 10.4 | 13.9 | 15.3 | 16.0 | 18.8 | 22.2 | 9.0 | 11.8 | 12.5 | 13.9 | 16.0 | 18.8 |
| | 30 | 14.6 | 19.5 | 21.5 | 23.6 | 27.1 | 32.0 | 12.5 | 16.7 | 18.1 | 20.2 | 23.6 | 27.1 |
| | 40 | 18.8 | 25.7 | 27.8 | 30.6 | 35.4 | 41.0 | 16.0 | 21.5 | 23.6 | 25.7 | 30.6 | 34.8 |
| | 50 | 23.6 | 31.3 | 34.1 | 37.5 | 43.8 | 50.7 | 20.2 | 26.4 | 29.2 | 32.0 | 36.8 | 43.1 |
| | 60 | 27.8 | 36.8 | 40.3 | 44.5 | 52.1 | 59.8 | 23.6 | 32.0 | 34.8 | 37.5 | 43.8 | 50.7 |

SI: 1 in = 25.4 mm, 1 mph = 1.61 km/h

- Assemblies consist of EcoSmart studs spaced a maximum of 24" o.c. and fastened with 2³/₈" x 0.113" nails spaced 6":12" (edge:field) per Section 9.
- Demonstrates equivalency to [IRC Table R602.10.3\(1\)](#). All adjustment factors from [IRC Table R602.10.3\(2\)](#) shall be applied. A minimum of 1/2" gypsum sheathing shall be applied to the interior side of the wall assembly and fastened with a minimum 5d cooler nails or 1 1/4" #6 types W or S screws in accordance with [IRC Section R703.2](#).
- Bracing lengths are the results of comparative equivalency testing and analysis using both tested and published design values as points of comparison. DrJ relies upon the design values published in the codes and standards listed in Section 4 that are adopted into law and that the manufacturer of those products stand behind. DrJ performs all equivalency analysis based on legally defined design values, the responsibility for which is the manufacturer of those products or the members of the associations that publish those design values.
- Linear interpolation is permitted.

6.3 Performance-Based Wood-Framed Construction

- 6.3.1 Wall assemblies using EcoSmart™ Studs shall be designed using the properties shown in **Table 5** or as otherwise permitted in this TER.
- 6.3.2 The design provisions for wood construction noted in IBC Section 2302.1^{xxi} and IRC Section R301.1.3 apply to EcoSmart™ Studs for Allowable Stress Design (ASD) unless otherwise noted in this report.
- 6.3.3 Design of connections using EcoSmart™ Studs shall be in accordance with NDS.
- 6.3.4 Reference design values for EcoSmart™ Studs are specified in **Table 5**.
- 6.3.5 Reference design values for EcoSmart™ Studs shall be multiplied by the adjustment factors specified in NDS Section 4.3 except that the size factor C_F , shall be taken as 1.0.

Table 5. EcoSmart Studs Allowable Design Values

| Product | F_b (psi) | F_t (psi) | F_v (psi) | F_c (psi) | $F_{c\perp}$ (psi) | EI (lb-in ²) | MOE (psi) | I (in ⁴) | S (in ³) |
|---------------|-------------|-------------|-------------|-------------|--------------------|--------------------------|-----------|----------------------|----------------------|
| Auxiliary 2x6 | 470 | 455 | 20 | 1265 | 425 | 18,331,000 | 868,600 | 20.8 | 7.6 |
| 2x6 | 440 | 335 | 20 | 1265 | 425 | 14,903,000 | 686,700 | 20.8 | 7.6 |
| 2x8 | 830 | 475 | 25 | 1210 | 425 | 31,056,000 | 641,000 | 47.6 | 13.1 |

- A single EcoSmart Stud has a bearing surface of 4.8 sq.in.when in the vertical orientation.
- Values are based on full wall assembly tests with EcoSmart Studs spaced a maximum of 24" on center and are reported on a per stud basis.
- Values include size factor adjustments as appropriate.
- Values may be adjusted by NDS adjustment factors except the size Factor, C_F shall be taken as 1.0.

- 6.3.6 EcoSmart™ Studs used in wall assemblies designed as shear walls are permitted to be designed in accordance with the methodology used in SDPWS for WSP using the capacities shown in **Table 6**.

Table 6. Allowable Unit Shear Capacity for EcoSmart Stud framed Walls (Wind)¹

| Product | Exterior Sheathing ¹ | Interior Sheathing | Maximum Stud Spacing (in) | Allowable Unit Shear Capacity (plf) | Internal Shear Stiffness (kip/in) |
|--------------------------------------|---------------------------------|--------------------|---------------------------|-------------------------------------|-----------------------------------|
| Wall Assembly with 2x6 EcoSmart Stud | 7/16 OSB | None | 24 | 175 | 7.5 |

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 lb/ft = 0.0146 kN/m, 1 psf = 0.0479 kN/m², 1 psi = 0.00689 MPa, 1 mph = 1.61 km/h, 1 F-ft²-h/Btu = 0.1761 K-m²/W
1. OSB sheathing fastened with 2 3/8" x 0.113" diameter nails, 6 inches on center at panel edged and 12" on center at intermediate studs.

- 6.3.7 Wall assemblies using EcoSmart™ Studs shall be designed to resist uplift load forces using accepted engineering practices.
- 6.3.8 Wall assemblies using EcoSmart™ Studs shall be designed to resist transverse wind load forces using accepted engineering practices.
- 6.4 Where the application falls outside of the performance evaluation, conditions of use and/or installation requirements set forth herein, alternative techniques shall be permitted in accordance with accepted engineering practice and experience. This includes but is not limited to the following areas of engineering: mechanics or materials, structural, building science and fire science.

7 Certified Performance^{xxii}

- 7.1 All construction methods shall conform to accepted engineering practices to ensure durable, livable and safe construction and shall demonstrate acceptable workmanship reflecting journeyman quality of work of the various trades.^{xxiii}
- 7.2 The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.^{xxiv}

8 Regulatory Evaluation and Accepted Engineering Practice

- 8.1 EcoSmart™ Stud complies with the following legislatively adopted regulations and/or accepted engineering practice for the following reasons:
- 8.1.1 Lateral force resisting systems for use in both wind and seismic applications follow the performance-based provisions of IBC Section 2306.1, IBC Section 2306.3 and/or Section 4.3 SDPWS for light-frame wood wall assemblies.
- 8.2 This report examines the EcoSmart™ Stud for the following:
- 8.2.1 Use as wall studs in wood framed construction in accordance with IBC Chapter 23 and IRC Chapter 6.
- 8.2.2 Use in IRC braced wall applications in accordance with IBC Section 2305 and IRC Section R602.10
- 8.2.3 Use as an alternative material to that described in IBC Chapter 23 in particular, compliance with requirements for the design and construction of wood-based products as described in IBC Section 2301.2 for Allowable Stress Design (ASD).
- 8.2.4 Structural performance under lateral load conditions for use with the IBC performance-based provisions, IBC Section 2306.1 and IBC Section 2306.3 for light-frame wood wall assemblies.
- 8.2.5 Structural performance under lateral load conditions for use as an alternative to SDPWS Section 4.3 Wood Frame Shear Walls.
- 8.2.6 Compliance with IBC Section 2308, IBC Section 2304 and IRC Chapter 6 for conventional light-frame construction applications.



- 8.2.7 Use as an alternative material and method of construction in compliance with IBC Section 104.11 and IRC Section R104.11.
- 8.2.8 When used in an application that exceeds the limits of IBC Section 2308 or IRC Section R301, an engineered design submitted in accordance with IRC Section R301.1.3 and this report is required.
- 8.3 Any building code, regulation and/or accepted engineering evaluations (i.e., research reports, duly authenticated reports, etc.) that are conducted for this Listing were performed by DrJ Engineering, LLC (DrJ), an ISO/IEC 17065 accredited certification body and a professional engineering company operated by RDP/approved sources. DrJ is qualified^{xxv} to practice product and regulatory compliance services within its scope of accreditation and engineering expertise, respectively.
- 8.4 Engineering evaluations are conducted with DrJ's ANAB accredited ICS code scope of expertise, which are also its areas of professional engineering competence.
- 8.5 Any regulation specific issues not addressed in this section are outside the scope of this report.

9 Installation

- 9.1 Installation shall comply with the approved construction documents, the manufacturer installation instructions, this report and the applicable building code.
- 9.2 In the event of a conflict between the manufacturer installation instructions and this report, the more restrictive shall govern.
- 9.3 *Installation Procedure*
 - 9.3.1 EcoSmart™ Studs are designed to be used as a replacement of nominal solid sawn lumber as wall studs using the material properties and provisions defined in this report.
 - 9.3.2 Install EcoSmart™ Studs in the same manner as solid sawn lumber, except as noted herein.
 - 9.3.2.1 EcoSmart™ Studs should be installed with the “nubs” (see **Figure 1**) facing the exterior portion of the wall.
 - 9.3.2.2 EcoSmart Auxiliary Studs may be used for door and window applications.
- 9.4 *Drilling and Notching*
 - 9.4.1 Most applications allow plumbing and electrical to be run through the EcoSmart™ Studs without notching or drilling.
 - 9.4.2 Where notching or drilling is required, reinforcement of the stud is required using accepted engineering practice or guidance provided by the manufacturer.
 - 9.4.2.1 Alternately, the EcoSmart™ Stud may be replaced with solid sawn lumber using the provisions of the applicable code for drilling and notching.
 - 9.4.3 More detailed information can be found on the EcoSmart™ Stud website at <https://ecosmartstud.com/how-to-install/>.

10 Substantiating Data

- 10.1 Testing has been performed under the supervision of a professional engineer and/or under the requirements of ISO/IEC 17025 as follows:
 - 10.1.1 Lateral shear testing for shear strength and shear stiffness in accordance with ASTM E564
 - 10.1.2 Beam Flexure Test for moment and flexural rigidity in accordance with ASTM D198
 - 10.1.3 Tensile strength in accordance with ASTM D198
 - 10.1.4 Compression strength in accordance with ASTM D198
- 10.2 Information contained herein may include the result of testing and/or data analysis by sources that are approved agencies, approved sources and/or RDPs. Accuracy of external test data and resulting analysis is relied upon.

- 10.3 Where pertinent, testing and/or engineering analysis are based upon provisions that have been codified into law through state or local adoption of regulations and standards. The developers of these regulations and standards are responsible for the reliability of published content. DrJ's engineering practice may use a regulation-adopted provision as the control. A regulation-endorsed control versus a simulation of the conditions of application to occur establishes a new material as being equivalent to the regulatory provision in terms of quality, strength, effectiveness, fire resistance, durability and safety.
- 10.4 The accuracy of the provisions provided herein may be reliant upon the published properties of raw materials, which are defined by the grade mark, grade stamp, mill certificate, or duly authenticated reports from approved agencies and/or approved sources provided by the supplier. These are presumed to be minimum properties and relied upon to be accurate. The reliability of DrJ's engineering practice, as contained in this duly authenticated report, may be dependent upon published design properties by others.
- 10.5 Testing and engineering analysis: The strength, rigidity and/or general performance of component parts and/or the integrated structure are determined by suitable tests that simulate the actual conditions of application that occur and/or by accepted engineering practice and experience.^{xxvi}
- 10.6 Where additional condition of use and/or regulatory compliance information is required, please search for EcoSmart™ Stud on the DrJ Certification website.

11 Findings

- 11.1 As outlined in Section 6, the EcoSmart™ Stud has performance characteristics that were tested and/or meet applicable regulations and is suitable for use pursuant to its specified purpose.
- 11.2 When used and installed in accordance with this duly authenticated report and the manufacturer installation instructions, EcoSmart™ Stud shall be approved for the following applications:
- 11.2.1 An alternate to solid wood studs for wall structural members. Any design incorporating EcoSmart™ Studs is permitted in accordance with accepted engineering procedures, experience, and technical judgement. Reference allowable design values as specified in **Table 5** shall be used in accordance with accepted engineered design.
- 11.3 Unless exempt by state statute, when EcoSmart™ Stud is to be used as a structural and/or building envelope component in the design of a specific building, the design shall be performed by an RDP.
- 11.4 Any application specific issues not addressed herein can be engineered by an RDP. Assistance with engineering is available from ViCa3 Ventures.
- 11.5 IBC Section 104.11 (IRC Section R104.11 and IFC Section 104.10^{xxvii} are similar) in pertinent part states:
- 104.11 Alternative materials, design and methods of construction and equipment.** The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code. Where the alternative material, design or method of construction is not approved, the building official shall respond in writing, stating the reasons the alternative was not approved.
- 11.6 **Approved:**^{xxviii} Building regulations require that the building official shall accept duly authenticated reports.^{xxix}
- 11.6.1 An approved agency is "approved" when it is ANAB ISO/IEC 17065 accredited.
- 11.6.2 An approved source is "approved" when an RDP is properly licensed to transact engineering commerce.
- 11.6.3 Federal law, Title 18 US Code Section 242, requires that where the alternative product, material, service, design, assembly and/or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved. Denial without written reason deprives a protected right to free and fair competition in the marketplace.



- 11.7 DrJ is a licensed engineering company, employs licensed RDPs and is an ANAB-Accredited Product Certification Body – Accreditation #1131.
- 11.8 Through the IAF Multilateral Agreements (MLA), this Duly Authenticated Report can be used to obtain product approval in any jurisdiction or country because all ANAB ISO/IEC 17065 Duly Authenticated Reports are equivalent.^{xxx}

12 Conditions of Use

- 12.1 Material properties shall not fall outside the boundaries defined in Section 6.
- 12.2 As defined in Section 6, where material and/or engineering mechanics properties are created for load resisting design purposes, the resistance to the applied load shall not exceed the ability of the defined properties to resist those loads using the principles of accepted engineering practice.
- 12.3 As listed herein, EcoSmart™ Studs shall be limited to use with wind design controls. Use in buildings constructed in accordance with the IRC in SDC A, B and detached dwellings in SDC C are also permitted.
- 12.4 When required by adopted legislation and enforced by the building official, also known as the authority having jurisdiction (AHJ) in which the project is to be constructed:
- 12.4.1 Any calculations incorporated into the construction documents shall conform to accepted engineering practice and, when prepared by an approved source, shall be approved when signed and sealed.
 - 12.4.2 This report and the installation instructions shall be submitted at the time of permit application.
 - 12.4.3 This innovative product has an internal quality control program and a third-party quality assurance program.
 - 12.4.4 At a minimum, this innovative product shall be installed per Section 9 of this report.
 - 12.4.5 The review of this report by the AHJ shall comply with IBC Section 104 and IBC Section 105.4.
 - 12.4.6 This innovative product has an internal quality control program and a third party quality assurance program in accordance with IBC Section 104.4, IBC Section 110.4, IBC Section 1703, IRC Section R104.4 and IRC Section R109.2.
 - 12.4.7 The application of this innovative product in the context of this report, is dependent upon the accuracy of the construction documents, implementation of installation instructions, inspection as required by IBC Section 110.3, IRC Section R109.2 and any other regulatory requirements that may apply.
- 12.5 The approval of this report by the AHJ shall comply with IBC Section 1707.1, where legislation states in part, *“the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new material or assemblies as provided for in Section 104.11”*, all of IBC Section 104 and IBC Section 105.4.
- 12.6 Design loads shall be determined in accordance with the regulations adopted by the jurisdiction in which the project is to be constructed and/or by the building designer (i.e., owner or RDP).
- 12.7 The actual design, suitability and use of this report for any particular building, is the responsibility of the owner or the authorized agent of the owner.



13 Identification

- 13.1 The innovative product listed in Section 1.1 is identified by a label on the board or packaging material bearing the manufacturer name, product name, this report number and other information to confirm code compliance.
- 13.2 Additional technical information can be found at www.ecosmartstud.com.

14 Review Schedule

- 14.1 This report is subject to periodic review and revision. For the latest version, visit drjcertification.org.
- 14.2 For information on the status of this report, please contact [DrJ Certification](#).

15 Approved for Use Pursuant to U.S. and International Legislation Defined in Appendix A

- 15.1 EcoSmart™ Stud is included in this report published by an approved agency that is concerned with evaluation of products or services, maintains periodic inspection of the production of listed materials or periodic evaluation of services. This report states either that the material, product, or service meets recognized standards or has been tested and found suitable for a specified purpose. This report meets the legislative intent and definition of being acceptable to the AHJ.



Appendix A

1 Legislation that Authorizes AHJ Approval

- 1.1 **Fair Competition:** State legislatures have adopted Federal regulations for the examination and approval of building code referenced and alternative products, materials, designs, services, assemblies and/or methods of construction that:
 - 1.1.1 Advance Innovation,
 - 1.1.2 Promote competition so all businesses have the opportunity to compete on price and quality in an open market on a level playing field unhampered by anticompetitive constraints, and
 - 1.1.3 Benefit consumers through lower prices, better quality and greater choice.
- 1.2 **Adopted Legislation:** The following local, state and federal regulations affirmatively authorize this innovative product to be approved by AHJs, delegates of building departments and/or delegates of an agency of the federal government:
 - 1.2.1 Interstate commerce is governed by the Federal Department of Justice to encourage the use of innovative products, materials, designs, services, assemblies and/or methods of construction. The goal is to “protect economic freedom and opportunity by promoting free and fair competition in the marketplace.”
 - 1.2.2 Title 18 US Code Section 242 affirms and regulates the right of individuals and businesses to freely and fairly have new products, materials, designs, services, assemblies and/or methods of construction approved for use in commerce. Disapproval of alternatives shall be based upon non-conformance with respect to specific provisions of adopted legislation and shall be provided in writing stating the reasons why the alternative was not approved, with reference to the specific legislation violated.
 - 1.2.3 The federal government and each state have a public records act. In addition, each state also has legislation that mimics the federal Defend Trade Secrets Act 2016 (DTSA),^{xxx} where providing test reports, engineering analysis and/or other related IP/TS is subject to prison of not more than ten years^{xxxii} and/or a \$5,000,000 fine or 3 times the value of^{xxxiii} the Intellectual Property (IP) and Trade Secrets (TS).
 - 1.2.3.1 Compliance with public records and trade secret legislation requires approval through the use of Listings, certified reports, Technical Evaluation Reports, duly authenticated reports and/or research reports prepared by approved agencies and/or approved sources.
 - 1.2.4 For new materials^{xxxiv} that are not specifically provided for in any regulation, the design strengths and permissible stresses shall be established by tests, where suitable load tests simulate the actual loads and conditions of application that occur.
 - 1.2.5 The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design using accepted engineering practice.^{xxxv}
 - 1.2.6 The commerce of approved sources (i.e., registered PEs) is regulated by professional engineering legislation. Professional engineering commerce shall always be approved by AHJs, except where there is evidence provided in writing, that specific legislation has been violated by an individual registered PE.
 - 1.2.7 The AHJ shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in IBC Section 104.11.^{xxxvi}

- 1.3 **Approved^{xxxvii} by Los Angeles:** The Los Angeles Municipal Code (LAMC) states in pertinent part that the provisions of LAMC are not intended to prevent the use of any material, device, or method of construction not specifically prescribed by LAMC. The Department shall use Part III, Recognized Standards in addition to Part II, Uniform Building Code Standards of Division 35, Article 1, Chapter IX of the LAMC in evaluation of products for approval where such standard exists for the product or the material and may use other approved standards that apply. Whenever tests or certificates of any material or fabricated assembly are required by Chapter IX of the LAMC, such tests or certification shall be made by a testing agency approved by the Superintendent of Building to conduct such tests or provide such certifications. The testing agency shall publish the scope and limitation(s) of the listed material or fabricated assembly.^{xxxviii} The Superintendent of Building Approved Testing Agency Roster is provided by the Los Angeles Department of Building and Safety (LADBS). The Center for Building Innovation (CBI) Certificate of Approval License is TA24945. Tests and certifications found in a DrJ Listing are LAMC approved. In addition, the Superintendent of Building shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in the California Building Code (CBC) Section 1707.1.^{xxxix}
- 1.4 **Approved by Chicago:** The Municipal Code of Chicago (MCC) states in pertinent part that an Approved Agency is a Nationally Recognized Testing Laboratory (NRTL) acting within its recognized scope and/or a certification body accredited by the American National Standards Institute (ANSI) acting within its accredited scope. Construction materials and test procedures shall conform to the applicable standards listed in the MCC. Sufficient technical data shall be submitted to the building official to substantiate the proposed use of any product, material, service, design, assembly and/or method of construction not specifically provided for in the MCC. This technical data shall consist of research reports from approved sources (i.e., MCC defined Approved Agencies).
- 1.5 **Approved by New York City:** The 2022 NYC Building Code (NYCBC) states in part that an approved agency shall be deemed^{xl} an approved testing agency via ISO/IEC 17025 accreditation, an approved inspection agency via ISO/IEC 17020 accreditation and an approved product evaluation agency via ISO/IEC 17065 accreditation. Accrediting agencies, other than federal agencies, must be members of an internationally recognized cooperation of laboratory and inspection accreditation bodies subject to a mutual recognition agreement^{xli} (i.e., ANAB, International Accreditation Forum (IAF), etc.).
- 1.6 **Approved by Florida:** Statewide approval of products, methods, or systems of construction shall be approved, without further evaluation by:
- 1.6.1 A certification mark or listing of an approved certification agency,
 - 1.6.2 A test report from an approved testing laboratory,
 - 1.6.3 A product evaluation report based upon testing or comparative or rational analysis, or a combination thereof, from an approved product evaluation entity, or
 - 1.6.4 A product evaluation report based upon testing, comparative or rational analysis, or a combination thereof, developed, signed and sealed by a professional engineer or architect, licensed in Florida.
- 1.7 For local product approval, products or systems of construction shall demonstrate compliance with the structural wind load requirements of the Florida Building Code (FBC) through one of the following methods;
- 1.7.1 A certification mark, listing or label from a commission-approved certification agency indicating that the product complies with the code,
 - 1.7.2 A test report from a commission-approved testing laboratory indicating that the product tested complies with the code,
 - 1.7.3 A product-evaluation report based upon testing, comparative or rational analysis, or a combination thereof, from a commission-approved product evaluation entity which indicates that the product evaluated complies with the code,
 - 1.7.4 A product-evaluation report or certification based upon testing or comparative or rational analysis, or a combination thereof, developed and signed and sealed by a Florida professional engineer or Florida registered architect, which indicates that the product complies with the code, or
 - 1.7.5 A statewide product approval issued by the Florida Building Commission.

- 1.8 The Florida Department of Business and Professional Regulation (DBPR) website provides a listing of companies certified as a Product Evaluation Agency (i.e., EVLMiami 13692), a Product Certification Agency (i.e., CER10642) and as a Florida Registered Engineer (i.e., ANE13741).
- 1.9 **Approved by Miami-Dade County (i.e., Notice of Acceptance [NOA]):** A Florida statewide approval is an NOA. An NOA is a Florida local product approval. By Florida law, Miami-Dade County shall accept the statewide and local Florida Product Approval as provided for in Florida legislation 553.842 and 553.8425.
- 1.10 **Approved by New Jersey:** Pursuant to the 2018 Building Code of New Jersey in IBC Section 1707.1 General,^{xlii} it states: *"In the absence of approved rules or other approved standards, the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in the administrative provisions of the Uniform Construction Code (N.J.A.C. 5:23)"*.^{xliii} Furthermore N.J.A.C 5:23-3.7 states: *"Municipal approvals of alternative materials, equipment, or methods of construction."*
 - 1.10.1 **Approvals:** Alternative materials, equipment, or methods of construction shall be approved by the appropriate subcode official provided the proposed design is satisfactory and that the materials, equipment, or methods of construction are suitable for the intended use and are at least the equivalent in quality, strength, effectiveness, fire resistance, durability and safety of those conforming with the requirements of the regulations.
 - 1.10.1.1 A field evaluation label and report or letter issued by a nationally recognized testing laboratory verifying that the specific material, equipment, or method of construction meets the identified standards or has been tested and found to be suitable for the intended use, shall be accepted by the appropriate subcode official as meeting the requirements of the above.
 - 1.10.1.2 Reports of engineering findings issued by nationally recognized evaluation service programs such as but not limited to, the Building Officials and Code Administrators (BOCA), the International Conference of Building Officials (ICBO), the Southern Building Code Congress International (SBCCI), the International Code Council (ICC) and the National Evaluation Service, Inc., shall be accepted by the appropriate subcode official as meeting the requirements of the above.
 - 1.10.2 The New Jersey Department of Community Affairs has confirmed that technical evaluation reports, from any accredited entity listed by ANAB, meets the requirements of item the previous paragraph, given that the listed entities are no longer in existence and/or do not provide *"reports of engineering findings"*.
- 1.11 **Approved by the Code of Federal Regulations Manufactured Home Construction and Safety Standards:** Pursuant to Title 24, Subtitle B, Chapter XX, Part 3282.14^{xliv} and Part 3280,^{xlv} the Department encourages innovation and the use of new technology in manufactured homes. The design and construction of a manufactured home shall conform to the provisions of Part 3282 and Part 3280 where key approval provisions in mandatory language follow:
 - 1.11.1 *"All construction methods shall be in conformance with accepted engineering practices"*
 - 1.11.2 *"The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur."*
 - 1.11.3 *"The design stresses of all materials shall conform to accepted engineering practice."*

- 1.12 **Approval by US, Local and State Jurisdictions in General:** In all other local and state jurisdictions, the adopted building code legislation states in pertinent part that:
- 1.12.1 For new materials that are not specifically provided for in this code, the design strengths and permissible stresses shall be established by tests.^{xlvi}
 - 1.12.2 For innovative alternatives and/or methods of construction, the building official shall accept duly authenticated reports from approved agencies with respect to the quality and manner of use of new materials or assemblies.^{xlvii}
 - 1.12.2.1 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is in the ANAB directory.
 - 1.12.2.2 An approved source is “approved” when an RDP is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.^{xlviii}
 - 1.12.3 The design strengths and permissible stresses of any structural material...shall conform to the specifications and methods of design of accepted engineering practice performed by an approved source.^{xlix}
- 1.13 **Approval by International Jurisdictions:** The USMCA and GATT agreements provide for approval of innovative materials, designs, services and/or methods of construction through the Agreement on Technical Barriers to Trade and the IAF Multilateral Recognition Arrangement (MLA), where these agreements:
- 1.13.1 State that conformity assessment procedures (i.e., ISO/IEC 17020, 17025, 17065, etc.) are prepared, adopted and applied so as to grant access for suppliers of like products originating in the territories of other Members under conditions no less favourable than those accorded to suppliers of like products of national origin or originating in any other country, in a comparable situation.
 - 1.13.2 **Approved:** The purpose of the MLA is to ensure mutual recognition of accredited certification and validation/verification statements between signatories to the MLA and subsequently, acceptance of accredited certification and validation/verification statements in many markets based on one accreditation for the timely approval of innovative materials, designs, services and/or methods of construction.
 - 1.13.3 ANAB is an IAF-MLA signatory where recognition of certificates, validation and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA, with the appropriate scope, shall be approved.ⁱ
 - 1.13.4 Therefore, all ANAB ISO/IEC 17065 Duly Authenticated Reports are approval equivalent.ⁱⁱ
- 1.14 Approval equity is a fundamental commercial and legal principle.ⁱⁱⁱ



Notes

- i For more information, visit drjcertification.org or call us at 608-310-6748.
- ii <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1702>
- iii Alternative Materials, Design and Methods of Construction and Equipment: The provisions of any regulation code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by a regulation. Please review <https://www.justice.gov/atr/mission> and <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104.11>
- iv <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706~:text=the%20design%20strengths%20and%20permissible%20stresses%20shall%20be%20established%20by%20tests%20as>
- v The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design of accepted engineering practice. <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706~:text=shall%20conform%20to%20the%20specifications%20and%20methods%20of%20design%20of%20accepted%20engineering%20practice>
- vi <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1707.1~:text=the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies>
- vii <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1703.4.2>
- viii https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved_agency
- ix https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved_source
- x <https://www.law.cornell.edu/uscode/text/18/1832> (b) Any organization that commits any offense described in subsection (a) shall be fined not more than the greater of \$5,000,000 or 3 times the value of the stolen trade secret to the organization, including expenses for research and design and other costs of reproducing the trade secret that the organization has thereby avoided. The federal government and each state have a public records act. To follow DTSA and comply state public records and trade secret legislation requires approval through ANAB ISO/IEC 17065 accredited certification bodies or approved sources. For more information, please review this website: [Intellectual Property and Trade Secrets](https://www.intellectualpropertyandtradesecrets.com/).
- xi <https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>
- xii <https://www.cbiteest.com/accreditation/>
- xiii <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104~:text=to%20enforce%20the%20provisions%20of%20this%20code>
- xiv <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104.11~:text=Where%20the%20alternative%20material%20design%20or%20method%20of%20construction%20is%20not%20approved%20C%20the%20building%20official%20shall%20respond%20in%20writing%20C%20stating%20the%20reasons%20why%20the%20alternative%20was%20not%20approved> AND <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#105.3.1~:text=If%20the%20application%20or%20the%20construction%20documents%20do%20not%20conform%20to%20the%20requirements%20of%20pertinent%20laws%20C%20the%20building%20official%20shall%20reject%20such%20application%20in%20writing%20C%20stating%20the%20reasons%20therefore>
- xv <https://up.codes/viewer/colorado/ibc-2021/chapter/17/special-inspections-and-tests#1707.1~:text=the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies%20in%20respect%20to%20the%20quality%20and%20manner%20of%20use%20of%20new%20materials%20or%20assemblies%20as%20provided%20for%20in%20Section%20104.11>
- xvi <https://iaf.nu/en/about-iaf-mla/#~:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%20C%20with%20the%20appropriate%20scope>
- xvii True for all ANAB accredited product evaluation agencies and all International Trade Agreements.
- xviii <https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>
- xix Unless otherwise noted, all references in this Listing are from the 2021 version of the codes and the standards referenced therein. This material, product, design, service and/or method of construction also complies with the 2000-2021 versions of the referenced codes and the standards referenced therein.
- xx [https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2\(Listed%20or%20certified\)](https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2(Listed%20or%20certified)); <https://up.codes/viewer/colorado/ibc-2021/chapter/2/definitions#listed> AND <https://up.codes/viewer/colorado/ibc-2021/chapter/2/definitions#labeled>
- xxi [2015 IBC Section 2301.2](https://up.codes/viewer/colorado/ibc-2021/chapter/2/definitions#labeled)
- xxii <https://up.codes/viewer/colorado/ibc-2021/chapter/17/special-inspections-and-tests#1703.4>
- xxiii <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#~:text=All%20construction%20methods%20shall%20be%20in%20conformance%20with%20accepted%20engineering%20practices%20to%20insure%20durable%20C%20livable%20C%20and%20safe%20housing%20and%20shall%20demonstrate%20acceptable%20workmanship%20reflecting%20journeyman%20quality%20of%20work%20of%20the%20various%20trades>
- xxiv <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#~:text=The%20strength%20and%20rigidity%20of%20the%20component%20parts%20and/or%20the%20integrated%20structure%20shall%20be%20determined%20by%20engineering%20analysis%20or%20by%20suitable%20load%20tests%20to%20simulate%20the%20actual%20loads%20and%20conditions%20of%20application%20that%20occur>



- xxv Qualification is performed by a legislatively defined Accreditation Body. ANSI National Accreditation Board (ANAB) is the largest independent accreditation body in North America and provides services in more than 75 countries. DrJ is an ANAB accredited product certification body.
- xxvi See Code of Federal Regulations (CFR) Title 24 Subtitle B Chapter XX Part 3280 for definition.
- xxvii 2018 IFC Section 104.9
- xxviii Approved is an adjective that modifies the noun after it. For example, Approved Agency means that the Agency is accepted officially as being suitable in a particular situation. This example conforms to IBC/IRC/IFC Section 201.4 where the building code authorizes sentences to have an ordinarily accepted meaning such as the context implies.
- xxix <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>
- xxx Multilateral approval is true for all ANAB accredited product evaluation agencies and all International Trade Agreements.
- xxxi <http://www.drjengineering.org/AppendixC> AND <https://www.drjcertification.org/cornell-2016-protection-trade-secrets>
- xxxi <https://www.law.cornell.edu/uscode/text/18/1832#:~:text=imprisoned%20not%20more%20than%2010%20years>
- xxxi <https://www.law.cornell.edu/uscode/text/18/1832#:~:text=Any%20organization%20that,has%20thereby%20avoided>
- xxxiv <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706.2>
- xxv IBC 2021, Section 1706.1 Conformance to Standards
- xxvi IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General
- xxvii See Section 11 for the distilled building code definition of **Approved**
- xxviii Los Angeles Municipal Code, SEC. 98.0503. TESTING AGENCIES
- xxix <https://up.codes/viewer/california/ca-building-code-2022/chapter/17/special-inspections-and-tests#1707.1>
- xl New York City, The Rules of the City of New York, § 101-07 Approved Agencies
- xli New York City, The Rules of the City of New York, § 101-07 Approved Agencies
- xlii <https://up.codes/viewer/new-jersey/ibc-2018/chapter/17/special-inspections-and-tests#1707.1>
- xliii <https://www.nj.gov/dca/divisions/codes/codreg/ucc.html>
- xliv <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3282/subpart-A/section-3282.14>
- xlv <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>
- xlvi IBC 2021, Section 1706 Design Strengths of Materials, 1706.2 New Materials. Adopted law pursuant to IBC model code language 1706.2.
- xlvi IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General. Adopted law pursuant to IBC model code language 1707.1.
- xlvi <https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>
- xlvi IBC 2021, Section 1706 Design Strengths of Materials, Section 1706.1 Conformance to Standards Adopted law pursuant to IBC model code language 1706.1.
- i <https://iaf.nu/en/about-iaf-mla/#:~:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope>
- li True for all ANAB accredited product evaluation agencies and all International Trade Agreements.
- lii <https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>